

# IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations through the Use of Optical Fiber Systems

IEEE Power and Energy Society

Sponsored by the  
Power System Communications Committee



# **IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations through the Use of Optical Fiber Systems**

Sponsor

**Power System Communications Committee**  
of the  
**IEEE Power and Energy Society**

Approved 23 August 2013

**IEEE-SA Standards Board**

**Abstract:** Safe and reliable methods for the electrical protection of telecommunication facilities serving electric supply locations through the use of optical fiber systems for the entire facility are presented in this standard.

**Keywords:** electric power stations, electric supply locations, electrical protection, fiber optic systems, ground potential rise, high-voltage environment, IEEE 487.2™, optical fiber systems

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2013 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 20 September 2013. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-8554-5      STD98326  
Print: ISBN 978-0-7381-8555-2      STDPD98326

*IEEE prohibits discrimination, harassment, and bullying.*

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**Notice and Disclaimer of Liability Concerning the Use of IEEE Documents:** IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon any IEEE Standard document.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained in its standards is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

**Translations:** The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

**Official Statements:** A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

**Comments on Standards:** Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important to ensure that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. Any person who would like to participate in evaluating comments or revisions to an IEEE standard is welcome to join the relevant IEEE working group at <http://standards.ieee.org/develop/wg/>.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

**Photocopies:** Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Notice to users

### Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

### Updating of IEEE documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://standards.ieee.org/index.html> or contact the IEEE at the address listed previously. For more information about the IEEE Standards Association or the IEEE standards development process, visit IEEE-SA Website at <http://standards.ieee.org/index.html>.

### Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

### Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this IEEE standard was completed, the Wire-line Working Group had the following membership:

**Percy E. Pool**, *Chair*  
**Larry S. Young**, *Vice Chair*

Steven Blume  
Joe Boyles  
Timothy Conser  
Bhimesh Dahal  
Jean de Seve

Ernest Duckworth  
John Fuller  
Ernest Gallo  
Dave Hartmann

Dan Jendek  
Richard Knight  
Randall Mears  
Mark Tirio  
Thomas Vo

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman  
Ali Al Awazi  
Thomas Barnes  
David Bassett  
R. Baysden  
Steven Blume  
Gustavo Brunello  
William Bush  
William Byrd  
Timothy Conser  
Randall Dotson  
Ernest Duckworth  
Dan Evans  
Doaa Galal  
Frank Gerleve  
Mietek Glinkowski  
Jalal Gohari  
Randall Groves  
Jeffrey Helzer  
Lee Herron  
Gary Heuston  
Werner Hoelzl

C. Huntley  
Noriyuki Ikeuchi  
Gael Kennedy  
Yuri Khersonsky  
Richard Knight  
Jim Kulchisky  
Chung-Yiu Lam  
Michael Lauxman  
Lawrenc Long  
William McCoy  
Joseph Mears  
Jose Morales  
Jerry Murphy  
H. Nerhood  
Michael S. Newman  
Joe Nims  
Gary Nissen  
Lorraine Padden  
Bansi Patel  
Percy E. Pool  
Craig Preuss

John Randolph  
Michael Roberts  
Charles Rogers  
Thomas Rozek  
Steven Sano  
Bartien Sayogo  
Dennis Schlender  
Devki Sharma  
Jerry Smith  
John Spare  
Gary Stoedter  
William Taylor  
David Tepen  
Mark Tirio  
Thomas Tullia  
Eric Udren  
John Vergis  
Jane Verner  
John Wang  
Kenneth White  
James Wilson  
Larry S. Young

When the IEEE-SA Standards Board approved this standard on 23 August 2013, it had the following membership:

**John Kulick**, *Chair*  
**David J. Law**, *Vice Chair*  
**Richard H. Hulett**, *Past Chair*  
**Konstantinos Karachalios**, *Secretary*

Masayuki Ariyoshi  
Peter Balma  
Farooq Bari  
Ted Burse  
Wael William Diab  
Stephen Dukes  
Jean-Philippe Faure  
Alexander Gelman

Mark Halpin  
Gary Hoffman  
Paul Houz e  
Jim Hughes  
Michael Janezic  
Joseph L. Koepfinger\*  
Oleg Logvinov

Ron Petersen  
Gary Robinson  
Jon Walter Rosdahl  
Adrian Stephens  
Peter Sutherland  
Yatin Trivedi  
Phil Winston  
Yu Yuan

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, *DOE Representative*  
Michael Janezic, *NIST Representative*

Julie Alessi  
*IEEE Standards Program Manager, Document Development*

Erin Spiewak  
*IEEE Standards Program Manager, Technical Program Development*



## Introduction

This introduction is not part of IEEE Std 487.2-2013, IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations through the Use of Optical Fiber Systems.

Some electrical environments, collectively called electric supply locations, require the application of unique electrical protection techniques because of their special nature. One such environment is the electric power station or substation. Another is at, or near, power line transmission and distribution structures such as towers or poles. Such structures often provide a convenient site for the location of wireless, personal communications service, and cellular antennas and their associated electronic equipment that is served by a link to the wired telecommunications network.

This standard assumes that optical fiber cables are to be used to provide electrical isolation for telecommunications services to these electric supply locations. Refer to IEEE Std 367™ or IEEE Std 487™ for other applications.

This standard describes applications consisting entirely of optical fiber cables. For applications where both metallic cables and fiber cables are used (i.e., hybrid applications), the user is referred to IEEE Std 487.3™.

Some delays in site activation often occur due to the time involved in obtaining electrical information data for most high-voltage tower or pole sites. The delays may be eliminated by using the optical fiber solutions described in this standard.

This project is part of a reorganization of IEEE Std 487™ in which the main document is broken down into a family of related documents (i.e., dot-series) segregated on the basis of technology:

- 487
- 487.1 [Metallic wire-line]
- 487.2 [Optical fiber systems]
- 487.3 [Hybrid facilities]
- 487.4 [Neutralizing transformers]
- 487.5 [Isolation transformers]

This standard has been prepared by the Wire-Line Subcommittee of the Power System Communications Committee of the IEEE Power and Energy Society. This standard represents the consensus of both power and telecommunications engineers.

This standard, along with IEEE Std 487.3™, will replace, in its entirety, the existing IEEE Std 1590™-2009.

## Contents

1. Overview .....	1
1.1 Scope .....	2
1.2 Purpose .....	2
2. Normative references.....	2
3. Definitions, abbreviations, and acronyms .....	3
3.1 Definitions .....	3
3.2 Abbreviations and acronyms .....	4
4. Overview of telecommunications service to electric supply locations .....	5
4.1 Electric power stations.....	5
4.2 Wireless cell sites .....	5
4.3 Service via metallic wire-line facilities .....	5
4.4 Service via fiber optic facilities .....	5
4.5 Service via microwave systems .....	6
4.6 Wireless site owners' responsibilities.....	6
5. Powering arrangements at electric supply locations .....	6
5.1 Typical ac power service to wireless locations at power line towers or poles.....	6
5.2 Distribution transformers.....	6
5.3 Electrostatic coupling .....	8
5.4 Engine generating units .....	8
6. Telecommunications service to electric supply locations.....	9
6.1 Wireless sites at electric supply locations.....	9
6.2 Wireless sites within zone of influence (ZOI) .....	10
6.3 Locations at, or near, high-voltage towers or poles .....	10
6.4 Electrical protection considerations for telecommunications outside plant serving high-voltage tower and pole sites .....	11
6.5 Electrical protection measures .....	11
7. Telecommunications service to electric supply locations—recommendations.....	12
7.1 GPR-related protection considerations .....	12
7.2 Induction-related protection considerations.....	12
7.3 Benefits of all-dielectric cables.....	12
8. Construction concerns and general recommendations.....	13
8.1 Existing facilities .....	13
9. Typical dc powering arrangements at the optical electrical interface (OEI).....	13
10. Installation and inspection considerations .....	13
10.1 Installation considerations .....	13
10.2 Inspection considerations.....	14
11. Safety.....	14
11.1 General safety considerations .....	14
11.2 Electrical safety .....	14
11.3 Radio frequency (RF) safety awareness .....	15
Annex A (informative) Bibliography .....	16

Annex B (informative) Locating buried plant .....	19
B.1 Overview.....	19
B.2 Locating methods.....	19
B.3 Benefits .....	20
B.4 Recommendations.....	20



# IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations through the Use of Optical Fiber Systems

*IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

During a power fault that occurs externally to an electric supply location, some portion of the fault current will return to the power system’s source(s) of generating power in the network through the electric supply location grid impedance. This current return may cause a large increase in potential to be developed in and around the electric supply location [i.e., ground potential rise (GPR) zone of influence (ZOI)] with respect to remote earth locations. This GPR will result in current flowing into the wire-line networks or the power system neutral or any metallic infrastructures connected to the grid under study. For telecommunication facilities, this creates a transferred voltage condition as defined in 8.1.6 and 17.9 of IEEE Std 80™-2000.

When a fault occurs on the power line transmission and distribution towers or poles, the current will return to the source(s) via the earth and various metallic paths available. The fault current will divide, and the resulting currents will return to their source(s) in proportion to their individual path impedances. Some power systems have a neutral return path while others do not. The absence of the neutral return path tends to produce a higher GPR. When metallic telecommunications cables and secondary neutrals are extended into electric supply locations, they represent remote earth and provide a significant discharge path during faults. A properly engineered and installed all-dielectric optical fiber cable will provide immunity from the effects of fault-produced GPR and induction, as well as lightning-induced phenomena, at these locations. Although the use of non-dielectric optical fiber cables is not recommended, guidance is provided for existing non-dielectric optical fiber cables.