

FINAL VERSION

VERSION FINALE

**Powertrack systems –
Part 1: General requirements**

**Systèmes de conducteurs préfabriqués –
Partie 1: Exigences générales**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	10
4 General requirements.....	15
5 General notes on tests	16
6 Ratings.....	17
7 Classification.....	17
8 Marking and documentation.....	18
9 Construction.....	21
10 Clearances, creepage distances and solid insulation	24
10.1 General.....	24
10.2 Clearances.....	24
10.2.1 General	24
10.2.2 Clearances for basic insulation.....	25
10.2.3 Clearances for functional insulation.....	25
10.2.4 Clearances for supplementary insulation	25
10.2.5 Clearances for reinforced insulation	26
10.3 Creepage distances.....	26
10.3.1 General	26
10.3.2 Creepage distances for basic insulation.....	27
10.3.3 Creepage distances for functional insulation.....	28
10.3.4 Creepage distances for supplementary insulation	28
10.3.5 Creepage distances for reinforced insulation	28
10.4 Solid insulation.....	28
11 Protection against electric shock	28
11.1 Access to live parts	28
11.2 Provision for earthing	29
11.3 Effectiveness of protective circuit continuity	29
12 Terminals and terminations	30
13 Screws, current carrying parts and connections.....	32
14 Mechanical strength	35
14.1 General.....	35
14.2 Impact test	35
14.3 Static load test	35
15 Insulation resistance test and dielectric strength test.....	36
15.1 General.....	36
15.2 Humidity treatment	37
15.3 Insulation resistance test.....	37
15.3.1 General	37
15.3.2 Test for functional insulation.....	37
15.3.3 Test for basic insulation, supplementary insulation and reinforced insulation.....	37

15.4 Dielectric strength test.....	38
16 Normal operation.....	38
17 Temperature rise.....	39
18 Short-circuit protection and short-circuit withstand strength.....	42
18.1 General.....	42
18.2 Information concerning short-circuit rating.....	42
18.3 Short circuit current values.....	43
18.3.1 Relationship between peak current and short-circuit current.....	43
18.3.2 Value and duration of the short-circuit current.....	43
18.4 Verification of short-circuit withstand strength.....	43
18.4.1 Test arrangement.....	43
18.4.2 Test conditions – General.....	43
18.4.3 Testing of the PT system.....	44
19 Resistance to heat.....	46
20 Fire hazard.....	47
20.1 Flammability.....	47
20.2 Flame spread.....	48
21 External influences.....	49
21.1 Resistance to corrosion.....	49
21.1.1 General.....	49
21.1.2 Corrosion test for dry non-aggressive environments.....	49
21.1.3 Corrosion test for powertrack in contact with wet screed material.....	49
21.2 Degrees of protection provided by enclosures.....	50
21.2.1 General.....	50
21.2.2 Protection against ingress of solid foreign objects.....	50
21.2.3 Protection against ingress of water.....	50
22 Electromagnetic compatibility.....	50
22.1 Immunity.....	50
22.2 Emission.....	50
Annex A (normative) Measurement of clearances and creepage distances.....	57
Annex B (normative) Proof tracking test.....	62
Annex C (normative) Relationship between rated impulse withstand voltage, rated voltage and overvoltage category III.....	63
Annex D (normative) Pollution degree.....	64
Annex E (informative) Diagram for the dimensioning of clearances and creepage distances.....	65
Annex F (normative) Impulse voltage test.....	66
Annex G (normative) Additional test requirements for PT systems already complying with IEC 61534-1:2011 and IEC 61534-1:2011/AMD1:2014.....	67
Bibliography.....	68
Figure 1 – Pull apparatus for testing the cord anchorage.....	51
Figure 2 – Torque apparatus for testing the cord anchorage.....	52
Figure 3 – Arrangement for flame test.....	53
Figure 4 – Enclosure for flame test.....	54
Figure 5 – Static load test for a length.....	55

Figure 6 – Static load test for a joint	55
Figure 7 – Short-circuit test arrangement	56
Figure 8 – Piston for durability of marking test	20
Table 1 – Pull and torque values for tests on cord anchorages	23
Table 2 – Minimum clearances for basic insulation	26
Table 3 – Minimum creepage distances for basic insulation	27
Table 4 – Minimum connecting capacity of terminals.....	31
Table 5 – Torque values for screws	33
Table 6 – Minimum insulation resistance.....	37
Table 7 – Dielectric strength	38
Table 8 – Temperature rise values.....	41
Table 9 – Cross-sectional areas of rigid test conductors (solid or stranded).....	41
Table 10 – Cross-sectional areas of flexible test conductors	42
Table 11 – Standard values for the factor <i>n</i>	43
Table 12 – Test temperatures for the glow wire test.....	48
Table A.1 – Minimum values of width <i>X</i>	57
Table C.1 – Rated impulse withstand voltage for PT systems energised directly from the low voltage mains	63
Table F.1 – Test voltages for verifying clearances at sea level.....	66

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWERTRACK SYSTEMS –

Part 1: General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 61534-1 edition 2.2 contains the second edition (2011-05) [documents 23A/630/FDIS and 23A/631/RVD], its amendment 1 (2014-06) [documents 23A/700A/FDIS and 23A/706/RVD] and its amendment 2 (2020-07) [documents 23A/903/FDIS and 23A/908/RVD].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 61534-1 has been prepared by subcommittee 23A: Cable management systems, of IEC technical committee 23: Electrical accessories.

The main changes from the previous edition are as follows:

- updated normative references (Clause 2);
- changes to the number of samples to be tested (Subclause 5.3);
- inclusion of a short circuit test (New Clause 18);
- changes to external influences (Clause 21).

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61534 series, under the general title *Powertrack systems*, can be found on the IEC website.

The following difference exists in the countries indicated below:

- Table 4, first column, first line: the 10 A rated terminal should be capable of clamping 1 mm² as a minimum (UK);
- Australia has specific wiring rules covering socket-outlets to be switched. In Australia, AS/NZS 3000 contains requirements for switching devices to be used in Australian and New Zealand electrical installations;
- 9.5: in Australia, fuses and fuse-links are not to be used.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Particular requirements for specific types of powertrack systems will be specified in the relevant parts 2 of IEC 61534.

For a specific type of powertrack system the requirements of Part 1 of the standard are to be considered, together with the particular requirements of the appropriate Part 2, which will supplement or modify some of the corresponding clauses in Part 1 to provide the complete requirements for that type of system.

Part 1 shall apply unless supplemented or modified by an appropriate Part 2.

POWERTRACK SYSTEMS –

Part 1: General requirements

1 Scope

1.1 This part of IEC 61534 specifies general requirements and tests for powertrack (PT) systems with a rated voltage not exceeding 277 V a.c. single phase, or 480 V a.c. two or three phase 50 Hz or 60 Hz with a rated current not exceeding 63 A. These systems are used for distributing electricity in household, commercial and industrial premises.

1.2 Powertrack systems, according to this standard, are intended for use under the following conditions:

- an ambient temperature in the range -5 °C to $+40\text{ °C}$, the average value over a 24 h period not exceeding 35 °C ;
- a situation not subject to a source of heat likely to raise temperatures above the limits specified above;
- an altitude not exceeding 2000 m above sea level;
- an atmosphere not subject to excessive pollution by smoke, chemical fumes, prolonged periods of high humidity or other abnormal conditions.

In locations where special conditions prevail, as in ships, vehicles and the like and in hazardous locations, for instance, where explosions are liable to occur, special constructions may be necessary.

This standard does not apply to

- cable trunking systems and cable ducting systems covered by IEC 61084 [8] ¹;
- busbar trunking systems covered by IEC 60439-2 [5];
- electrical supply track systems for luminaires covered by IEC 60570 [6].

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-52:2017, *Environmental testing – Part 2-52: Tests - Test Kb: Salt mist, cyclic (sodium, chloride solution)*

IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

¹ Figures in square brackets refer to the bibliography.