



## BSI Standards Publication

# Energy performance of buildings — Energy requirements for lighting

---

Part 1: Specifications, Module M9

## National foreword

This British Standard is the UK implementation of EN 15193-1:2017+A1:2021. It supersedes BS EN 15193-1:2017, which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to CEN text carry the number of the CEN amendment. For example, text altered by CEN amendment A1 is indicated by **A1** **A1**.

The UK participation in its preparation was entrusted to Technical Committee EL/1, Light and lighting applications.

A list of organizations represented on this committee can be obtained on request to its committee manager.

### Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2021  
Published by BSI Standards Limited 2021

ISBN 978 0 539 17713 8

ICS 91.120.10; 91.140.99; 91.160.01

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2017.

### Amendments/corrigenda issued since publication

Date	Text affected
30 June 2021	Implementation of CEN amendment A1:2021

---

**EUROPEAN STANDARD**  
**NORME EUROPÉENNE**  
**EUROPÄISCHE NORM**

**EN 15193-1:2017+A1**

June 2021

ICS 91.120.10; 91.140.99; 91.160.01

Supersedes EN 15193-1:2017

English Version

**Energy performance of buildings - Energy requirements  
for lighting - Part 1: Specifications, Module M9**

Performance énergétique des bâtiments - Exigences  
énergétiques pour l'éclairage - Partie 1 : Spécifications,  
module M9

Energetische Bewertung von Gebäuden - Energetische  
Anforderungen an die Beleuchtung - Teil 1:  
Spezifikationen, Modul M9

This European Standard was approved by CEN on 27 February 2017 and includes Amendment 1 approved by CEN on 4 May 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

	Page
<b>Contents</b>	
<b>European foreword .....</b>	<b>5</b>
<b>Introduction .....</b>	<b>6</b>
<b>1 Scope.....</b>	<b>9</b>
<b>2 Normative references.....</b>	<b>11</b>
<b>3 Terms and definitions .....</b>	<b>11</b>
<b>4 Symbols and abbreviations.....</b>	<b>12</b>
<b>4.1 Symbols and units.....</b>	<b>12</b>
<b>4.2 Subscripts .....</b>	<b>18</b>
<b>4.3 Abbreviations.....</b>	<b>18</b>
<b>5 Brief description of the method(s) and routing.....</b>	<b>18</b>
<b>5.1 Output of the method 1 – Comprehensive method.....</b>	<b>18</b>
<b>5.2 Optional methods .....</b>	<b>19</b>
<b>5.2.1 Method 2 – Quick calculation method .....</b>	<b>19</b>
<b>5.2.2 Method 3 – Direct metering method .....</b>	<b>19</b>
<b>5.3 Selection criteria between the methods.....</b>	<b>19</b>
<b>6 Method 1 - Calculation of the energy required for lighting .....</b>	<b>20</b>
<b>6.1 Output data .....</b>	<b>20</b>
<b>6.2 Calculation time interval and calculation period.....</b>	<b>20</b>
<b>6.3 Input data.....</b>	<b>21</b>
<b>6.3.1 Lighting system data.....</b>	<b>21</b>
<b>6.3.2 Product data .....</b>	<b>21</b>
<b>6.3.3 System design data .....</b>	<b>22</b>
<b>6.3.4 Operating conditions .....</b>	<b>23</b>
<b>6.3.5 Constants and physical data.....</b>	<b>23</b>
<b>6.4 Calculation procedure.....</b>	<b>23</b>
<b>6.4.1 Applicable time step .....</b>	<b>23</b>
<b>6.4.2 Operating conditions calculation.....</b>	<b>23</b>
<b>6.4.3 Energy for lighting calculation.....</b>	<b>23</b>
<b>6.5 Expenditure factors for lighting systems .....</b>	<b>27</b>
<b>7 Method 2 - Quick calculation of the energy required for lighting .....</b>	<b>30</b>
<b>7.1 Output data .....</b>	<b>30</b>
<b>7.2 Calculation time steps .....</b>	<b>30</b>
<b>7.3 Input data.....</b>	<b>30</b>
<b>7.3.1 Lighting system data.....</b>	<b>30</b>
<b>7.3.2 Luminaire data.....</b>	<b>31</b>
<b>7.3.3 System design data .....</b>	<b>31</b>
<b>7.3.4 Operating conditions .....</b>	<b>31</b>
<b>7.3.5 Constants and physical data.....</b>	<b>31</b>
<b>7.4 Calculation procedure.....</b>	<b>31</b>
<b>7.4.1 Applicable time step .....</b>	<b>31</b>
<b>7.4.2 Operating conditions calculation.....</b>	<b>31</b>
<b>7.4.3 Energy calculation .....</b>	<b>31</b>
<b>7.5 Expenditure factors for lighting systems .....</b>	<b>34</b>
<b>8 Method 3 - Metered energy used for lighting.....</b>	<b>34</b>
<b>8.1 Output data .....</b>	<b>34</b>
<b>8.2 Calculation time steps .....</b>	<b>35</b>
<b>8.3 Input data.....</b>	<b>35</b>

<b>8.4</b>	<b>Calculation procedure of annual energy .....</b>	<b>35</b>
<b>9</b>	<b>Quality control.....</b>	<b>36</b>
<b>9.1</b>	<b>Method 1 .....</b>	<b>36</b>
<b>9.2</b>	<b>Method 2 .....</b>	<b>36</b>
<b>9.3</b>	<b>Method 3 .....</b>	<b>36</b>
<b>10</b>	<b>Compliance check.....</b>	<b>36</b>
<b>10.1</b>	<b>General .....</b>	<b>36</b>
<b>10.2</b>	<b>Method 1 .....</b>	<b>36</b>
<b>10.3</b>	<b>Method 2 .....</b>	<b>37</b>
<b>10.4</b>	<b>Method 3 .....</b>	<b>37</b>
<b>Annex A (normative) Input and method selection data sheet — Template .....</b>		<b>38</b>
<b>A.1</b>	<b>General .....</b>	<b>38</b>
<b>A.2</b>	<b>System design data.....</b>	<b>38</b>
<b>A.2.1</b>	<b>General .....</b>	<b>38</b>
<b>A.2.2</b>	<b>Standby energy density .....</b>	<b>39</b>
<b>A.2.3</b>	<b>Annual operating hours .....</b>	<b>39</b>
<b>A.2.4</b>	<b>Daylight supply factor for vertical façades.....</b>	<b>39</b>
<b>A.2.5</b>	<b>Daylight supply factor for roof lights .....</b>	<b>39</b>
<b>A.2.6</b>	<b>Absence factor (<math>F_A</math>) for rooms in building types.....</b>	<b>39</b>
<b>A.2.7</b>	<b>Example constant illuminance dependency factors (<math>F_c</math>) .....</b>	<b>40</b>
<b>A.2.8</b>	<b>Installed power for residential buildings.....</b>	<b>40</b>
<b>A.2.9</b>	<b>Useful areas in residential buildings.....</b>	<b>41</b>
<b>Annex B (informative) Input and method selection data sheet — Default choices .....</b>		<b>42</b>
<b>B.1</b>	<b>General .....</b>	<b>42</b>
<b>B.2</b>	<b>Method 1 .....</b>	<b>42</b>
<b>B.2.1</b>	<b>Luminaire description data .....</b>	<b>42</b>
<b>B.2.2</b>	<b>Luminaire technical data tables.....</b>	<b>42</b>
<b>B.2.3</b>	<b>System design data.....</b>	<b>43</b>
<b>B.3</b>	<b>Method 2 .....</b>	<b>43</b>
<b>B.3.1</b>	<b>Luminaire description data .....</b>	<b>43</b>
<b>B.3.2</b>	<b>Luminaire technical data tables.....</b>	<b>43</b>
<b>B.3.3</b>	<b>System design data.....</b>	<b>43</b>
<b>B.4</b>	<b>Method 3 .....</b>	<b>49</b>
<b>Annex C (normative) Simplified Method for Installed Power Estimation.....</b>		<b>50</b>
<b>C.1</b>	<b>General .....</b>	<b>50</b>
<b>C.2</b>	<b>Installed power assessment for non-residential buildings.....</b>	<b>50</b>
<b>C.3</b>	<b>Installed power assessment for residential buildings.....</b>	<b>52</b>
<b>Annex D (normative) Assessment of the installed power for lighting systems in existing buildings .....</b>		<b>53</b>
<b>Annex E (normative) Occupancy estimation .....</b>		<b>54</b>

<b>Annex F (normative) Daylight availability .....</b>	<b>59</b>
<b>F.1 General.....</b>	<b>59</b>
<b>F.2 Building segmentation: Spaces benefiting from daylight.....</b>	<b>61</b>
<b>F.3 Daylight supply factor for vertical façades.....</b>	<b>63</b>
<b>F.3.1 Daylight factor classification .....</b>	<b>63</b>
<b>F.3.2 Daylight supply factor .....</b>	<b>69</b>
<b>F.4 Daylight supply factor for roof lights.....</b>	<b>81</b>
<b>F.4.1 General.....</b>	<b>81</b>
<b>F.4.2 Daylight availability factor .....</b>	<b>81</b>
<b>F.4.3 Daylight supply factor .....</b>	<b>86</b>
<b>F.4.4 Relative times, shading activated/ not activated for roof lights.....</b>	<b>87</b>
<b>F.4.5 Daylight supply factors as function of the daylight availability classification .....</b>	<b>89</b>
<b>F.5 <math>\text{A}_1</math> Daylight supply factor for windows in sloped roofs <math>\text{A}_1</math>.....</b>	<b>93</b>
<b>F.6 Daylight Responsive Control Systems .....</b>	<b>95</b>
<b>F.7 Monthly evaluation method.....</b>	<b>97</b>
<b>F.8 Determination of daytime and night time hours.....</b>	<b>98</b>
<b>F.9 Comprehensive calculation.....</b>	<b>101</b>
<b>F.10 Collection of input data required for daylight calculations.....</b>	<b>102</b>
<b>Annex G (normative) Constant illuminance .....</b>	<b>103</b>
<b>G.1 General.....</b>	<b>103</b>
<b>G.2 Constant illuminance factor (<math>F_c</math>) .....</b>	<b>103</b>
<b>G.3 Constant lumen output system (CLO) .....</b>	<b>104</b>
<b>Annex H (normative) Standby system energy requirements .....</b>	<b>105</b>
<b>H.1 Emergency lighting luminaire standby charging power (<math>P_{em}</math>) .....</b>	<b>105</b>
<b>H.2 Lighting controls standby power (<math>P_{pc}</math>) .....</b>	<b>105</b>
<b>Bibliography .....</b>	<b>106</b>

## European foreword

This document (EN 15193-1:2017+A1:2021) has been prepared by Technical Committee CEN/TC 169 "Light and lighting", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2021, and conflicting national standards shall be withdrawn at the latest by December 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 4 May 2021.

This document supersedes ~~EN 15193:2017~~.

The start and finish of text introduced or altered by amendment is indicated in the text by tags ~~A1~~ A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

EN 15193 consists of the following parts, under the general title "Energy performance of buildings — Energy requirements for lighting".

*Part 1: Specifications, Module M9*

*Part 2: (Technical Report) Explanation and justification of EN 15193-1, Module M9*

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

This Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this standard a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

The main target groups of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE So in this case:

- the regulators will specify the choices;
- the individual user will apply the standard to assess the energy performance of a building, and thereby use the choices made by the regulators.

Topics addressed in this standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B. Public regulation on the same topics can even, for certain applications, override the use of this standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

- national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case the national annex (e.g. NA) refers to this text;
- or, by default, the national standards body will consider the possibility to add or include a national annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 15193-2 [5]).

CEN/TC 169 deals with light and lighting and the subjects covered by committee are:

- Lighting criteria for indoor and outdoor activities;
- Photometry of lighting systems;

- Lighting terminology;
- Energy efficiency of lighting systems.

This standard specifies three methods for evaluating the energy performance of lighting systems.

It is of paramount importance that correct lighting is provided in buildings. The convention and procedures in this standard assumes that the designed and installed lighting scheme conforms to good lighting practices. For new and refurbished installations in the non-residential building sector the design of the lighting system should conform to the requirements in the lighting applications standards EN 12464-1 for indoor workplaces, EN 12193 for sports buildings and EN 1838 for emergency escape lighting. For residential buildings the lighting system should be designed to fulfil the needs of the rooms in the buildings. Guidance on the requirements is provided in the supporting Technical Report CEN/TR 15193-2 [5].


This standard also assumes that the buildings can have access to daylight to provide all or some of the illumination required in the rooms and that in addition there will be an adequate amount of electric lighting installed to provide the required illumination in the absence of daylight or with a reduced daylight contribution.

This standard defines the methods for estimating or measuring the amount of energy required or used for lighting in buildings. The method of separate metering of the energy used for lighting will also give regular feedback on the effectiveness of the lighting control.

The methodology of energy estimation not only provides values for the Lighting Energy Numeric Indicator (*LENI*) but it will also provide input for the heating and cooling load estimations for the combined total energy performance of building indicator.

Figure 1 gives an overview of the methodology and the flow of the processes involved.

**NOTE** The dotted line in Figure 1 linking preliminary annual *LENI* to the comprehensive lighting design indicates the requirement to follow-up the budget calculation with a comprehensive calculation during the detailed lighting design process.



**Figure 1 — Flow chart illustrating methods to determine energy for lighting**

This standard was developed during the first EPBD mandate and the first edition was published in 2007.

The revision for inclusion in the second mandate package was performed during 2013-2016.

The most important changes are:

- extension of calculation methods,
- inclusion of lighting for residential buildings,
- substantial editorial changes.

## 1 Scope

This standard specifies the methodology for evaluating the energy performance of lighting systems for providing general illumination in residential and non-residential buildings and for calculating or measuring the amount of energy required or used for lighting in buildings. The method may be applied to new, existing or refurbished buildings. It also provides a methodology (*LENI*) as the measure of the energy efficiency of the lighting installations in buildings.

This standard does not cover lighting requirements, the design of lighting systems, the planning of lighting installations, the characteristics of lighting equipment (lamps, control gear and luminaires) and systems used for display lighting, desk lighting or luminaires built into furniture. This standard does not provide any procedure for the dynamic simulation of lighting scene setting.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

**NOTE** In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2.

**Table 1 — Position of this standard within the modular structure of the set of EPB standards**

Submodule	Overarching		Building (as such)		Technical Building Systems									
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic hot water	Lighting	Building automation and control	PV, wind,..
<b>sub1</b>		<b>M1</b>		<b>M2</b>		<b>M3</b>	<b>M4</b>	<b>M5</b>	<b>M6</b>	<b>M7</b>	<b>M8</b>	<b>M9</b>	<b>M10</b>	<b>M11</b>
1	General		General	General										
2	Common terms and definitions; symbols, units and subscripts		Building Energy Needs	Needs								EN 15193-1	a	
3	Applications		(Free) Indoor Conditions without Systems	Maximum Load and Power								EN 15193-1		
4	Ways to Express Energy Performance		Ways to Express Energy Performance	Ways to Express Energy Performance								EN 15193-1		
5	Building categories and Building Boundaries		Heat Transfer by Transmission	Emission and control								EN 15193-1		