

BS EN 60079-1:2014



BSI Standards Publication

Explosive atmospheres

Part 1: Equipment protection by
flameproof enclosures “d”

National foreword

This British Standard is the UK implementation of EN 60079-1:2014. It is identical to IEC 60079-1:2014. It supersedes BS EN 60079-1:2007 which is withdrawn.

BSI, as a member of CENELEC is obliged to publish BS EN 60079-1 as a British Standard. However, attention is drawn to the fact that during the development of this European Standard, the UK voted against its approval as a European Standard. The reason for this disapproval was that the pass criteria for the test relating to cemented joints in subclause 6.1.2 is considered to be not as robust when compared with the previously published edition.

Other National Standard Bodies have also recorded a negative vote on the document citing the identical concern in the difference between the 2007 edition and the 2014 edition. Many manufacturers had no difficulty in complying with the previous requirement when choosing appropriate cements and the UK committee did not see any justification for revising the requirement.

The UK participation in its preparation was entrusted to Technical Committee EXL/31, Equipment for explosive atmospheres.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.
Published by BSI Standards Limited 2014

ISBN 978 0 580 75475 3
ICS 13.230; 29.260.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 October 2014.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60079-1

October 2014

ICS 29.260.20

Supersedes EN 60079-1:2007

English Version

**Explosive atmospheres - Part 1: Equipment protection by
flameproof enclosures "d"
(IEC 60079-1:2014)**

Atmosphères explosives - Partie 1: Protection de l'appareil
par enveloppes antidéflagrantes "d"
(CEI 60079-1:2014)

Explosionsgefährdete Bereiche - Teil 1: Geräteschutz
durch druckfeste Kapselung "d"
(IEC 60079-1:2014)

This European Standard was approved by CENELEC on 2014-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 31/1111/FDIS, future edition 7 of IEC 60079-1, prepared by IEC/TC 31 "Equipment for explosive atmospheres" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60079-1:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-05-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-08-01

This document supersedes EN 60079-1:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For the relationship with EU Directive see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 60079-1:2014 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60061	-	Lamp caps and holders together with gauges for the control of interchangeability and safety	-	-
IEC 60079-0 (mod)	-	Explosive atmospheres - Part 0: Equipment - General requirements	EN 60079-0	-
			+A11	2013
IEC 60079-7	-	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"	EN 60079-7	-
IEC 60079-11	-	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"	EN 60079-11	-
IEC 60079-15	-	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"	EN 60079-15	-
IEC 60127	series	Miniature fuses	EN 60127	series
ISO 965-1	-	ISO general purpose metric screw threads - Tolerances – Part 1: Principles and basic data	-	-
ISO 965-3	-	ISO general purpose metric screw threads - Tolerances – Part 3: Deviations for constructional screw threads	-	-
ISO 2738	-	Sintered metal materials, excluding hardmetals - Permeable sintered metal materials - Determination of density, oil content and open porosity	EN ISO 2738	-
ISO 4003	-	Permeable sintered metal materials - Determination of bubble test pore size	EN 24003	-
ISO 4022	-	Permeable sintered metal materials - Determination of fluid permeability	EN ISO 4022	-
ANSI/ASME B 1.20.1 -			-	-

Annex ZY (informative)

Significant changes between this European Standard and EN 60079-1:2007

This European Standard supersedes EN 60079-1:2007.

The significant changes with respect to EN 60079-1:2007 are as listed below.

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
<i>Normative references</i> (Removal of the edition date from the reference for 60079-0) IEC	2	X		
<i>Requirements for level of protection “da”</i> (Catalytic sensors for combustible gas detectors)	4.2		X	
Requirements for level of protection “dc” (“Enclosed break” devices from IEC 60079-15)	4.4, 15.5	X		
Flameproof joints, General requirements (Documentation clarification and examples of corrosion inhibiting grease)	5.1	X		
Flameproof joints, General requirements (Specific Conditions of Use that joints are not intended to be repaired)	5.1		X	
Flameproof joints, General requirements (Electroplating more than 0.008 mm thick)	5.1		X	
Non-threaded joints, Gap (<i>l</i>) (Intentional gaps between surface for flanged joints)	5.2.2	X		
Serrated joints (Use and test requirements)	5.2.8	X		
Multi-step joints (Not less than 3 adjacent segments and two path changes)	5.2.9		X	
Minimum width of joint and maximum gap for enclosures of groups IIA and IIB (Maximum gaps for flanged, cylindrical or spigot joints of 9,5 mm minimum width and volume greater than 2,000 cm ³)	Table 2		X	
Minimum width of joint and maximum gap for enclosures of groups I, IIA, IIB and IIC (ISO 80000-1 for constructional value rounding)	Table 2, Table 3	X		
Cylindrical threaded joints (ISO 965-1 standard in respect of thread form or quality of fit)	Table 4	X		
Taper threaded joints (External and internal thread construction)	Table 5	X		
Cemented joints (Supplemental mechanical means of securement)	6.1.2			C1
Cemented joints (Evaluation criteria if there is leakage)	6.1.2		X	
Fused glass joints (Glass-to-metal joints)	6.2		X	

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Thermal tests of breathing and draining devices (Temperature class based on external surface temperature after the 10 min test period)	10.9.3.2	X		
Test of the ability of the breathing and draining device to withstand pressure (Relocated from before thermal tests to after the non-transmission test)	10.9.3.4	X		
Ex component certificate (Service temperature range for non-metallic enclosures per IEC 60079-0)	10.9.4	X		
Fasteners and openings (Relocation of blanking element content to Clauses 13.8 and C.2.3)	11	X		
Fasteners and openings, Property class or yield stress (Certificate specific condition of use)	11.3	X		
Fasteners and openings (Openings in the wall of the enclosure)	11.8	X		
Materials (Material limitation in acetylene atmospheres)	12.8			C2
Entries for flameproof enclosures, General (Metric and NPT threaded entries)	13.1	X		
Entries for flameproof enclosures, General (Group I non-threaded joints)	13.1		X	
Entries for flameproof enclosures, Non-threaded holes (Group I application)	13.3		X	
Entries for flameproof enclosures, Cable glands (Group I application)	13.4		X	
Cable glands, Conduit sealing devices (Documentation to facilitate mounting)	13.4,13.5	X		
Plugs and sockets and cable couplers (Load requirement for arc-quenching test)	13.6.4			C3
Bushings (Documentation to facilitate mounting)	13.7	X		
Blanking elements (Relocated from Clause 11)	13.8	X		
Verification and tests (Maximum surface temperature conditions)	Table 6	X		
Type tests (Sequence and number of samples for tests)	15	X		
Determination of explosion pressure, General (Devices that can cause turbulence)	15.2.2.2	X		
Determination of explosion pressure, General (Number of tests for Group IIC)	15.2.2.2	X		
Determination of explosion pressure, General (Pressure pilling for Group IIB)	15.2.2.4	X		
Determination of explosion pressure, General (Equipment marked for a single gas)	15.2.2.5	X		
Overpressure test, General (Low ambient overpressure tests not required)	15.2.3	X		

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Overpressure test – First method (static) (3 times option when routine batch testing)	15.2.3.2		X	
Overpressure test – First method (static) (Adjustment for low ambient due to small size of equipment)	15.2.3.2		X	
Overpressure test – Second method (dynamic) (Number of tests to be made)	15.2.3.3	X		
Test for non-transmission of an internal ignition (Clarification regarding grease)	15.3	X		
Reduction in length of a threaded joint for non-transmission test (ISO 965-1 and 965-3 standards in respect of thread form and quality of fit)	Table 9	X		
Test factors to increase pressure or test gap (Group IIC adjustments for elevated ambients)	Table 10	X		
Test for non-transmission of an internal ignition, Groups I, IIA and IIB (Number of tests to be made)	15.3.2.3	X		
Test for non-transmission of an internal ignition, Group IIC testing by increased gap (Number of tests to be made)	15.3.3.2	X		
Test for non-transmission of an internal ignition, Group IIC (Oxygen enrichment of test gases)	15.3.3.4		X	
Thermal tests of enclosures with breathing and draining devices (Temperature class based on external surface temperature after the 10 min test period)	15.4.3.1	X		
Tests for “dc” devices (“Enclosed break” devices from IEC 60079-15)	15.5		X	
Routine tests, General (Adjustment for low ambient due to small size of equipment)	16.1.2		X	
Routine tests, General (Options when second method is chosen)	16.1.3	X		
Routine tests, General (Welded joint inspection options)	16.3		X	
Routine tests, General (Allowance for batch testing)	16.6		X	
Switchgear for Group I (Clarifying need for compliance with EPL Mb types of protection)	17.2.2, 17.2.3	X		
Non-metallic enclosures and non-metallic parts of enclosures, General (Exception for cemented joints)	19.1	X		
Non-metallic enclosures and non-metallic parts of enclosures, Resistance to tracking and creepage distances (Reference to both IEC 60079-7 and or IEC 60079-15)	19.2		X	
Non-metallic enclosures and non-metallic parts of enclosures, Requirements for type tests (Clarification of test sequence)	19.3	X		

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Instructions (Indication that repair of flamepaths is not intended)	21		X	
Bushings (Documentation regarding numbers of cores)	C.2.1.4	X		
Bushings (Criteria for non-transmission test)	C.2.1.4	X		
Bushings (Evaluation criteria if there is leakage)	C.2.1.4		X	
Flameproof joints, Threaded joints (Requirement options)	C.2.2.1	X		
Flameproof joints, Non-threaded joints (Group I application)	C.2.2.2		X	
Constructional requirements for Ex blanking elements (Relocated from Clause 11)	C.2.3.1	X		
Constructional requirements for Ex blanking elements (Metric and NPT Ex blanking elements)	C.2.3.2, C.2.3.3	X		
Constructional requirements for Ex blanking elements (Group I non-threaded construction)	C.2.3.4		X	
Sealing test, General (Allowance for re-tightening)	C.3.1.1	X		
Cable glands and conduit sealing devices with sealing ring (Mandrel to be corrosion-resistant metal)	C.3.1.2	X		
Type tests for Ex blanking elements, Torque test (Test-block to be steel)	C.3.3.1	X		
Tightening torque values (Addition of < 16 mm thread size)	Table C.1		X	
Tightening torque values (Addition of NPT thread sizes)	Table C.2		X	
Ex component enclosure requirements (Markings content)	D.3.8			C4
Ex component enclosure requirements (Certificate content)	D.3.10		X	
Utilization of an Ex component enclosure certificate to prepare an equipment certificate, Procedure (Devices that can create significant turbulence)	D.4.1		X	
Acceptable primary cells (Addition of Type B cells)	Table E.1		X	
Acceptable primary cells (Removal of Type T cells)	Table E.1			C5
Acceptable secondary cells (Addition of Lithium type cells)	Table E.2		X	
Prevention of excessive temperature and cell damage (Application of IEC 60079-11 requirement)	E.4.1.2	X		
Prevention of inadvertent charging of a battery by other voltage sources in the enclosure (Construction not requiring additional protection)	E.4.3		X	

		Type		
Significant Changes	Clause	Minor and editorial changes	Extension	Major technical changes
Recharging of secondary cells inside flameproof enclosures (<i>Additional battery options</i>)	E.5.1		X	
Introduction of an alternative risk assessment method encompassing equipment protection levels' for Ex equipment (<i>Removal of previous Informative Annex</i>)	Annex G	X		
Additional requirements for Flameproof enclosures with an internal source of release (containment system) (<i>Addition of new Normative Annex</i>)	Annex G		X	
Requirements for machines with flameproof "d" enclosures fed from converters (<i>Addition of new Normative Annex</i>)	Annex H		X	

Explanation of the Types of Significant Changes:

A) Definitions

1. Minor and editorial changes:

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2. Extension:

Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3. Major technical changes:


- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

Note These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major technical changes'

C1 – Supplemental mechanical means of securing the cemented joint shall not be defeated by the opening of doors or covers that are intended to be opened during installation or maintenance. For example, in the images below for a luminaire incorporating a cemented joint between the lens and the enclosure cover, the construction shown in the second image would be in accordance with this requirement, while the construction shown in the first image would not.



C2 – Addition of material limitations of enclosures of equipment and enclosures of Ex components for external mounting, if constructed of copper or copper alloys, when used in explosive gas atmospheres containing acetylene (12.8).

C3 – Addition of power factor requirement for evaluating the ability of a plug and socket to remain flameproof during the arc-quenching period while opening a test circuit (13.6.4).

C4 – Addition of marking requirements for Ex component enclosures, in addition to the requirements for marking of Ex components given in IEC 60079-0 (D.3.8).

C5 – Removal of Type T cells as acceptable primary cells (Table E.1).

Annex ZZ

(informative)

Coverage of Essential Requirements of EC Directives

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers only the following essential requirements out of those given in Annex II of the EC Directive 94/9/EC:

- ER 1.0.1, ER 1.0.2 (partly), ER 1.0.3, ER 1.0.4 (partly), ER 1.0.5, ER 1.0.6
- ER 1.1
- ER 1.2.1 (partly), ER 1.2.2 (partly), ER 1.2.3, ER 1.2.6, ER 1.2.7, ER 1.2.8, ER 1.2.9
- ER 1.3.1, ER 1.3.4
- ER 1.4
- ER 1.5
- ER 1.6.4
- ER 2.0
- ER 2.1
- ER 2.2.1
- ER 2.3

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directive[s] concerned.

WARNING: Other requirements and other EC Directives may be applicable to the products falling within the scope of this standard.

CONTENTS

1	Scope	16
2	Normative references	16
3	Terms and definitions	17
4	Level of protection (equipment protection level, EPL)	19
4.1	General.....	19
4.2	Requirements for level of protection “da”	19
4.3	Requirements for level of protection “db”	20
4.4	Requirements for level of protection “dc”	20
4.4.1	General	20
4.4.2	Construction of “dc” devices	20
4.4.3	Tests for “dc” devices	20
5	Flameproof joints.....	21
5.1	General requirements	21
5.2	Non-threaded joints	22
5.2.1	Width of joints (<i>L</i>)	22
5.2.2	Gap (<i>i</i>).....	22
5.2.3	Spigot joints.....	22
5.2.4	Holes in joint surfaces	23
5.2.5	Conical joints.....	25
5.2.6	Joints with partial cylindrical surfaces (not permitted for Group IIC)	25
5.2.7	Flanged joints for acetylene atmospheres	26
5.2.8	Serrated joints	26
5.2.9	Multi-step joints	27
5.3	Threaded joints	30
5.4	Gaskets (including O-rings).....	30
5.5	Equipment using capillaries	32
6	Sealed joints.....	32
6.1	Cemented joints.....	32
6.1.1	General	32
6.1.2	Mechanical strength.....	32
6.1.3	Width of cemented joints	33
6.2	Fused glass joints.....	33
6.2.1	General	33
6.2.2	Width of fused glass joints	33
7	Operating rods.....	33
8	Supplementary requirements for shafts and bearings.....	34
8.1	Joints of shafts	34
8.1.1	General	34
8.1.2	Cylindrical joints	34
8.1.3	Labyrinth joints	34
8.1.4	Joints with floating glands.....	34
8.2	Bearings	36
8.2.1	Sleeve bearings.....	36
8.2.2	Rolling-element bearings	36

9	Light-transmitting parts	36
10	Breathing and draining devices which form part of a flameproof enclosure	37
10.1	General.....	37
10.2	Openings for breathing or draining	37
10.3	Composition limits.....	37
10.4	Dimensions	37
10.5	Elements with measurable paths.....	37
10.6	Elements with non-measurable paths	37
10.7	Removable devices	38
10.7.1	General	38
10.7.2	Mounting arrangements of the elements	38
10.8	Mechanical strength.....	38
10.9	Breathing devices and draining devices when used as Ex components	38
10.9.1	General	38
10.9.2	Mounting arrangements of the elements and components.....	38
10.9.3	Type tests for breathing and draining devices used as Ex components	38
10.9.4	Ex component certificate	41
11	Fasteners and openings	42
12	Materials	43
13	Entries for flameproof enclosures	44
13.1	General.....	44
13.2	Threaded holes	44
13.3	Non-threaded holes (for Group I only)	44
13.4	Cable glands.....	45
13.5	Conduit sealing devices	45
13.6	Plugs and sockets and cable couplers	46
13.7	Bushings.....	47
13.8	Blanking elements.....	47
14	Verification and tests	47
15	Type tests	48
15.1	General.....	48
15.2	Tests of ability of the enclosure to withstand pressure	49
15.2.1	General	49
15.2.2	Determination of explosion pressure (reference pressure)	49
15.2.3	Overpressure test	52
15.3	Test for non-transmission of an internal ignition	53
15.3.1	General	53
15.3.2	Electrical equipment of Groups I, IIA and IIB.....	55
15.3.3	Electrical equipment of Group IIC	56
15.4	Tests of flameproof enclosures with breathing and draining devices	57
15.4.1	General	57
15.4.2	Tests of ability of the enclosure to withstand pressure	57
15.4.3	Thermal tests.....	58
15.4.4	Test for non-transmission of an internal ignition.....	58
15.5	Tests for “dc” devices	59
15.5.1	General	59
15.5.2	Preparation of “dc” samples.....	59
15.5.3	Test conditions for “dc” devices	59

16	Routine tests	60
16.1	General.....	60
16.2	Enclosures not incorporating a welded construction	61
16.3	Enclosures incorporating a welded construction	61
16.4	Bushings not specific to one flameproof enclosure	61
16.5	Acceptance criteria	61
16.6	Batch testing	61
17	Switchgear for Group I	62
17.1	General.....	62
17.2	Means of isolation.....	62
17.2.1	General	62
17.3	Doors or covers	62
17.3.1	Quick-acting doors or covers	62
17.3.2	Doors or covers fixed by screws	62
17.3.3	Threaded doors or covers	63
18	Lampholders and lamp caps	63
18.1	General.....	63
18.2	Device preventing lamps working loose.....	63
18.3	Holders and caps for lamps with cylindrical caps.....	63
18.4	Holders for lamps with threaded caps	63
19	Non-metallic enclosures and non-metallic parts of enclosures	63
19.1	General.....	63
19.2	Resistance to tracking and creepage distances on internal surfaces of the enclosure walls	64
19.3	Requirements for type tests	64
19.4	Test of erosion by flame.....	64
20	Marking	64
20.1	General.....	64
20.2	Caution and warning markings	65
20.3	Informative markings.....	65
21	Instructions.....	65
	Annex A (normative) Additional requirements for crimped ribbon elements and multiple screen elements of breathing and draining devices	66
	Annex B (normative) Additional requirements for elements, with non-measurable paths of breathing and draining devices	67
B.1	Sintered metal elements	67
B.2	Pressed metal wire elements	67
B.3	Metal foam elements.....	68
	Annex C (normative) Additional requirements for flameproof entry devices	69
C.1	General.....	69
C.2	Constructional requirements	69
C.2.1	Sealing methods.....	69
C.2.2	Flameproof joints.....	70
C.2.3	Constructional requirements for Ex blanking elements	71
C.2.4	Constructional requirements for Ex thread adapters.....	73
C.3	Type tests	73
C.3.1	Sealing test	73
C.3.2	Test of mechanical strength.....	74

C.3.3	Type tests for Ex blanking elements	75
C.3.4	Type tests for Ex thread adapters	76
Annex D (normative)	Empty flameproof enclosures as Ex components.....	78
D.1	General.....	78
D.2	Introductory remarks	78
D.3	Ex component enclosure requirements.....	78
D.4	Utilization of an Ex component enclosure certificate to prepare an equipment certificate	80
D.4.1	Procedure.....	80
D.4.2	Application of the schedule of limitations	80
Annex E (normative)	Cells and batteries used in flameproof “d” enclosures	81
E.1	Introductory remarks	81
E.2	Acceptable electrochemical systems	81
E.3	General requirements for cells (or batteries) inside flameproof enclosures	82
E.4	Arrangement of safety devices	82
E.4.1	Prevention of excessive temperature and cell damage.....	82
E.4.2	Prevention of cell polarity reversal or reverse charging by another cell in the same battery	83
E.4.3	Prevention of inadvertent charging of a battery by other voltage sources in the enclosure	83
E.5	Recharging of secondary cells inside flameproof enclosures	84
E.6	Rating of protection diodes and reliability of protection devices.....	85
Annex F (informative)	Mechanical properties for screws and nuts	86
Annex G (normative)	Additional requirements for flameproof enclosures with an internal source of release (containment system)	87
G.1	General.....	87
G.2	Release conditions.....	87
G.2.1	No release	87
G.2.2	Limited release of a gas or vapour	88
G.2.3	Limited release of a liquid	88
G.3	Design requirements for the containment system	88
G.3.1	General design requirements	88
G.3.2	Infallible containment system.....	88
G.3.3	Containment system with a limited release	89
G.4	Type tests for the containment system	89
G.4.1	Overpressure test	89
G.4.2	Leakage test for an infallible containment system	89
G.4.3	Leakage test for a containment system with a limited release	90
Annex H (normative)	Requirements for machines with flameproof “d” enclosures fed from converters.....	91
H.1	General.....	91
H.2	Construction requirements for bearings.....	91
H.3	Temperature requirements	91
Bibliography	92
Figure 1 – Example of construction for indirect checking of a flanged Group I flameproof joint.....		22
Figure 2 – Spigot joints		23
Figure 3 – Holes in surfaces of flanged joints, example 1		24

Figure 4 – Holes in surfaces of flanged joints, example 2	24
Figure 5 – Holes in surfaces of flanged joints, example 3	24
Figure 6 – Holes in surfaces of spigot joints, example 1	24
Figure 7 – Holes in surfaces of spigot joints, example 2	25
Figure 8 – Holes in surfaces of spigot joints, example 3	25
Figure 9 – Examples of joint constructions	26
Figure 10 – Illustration of the requirements concerning gaskets – Example 1	31
Figure 11 – Illustration of the requirements concerning gaskets – Example 2	31
Figure 12 – Illustration of the requirements concerning gaskets – Example 3	31
Figure 13 – Illustration of the requirements concerning gaskets – Example 4	31
Figure 14 – Illustration of the requirements concerning gaskets – Example 5	31
Figure 15 – Illustration of the requirements concerning gaskets – Example 6	31
Figure 16 – Illustration of the requirements concerning gaskets – Example 7	32
Figure 17 – Example of cylindrical joint for shaft of rotating electrical machine	35
Figure 18 – Example of labyrinth joint for shaft of rotating electrical machine	35
Figure 19 – Example of joint with floating gland for shaft of rotating electrical machine	35
Figure 20 – Joints of shaft glands of rotating electrical machines	36
Figure 21 – Component test rig for breathing and draining devices	39
Figure 22 – Example of possible documentation	45
Figure 23 – Example of a regular shaped waveform	51
Figure 24 – Example of an irregular shaped waveform	51
Figure C.1 – Examples of blanking elements for unused entries	72
Figure C.2 – Device for the sealing tests for cable glands	74
Figure C.3 – Examples of Ex thread adapters	77
Figure E.1 – Fitting of diode arrangement for three cells in series	83
Figure E.2 – Fitting of blocking diodes to meet E.4.3 (third example)	84
Figure G.1 – Flameproof enclosure with containment system	87
Table 1 – Number of non-transmission tests for level of protection “da”	20
Table 2 – Minimum width of joint and maximum gap for enclosures of Groups I, IIA and IIB	28
Table 3 – Minimum width of joint and maximum gap for Group IIC enclosures	29
Table 4 – Cylindrical threaded joints	30
Table 5 – Taper threaded joints ^{a, c}	30
Table 6 – Conditions for the determination of maximum surface temperature	48
Table 7 – Test factors for reduced ambient conditions	50
Table 8 – Relative pressures for small equipment	52
Table 9 – Reduction in length of a threaded joint for non-transmission test	54
Table 10 – Test factors to increase pressure or test gap (i_E)	54
Table 11 – Minimum distance of obstructions from flameproof “d” flange openings	54
Table 12 – Gas/air mixtures	55
Table 13 – Static pressures	60
Table 14 – Text of caution or warning markings	65

Table 15 – Text of informative markings.....	65
Table C.1 – Tightening torque values, metric	76
Table C.2 – Tightening torque values, NPT.....	77
Table E.1 – Acceptable primary cells	81
Table E.2 – Acceptable secondary cells.....	82
Table F.1 – Mechanical properties for screws and nuts	86

EXPLOSIVE ATMOSPHERES –

Part 1: Equipment protection by flameproof enclosures “d”

1 Scope

This part of IEC 60079 contains specific requirements for the construction and testing of electrical equipment with the type of protection flameproof enclosure “d”, intended for use in explosive gas atmospheres.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard will take precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60061 (all parts), *Lamp caps and holders together with gauges for the control of interchangeability and safety*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety “e”*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection “n”*

IEC 60127 (all parts), *Miniature fuses*

ISO 965-1, *ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*

ISO 965-3, *ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads*

ISO 2738, *Sintered metal materials, excluding hardmetals – Permeable sintered metal materials – Determination of density, oil content and open porosity*

ISO 4003, *Permeable sintered metal materials – Determination of bubble test pore size*

ISO 4022, *Permeable sintered metal materials – Determination of fluid permeability*

ANSI/ASME B1.20.1, *Pipe threads, general purpose (inch)*