

BS EN 50270:2015
Incorporating corrigendum August 2016



BSI Standards Publication

Electromagnetic compatibility — Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen

National foreword

This British Standard is the UK implementation of EN 50270:2015, incorporating corrigendum August 2016. It supersedes BS EN 50270:2006 which is withdrawn.

The start and finish of text introduced or altered by corrigendum is indicated in the text by tags. Text altered by CENELEC corrigendum August 2016 is indicated in the text by AC1 AC1.

The UK participation in its preparation was entrusted by Technical Committee EXL/31, Equipment for explosive atmospheres, to Subcommittee EXL/31/1, Gas detectors.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016. Published by BSI Standards Limited 2016

ISBN 978 0 580 95421 4

ICS 13.320; 19.080; 33.100.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 28 February 2015.

Amendments/corrigenda issued since publication

Date	Text affected
31 October 2016	Implementation of CENELEC corrigendum August 2016

EUROPEAN STANDARD

EN 50270

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2015

ICS 13.320

Incorporating corrigendum August 2016
Supersedes EN 50270:2006

English Version

Electromagnetic compatibility - Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen

Compatibilité électromagnétique - Appareils de détection et
de mesure de gaz combustible, de gaz toxique et
d'oxygène

Elektromagnetische Verträglichkeit - Elektrische Geräte für
die Detektion und Messung von brennbaren Gasen,
toxischen Gasen oder Sauerstoff

This European Standard was approved by CENELEC on 2014-10-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

1	Scope.....	4
2	Normative references	5
3	Terms and Definitions.....	6
4	EMC test plan	8
4.1	General.....	8
4.2	Configuration of the apparatus (EUT) during testing	8
4.2.1	General	8
4.2.2	Composition of EUT.....	8
4.2.3	Configuration of EUT, operation modes	8
4.2.4	I/O ports	9
4.2.5	Auxiliary equipment.....	9
4.2.6	Cabling and earthing (grounding)	9
4.3	Operation conditions of EUT during testing	9
4.3.1	Test gases, alarm settings.....	9
4.3.2	Environmental conditions.....	10
4.3.3	EUT software during test	10
4.4	Test description	10
5	Immunity tests.....	10
5.1	Performance criteria	10
5.2	Requirements	11
6	Emission tests.....	11
7	Test report	12
8	Modifications.....	12

Foreword

This document (EN 50270:2015) has been prepared by CLC/SC 31-9 "Electrical apparatus for the detection and measurement of combustible gases to be used in industrial and commercial potentially explosive atmospheres" of CLC/TC 31, "Electrical apparatus for explosive atmospheres" and by CLC/TC 216 "Gas detectors".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-10-20
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2017-10-20

This document supersedes EN 50270:2006.

EN 50270:2015 includes the following significant technical changes with respect to EN 50270:2006:

- requirements updated according to EN 61326–1:2013;
- aspects related to functional safety considered;
- several requirements of EN 61326–3–2 implemented;
- the hierarchical level between criteria B and C re-inserted by modifying the requirements for B;
- Tables 1 to 4 updated according to above mentioned points;
- Table 5 modified according to new and updated performance standards;
- Table 5 now includes also the requirements for criterion B.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

1 Scope

This European Standard specifies requirements for the electromagnetic compatibility (EMC) for electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen which are subject to the performance standards for gas detection apparatus, for example EN 45544 (all parts), EN 50104, EN 50194 (all parts), EN 50291 (all parts), EN 50379 (all parts), EN 50543, EN 50545-1, EN 60079-29-1 or EN 60079-29-4.

NOTE For the purpose of this standard the word 'toxic' covers 'very toxic', 'toxic', 'harmful', 'corrosive', 'irritating', 'sensitising', 'carcinogenic', 'mutagenic' and 'teratogenic'.

This European Standard applies to apparatus intended for use in residential, commercial and light-industrial environments as well as to apparatus intended for use in industrial environments. The apparatus may be AC-, DC- or battery powered.

This European Standard is also applicable to apparatus which is intended for use in hazardous areas which may contain explosive or potentially explosive atmospheres. It covers only normal operation and does not cover safety requirements related to EMC phenomena.

This standard is a product standard which is based on the product family standard EN 61326-1. This product standard takes precedence over the product family standard and over generic standards.

This standard applies to electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen that include functions specified by the manufacturer as being safety functions and can include functions specified as not being safety functions.

All performance standards for the detection and measurement of combustible gases, toxic gases or oxygen include the minimum requirements for functional safety specified in EN 50271. There are also gas detectors and gas detection systems which are intended to be used with safety integrity levels SIL 1 to SIL 3 according to EN 50402 and EN 61508 (all parts). For functional safety in industrial applications, this standard has taken into account those aspects of EN 61326-3-2 relating to the measuring and warning function of the apparatus defined as safety function.

This standard specifies requirements for immunity tests in relation to continuous and transient, conducted and radiated disturbances, including electrostatic discharges, and also for emission tests. The test requirements are specified for each port considered.

Apparatus falling within the scope of this European Standard is classified as follows by the following types.

- Type 1: apparatus intended for use in residential, commercial and light-industrial environments, as described in EN 61000-6-1 and EN 61000-6-3.
- Type 2: apparatus intended for use in industrial environments, as described in EN 61000-6-2 and EN 61000-6-4.

Apparatus of type 1 where the manufacturer claims a safety integrity level should be considered as type 2 apparatus with regard to immunity requirements.

This European Standard does not apply to any of the following:

- apparatus intended for the detection of dusts or mists in air;
- scientific or laboratory based apparatus used only for analysis or measurement;
- apparatus used exclusively for process measurement purposes;
- apparatus for medical purposes;
- apparatus used for breath alcohol measurement
- apparatus intended for the direct measurement of automotive exhaust gases.