

INTERNATIONAL STANDARD



**Submarine power cables with extruded insulation and their accessories for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 60 kV ($U_m = 72,5$ kV) –
Test methods and requirements**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

INTERNATIONAL STANDARD



**Submarine power cables with extruded insulation and their accessories for
rated voltages from 6 kV ($U_m = 7,2$ kV) up to 60 kV ($U_m = 72,5$ kV) –
Test methods and requirements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-7642-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references	10
3 Terms and definitions	11
3.1 Definitions of dimensional values (thicknesses, cross-sections, etc.)	12
3.2 Definitions concerning tests	12
3.3 Other definitions	12
3.4 Definitions concerning test objects.....	13
4 Voltage designations, materials and rounding of numbers	14
4.1 Rated voltages.....	14
4.2 Cable insulating compounds	15
4.3 Rounding of numbers.....	15
5 Cable construction.....	16
5.1 General.....	16
5.2 Conductors	16
5.3 Insulation	16
5.4 Screening	16
5.5 Metal screen	17
5.6 Core oversheathing materials	17
5.7 Assembly of three-core cables and fillers	17
5.8 Cable armour	17
5.9 Cable outer serving.....	18
5.10 Packaging.....	18
6 Cable characteristics	18
7 Accessory characteristics	19
8 Test conditions	19
8.1 Ambient temperature.....	19
8.2 Frequency and waveform for AC voltage tests	19
8.3 Lightning impulse test.....	19
8.4 Relationship of test voltages to rated voltages	19
8.5 Determination of the cable conductor temperature	20
9 Routine tests on cables and accessories	20
9.1 General.....	20
9.2 Test on manufacturing lengths	20
9.2.1 Partial discharge test.....	20
9.2.2 AC voltage test.....	20
9.3 Test on factory joints.....	21
9.4 Test on delivery lengths	21
9.4.1 General	21
9.4.2 AC voltage test.....	21
9.4.3 Partial discharge test.....	21
9.5 Test on accessories	21
10 Sample tests on cables.....	21
10.1 General.....	21
10.2 Frequency of tests	22

10.3	Repetition of tests	22
10.4	Conductor examination	22
10.5	Measurement of electrical resistance of conductor and of metal screen	22
10.6	Measurement of thickness of insulation	23
10.6.1	General	23
10.6.2	Requirements for the insulation	23
10.7	Measurement of thickness of oversheath	23
10.7.1	General	23
10.7.2	Requirements for the oversheath	23
10.8	Measurement of thickness of metal sheath	23
10.8.1	General	23
10.8.2	General	24
10.8.3	Strip method	24
10.8.4	Ring method	24
10.9	Measurement of diameters	24
10.10	Hot set test for XLPE, EPR and HEPR insulations	24
10.10.1	Procedure	24
10.10.2	Requirements	24
10.11	Measurement of capacitance	25
10.12	Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath	25
10.13	Examination of completed cable	25
11	Sample tests on accessories	25
11.1	Factory joints	25
11.1.1	General	25
11.1.2	PD measurement and AC voltage test	25
11.1.3	Lightning impulse voltage test	25
11.1.4	Hot set test for insulation	25
11.1.5	Tensile test	26
11.1.6	Joint inspection	26
11.1.7	Pass criteria	26
11.2	Sample tests on repair (field) joints and terminations	26
11.2.1	Tests on components	26
11.2.2	Tests on complete accessory	26
12	Type tests on cable systems	27
12.1	General	27
12.2	Range of type approval	27
12.3	Summary of type tests	29
12.4	Mechanical tests	29
12.4.1	Coiling test	29
12.4.2	Tensile bending test	32
12.4.3	Tensile test	34
12.5	Electrical type tests	35
12.5.1	Test voltage values	35
12.5.2	Electrical type tests and sequence of tests	35
12.5.3	Partial discharge tests	36
12.5.4	Tan δ measurement	36
12.5.5	Heating cycle voltage test	36

12.5.6	Lightning impulse voltage test followed by a power frequency voltage test	37
12.5.7	Examination.....	37
12.5.8	Resistivity of semi-conducting screens	38
12.6	Longitudinal/radial water penetration (LWP, RWP) test	38
12.6.1	General	38
12.6.2	Conductor water penetration test	39
12.6.3	Metal screen water penetration test	40
12.6.4	Radial water penetration test for joints.....	41
12.7	Non-electrical type tests on cable components and on complete cable.....	42
12.7.1	General	42
12.7.2	Check of cable construction.....	42
12.7.3	Tests for determining the mechanical properties of insulation before and after ageing	43
12.7.4	Tests for determining the mechanical properties of oversheaths before and after ageing	43
12.7.5	Ageing tests on pieces of complete cable to check compatibility of materials	43
12.7.6	Pressure test at high temperature for ST7 oversheaths.....	44
12.7.7	Ozone resistance test for EPR and HEPR insulation.....	44
12.7.8	Hot set test for EPR, HEPR and XLPE insulations	44
12.7.9	Measurement of carbon black content of black PE oversheaths	44
12.7.10	Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath	45
12.7.11	Water absorption test on insulation	45
12.7.12	Shrinkage test for XLPE insulation.....	45
12.7.13	Determination of hardness of HEPR insulation.....	45
12.7.14	Determination of the elastic modulus of HEPR insulation	45
12.7.15	Shrinkage test for PE oversheath	46
13	Electrical tests after installation	46
13.1	General.....	46
13.2	DC voltage test of the oversheath	46
13.3	AC voltage test of the insulation.....	46
13.4	DC voltage test of the insulation	46
13.5	Time domain reflectometry (TDR)	46
Annex A	(normative) Methods of heating the test cable and determination of the cable conductor temperature.....	52
A.1	Purpose	52
A.2	Methods of heating armoured cables for the electrical test.....	52
A.2.1	Single-core cables	52
A.2.2	Three-core cables.....	53
A.3	Measurement of the temperature of the test cable.....	54
A.3.1	General	54
A.3.2	Installation of cable and temperature sensors	54
A.4	Heating for the test	57
Annex B	(normative) Rounding of numbers	58
Annex C	(normative) Method of measuring resistivity of semi-conducting screens	59
Annex D	(normative) Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath	62
D.1	Visual inspection.....	62

D.2	Adhesion and peel strength of metal foil	62
D.2.1	General	62
D.2.2	Adhesion strength test	62
D.2.3	Peel strength test of overlapped metal foil	63
D.2.4	Requirements for adhesion and peel strength	65
Annex E (normative)	Determination of hardness of HEPR insulations	66
E.1	Test piece	66
E.2	Test procedure	66
E.2.1	General	66
E.2.2	Surfaces of large radius of curvature	66
E.2.3	Surfaces of small radius of curvature	66
E.2.4	Conditioning and test temperature	66
E.2.5	Number of measurements	67
Annex F (informative)	Tests on factory joints	68
Annex G (normative)	Tensile bending and tensile tests load calculation	69
Annex H (informative)	DC voltage test of the insulation	70
Bibliography	71
Figure 1	– Example of accessory length extension in the case of factory joint	27
Figure 2	– Example of coiling test arrangement	30
Figure 3	– Test cable length for coiling test	31
Figure 4	– Illustration of an example of an anchoring head where relative load sharing between conductor and armour can be controlled	33
Figure 5	– Example of set-up for tensile bending test with a flexible or factory joint	34
Figure 6	– Set-up for the conductor water penetration test	40
Figure 7	– Set-up for the metal screen water penetration test	41
Figure 8	– Circuit diagram for TDR testing (traditional transmission line diagram, π -model)	47
Figure A.1	– Arrangement for heating of single-core armoured cables	52
Figure A.2	– Arrangement 1 for heating of three-core armoured cables	53
Figure A.3	– Arrangement 2 for heating of three-core armoured cables	54
Figure A.4	– Installation of the temperature sensors in the conductor(s) of the reference cable	55
Figure A.5	– Reference cable for heating of single-core armoured cables	56
Figure A.6	– Reference cable for heating of three-core armoured cables	57
Figure C.1	– Preparation of samples for measurement of resistivity of conductor and insulation screens	61
Figure D.1	– Adhesion of metal foil	63
Figure D.2	– Example of overlapped metal foil	63
Figure D.3	– Peel strength of overlapped metal foil	64
Figure D.4	– Example 1 of strength versus grip spacing curve	64
Figure D.5	– Example 2 of strength versus grip spacing curve	65
Figure E.1	– Test on surfaces of large radius of curvature	67
Figure E.2	– Test on surfaces of small radius of curvature	67

Table 1 – Recommended rated voltages U_0	15
Table 2 – Insulating materials	15
Table 3 – Tan δ requirements for insulating compounds for cables	47
Table 4 – Test voltages.....	47
Table 5 – Non-electrical type tests for insulating and oversheath compounds for cables	48
Table 6 – Test requirements for mechanical characteristics of insulating compounds for cables (before and after ageing)	49
Table 7 – Test requirements for mechanical characteristics of oversheathing compounds for cables (before and after ageing)	50
Table 8 – Test requirements for particular characteristics of insulating compounds for cables.....	51
Table D.1 – Minimum acceptable adhesion or peel strength forces	65

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SUBMARINE POWER CABLES WITH EXTRUDED INSULATION
AND THEIR ACCESSORIES FOR RATED VOLTAGES
FROM 6 kV ($U_m = 7,2$ kV) UP TO 60 kV ($U_m = 72,5$ kV) –
TEST METHODS AND REQUIREMENTS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 63026 has been prepared by IEC technical committee 20: Electric cables.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
20/1888/FDIS	20/1895/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

As a result of the growing demand for inter-array cables for offshore windfarms, IEC TC 20 decided to develop an International Standard for medium voltage submarine cable systems.

The worldwide mandate to reduce carbon emissions has stimulated major developments of power production systems where the principal contribution comes from offshore wind farms.

Due to the location of these wind power generation systems, large amounts of submarine cables are required to inter-connect individual power generating units (inter-array cable) and to connect to the mainland (power export cable).

Many offshore wind farms have been built or are today under construction and there are plans for even more farms to be built in future. Although the focus is on wind farms, the need for cable connections to other types of offshore generation will increase. At this stage most of the information and expertise already available on cables for the connection to the mainland grid can be found in CIGRE documents.

Requirements of this document are mainly based on IEC 60502-2, IEC 60840 and CIGRE TB 490, *Recommendations for testing of long AC submarine cables with extruded insulation for system voltage above 30 (36) kV to 500 (550) kV*. References to the relevant applicable mechanical tests are taken from CIGRE TB 623, *Recommendations for mechanical testing of submarine cables*.

A list of relevant additional references is given in the bibliography.

SUBMARINE POWER CABLES WITH EXTRUDED INSULATION AND THEIR ACCESSORIES FOR RATED VOLTAGES FROM 6 kV ($U_m = 7,2$ kV) UP TO 60 kV ($U_m = 72,5$ kV) – TEST METHODS AND REQUIREMENTS

1 Scope

This document specifies test methods and requirements for power cable systems, cables with extruded insulation and their accessories for fixed submarine installations, for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 60 kV ($U_m = 72,5$ kV).

This document includes the electrical tests and the physical tests on materials and components as well as the specific mechanical tests that are applicable to submarine cable systems.

The requirements apply to armoured single-core cables and three-core cables in combination with their accessories, terminations and joints for usual conditions of installation and operation, but not to special cables and their accessories, such as submarine cables for dynamic applications (i.e. for direct connection to a floating structure), for which modifications to the standard tests can be necessary or special test conditions be devised.

This document is applicable to submarine cables installed in permanently submerged conditions with water depths up to 250 m.

NOTE This document does not include accessories having a mechanical function only, such as hang-offs or armour clamps.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60229:2007, *Electric cables – Tests on extruded oversheaths with a special protective function*

IEC 60230, *Impulse tests on cables and their accessories*

IEC 60287-1-1:2006, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*

IEC 60502-2:2014, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 2: Cables for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)*

IEC 60502-4, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)*