



BSI Standards Publication

Specification for radio disturbance and immunity measuring apparatus and methods

Part 2-3: Methods of measurement of disturbances and immunity — Radiated disturbance measurements

National foreword

This British Standard is the UK implementation of EN 55016-2-3:2017+A2:2023. It is identical to CISPR 16-2-3:2016, incorporating amendment 1:2019 and amendment 2:2023. It supersedes BS EN 55016-2-3:2017+A1:2019, which will be withdrawn on 19 July 2026.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to CISPR text carry the number of the CISPR amendment. For example, text altered by CISPR amendment A1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee GEL/210, EMC - Policy committee.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 00232 4

ICS 33.100.10; 33.100.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2018.

Amendments/corrigenda issued since publication

Date	Text affected
31 October 2019	Implementation of CISPR amendment 1:2019 with CENELEC endorsement A1:2019
31 August 2023	Implementation of CISPR amendment 2:2023 with CENELEC endorsement A2:2023

EUROPEAN STANDARD

EN 55016-2-3:2017+A2

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2023

ICS 33.100.10; 33.100.20

English Version

Specification for radio disturbance and immunity measuring
apparatus and methods - Part 2-3: Methods of measurement of
disturbances and immunity - Radiated disturbance
measurements
(CISPR 16-2-3:2016)

Spécifications des méthodes et des appareils de mesure
des perturbations radioélectriques et de l'immunité aux
perturbations radioélectriques - Partie 2-3: Méthodes de
mesure des perturbations et de l'immunité - Mesures des
perturbations rayonnées
(CISPR 16-2-3:2016)

Anforderungen an Geräte und Einrichtungen sowie
Festlegung der Verfahren zur Messung der hochfrequenten
Störaussendung (Funkstörungen) und Störfestigkeit - Teil 2-
3: Verfahren zur Messung der hochfrequenten
Störaussendung (Funkstörungen) und Störfestigkeit -
Messung der gestrahlten Störaussendung
(CISPR 16-2-3:2016)

This European Standard was approved by CENELEC on 2016-10-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 55016-2-3:2017+A2:2023

European foreword

The text of document CISPR/A/1176A/FDIS, future edition 4 of CISPR 16-2-3, prepared by CISPR SC A "Radio-Interference measurements and statistical methods" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 55016-2-3:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2017-10-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-04-28

This document supersedes EN 55016-2-3:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard CISPR 16-2-3:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

CISPR 11:2015	NOTE	Harmonized as EN 55011:2016.
CISPR 16-1-6:2014	NOTE	Harmonized as EN 55016-1-6:2015.
CISPR 22:2008	NOTE	Harmonized as EN 55022:2010.
IEC 61140:2016	NOTE	Harmonized as EN 61140:2016.
ISO/IEC Guide 2:2004	NOTE	Harmonized as EN 45020:2006.
ISO/IEC 17000:2004	NOTE	Harmonized as EN ISO/IEC 17000:2004.
IEC 61000-4-21	NOTE	Harmonized as EN 61000-4-21.

Foreword to amendment A1

The text of document CIS/A/1278/FDIS, future CISPR 16-2-3/A1, prepared by CISPR SC A "Radio-interference measurements and statistical methods" of CISPR "International special committee on radio interference" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 55016-2-3:2017/A1:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-04-25
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-07-25

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard CISPR 16-2-3:2016/A1:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

CISPR 11:2015	NOTE	Harmonized as EN 55011:2016
CISPR 32:2015	NOTE	Harmonized as EN 55032:2015 (not modified)

European foreword to amendment A2

The text of document CIS/A/1391/FDIS, future CISPR 16-2-3/AMD2, prepared by CISPR SC A "Radio-interference measurements and statistical methods" of CISPR "International special committee on radio interference" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 55016-2-3:2017/A2:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2024-04-19 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2026-07-19 document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard CISPR 16-2-3:2016/AMD2:2023 was approved by CENELEC as a European Standard without any modification.



Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-161	-	International Electrotechnical Vocabulary (IEV) - Chapter 161: Electromagnetic compatibility	-	-
IEC 61000-4-3	2006	Electromagnetic compatibility (EMC) Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	2006
+ A1	2007		+ A1	2008
+ A2	2010		+ A2	2010
IEC 61000-4-20	-	Electromagnetic compatibility (EMC) - Part 4-20: Testing and measurement techniques - Emission and immunity testing in transverse electromagnetic (TEM) waveguides	EN 61000-4-20	
CISPR 14-1	2016	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission	FprEN 55014-1	2016
CISPR 16-1-1	-	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-1: Radio disturbance and immunity measuring apparatus - Measuring apparatus	-	-
CISPR 16-1-2	2014	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-2: Radio disturbance and immunity measuring apparatus - Coupling devices for conducted disturbance measurements	EN 55016-1-2	2014
 CISPR 16-1-4	2019	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-4: Radio disturbance and immunity measuring apparatus - Antennas and test sites for radiated disturbance measurements	EN IEC 55016-1-4	2019
+ A1	2020		+ A1	2020
+ A2	2023		+ A2	2023 

EN 55016-2-3:2017+A2:2023

CISPR 16-2-1	2014	Specification for radio disturbance and immunity measuring apparatus and methods - Part 2-1: Methods of measurement of disturbances and immunity - Conducted disturbance measurements	EN 55016-2-1	2014
CISPR 16-4-2	2011	Specification for radio disturbance and immunity measuring apparatus and methods - Part 4-2: Uncertainties, statistics and limit modelling - Measurement instrumentation uncertainty	EN 55016-4-2	2011
+ A1	2014		+ A1	2014
+ A2	2018		+ A2	2018
CISPR TR 16-4-1	-	Specification for radio disturbance and immunity measuring apparatus and methods - Part 4-1: Uncertainties, statistics and limit modelling - Uncertainties in standardized EMC tests	-	-
CISPR TR 16-4-5	-	Specification for radio disturbance and immunity measuring apparatus and methods - Part 4-5: Uncertainties, statistics and limit modelling - Conditions for the use of alternative test methods	-	-

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references	11
3 Terms, definitions and abbreviations	12
3.1 Terms and definitions.....	12
3.2 Abbreviated terms.....	18
4 Types of disturbance to be measured	19
4.1 General.....	19
4.2 Types of disturbance.....	19
4.3 Detector functions.....	20
5 Connection of measuring equipment.....	20
6 General measurement requirements and conditions	20
6.1 General.....	20
6.2 Disturbance not produced by the equipment under test.....	20
6.2.1 General	20
6.2.2 Compliance (conformity assessment) testing	21
6.3 Measurement of continuous disturbance	21
6.3.1 Narrowband continuous disturbance	21
6.3.2 Broadband continuous disturbance	21
6.3.3 Use of spectrum analyzers and scanning receivers.....	21
6.4 EUT arrangement and measurement conditions	21
6.4.1 General arrangement of the EUT	21
6.4.2 Operation of the EUT	24
6.4.3 EUT time of operation	24
6.4.4 EUT running-in time	24
6.4.5 EUT supply	24
6.4.6 EUT mode of operation	24
6.4.7 Operation of multifunction equipment.....	24
6.4.8 Determination of arrangement(s) causing maximum emissions	25
6.4.9 Recording of measurements	25
6.5 Interpretation of measuring results.....	25
6.5.1 Continuous disturbance	25
6.5.2 Discontinuous disturbance	25
6.5.3 Measurement of the duration of disturbance	26
6.6 Measurement times and scan rates for continuous disturbance.....	26
6.6.1 General	26
6.6.2 Minimum measurement times.....	26
6.6.3 Scan rates for scanning receivers and spectrum analyzers	27
6.6.4 Scan times for stepping receivers	28
6.6.5 Strategies for obtaining a spectrum overview using the peak detector.....	28
6.6.6 Timing considerations using FFT-based instruments.....	32
7 Measurement of radiated disturbances	35
7.1 General.....	35
7.1.1 General remarks and overview of test methods	35

7.1.2	Overview of maximum EUT volumes depending on measurement method, frequency range, and measurement distance	37
7.2	Loop-antenna system measurements (9 kHz to 30 MHz)	38
7.2.1	General	38
7.2.2	General measurement method	39
7.2.3	Test environment	40
7.2.4	Configuration of the equipment under test.....	40
7.2.5	Measurement uncertainty for LLAS	41
7.3	Open-area test site or semi-anechoic chamber measurements (30 MHz to 1 GHz).....	41
7.3.1	Measurand.....	41
7.3.2	Test site requirements	44
7.3.3	General measurement method	44
7.3.4	Measurement distance	45
7.3.5	Antenna height variation	46
7.3.6	Product specification details	46
7.3.7	Measurement instrumentation	48
7.3.8	Field-strength measurements on other outdoor sites.....	48
7.3.9	Measurement uncertainty for OATS and SAC.....	48
7.4	Fully-anechoic room measurements (30 MHz to 1 GHz).....	48
7.4.1	Test set-up and site geometry.....	48
7.4.2	EUT position	51
7.4.3	Cable layout and termination	52
7.4.4	Measurement uncertainty for FAR.....	53
7.5	Radiated emission measurement method (30 MHz to 1 GHz) and radiated immunity test method (80 MHz to 1 GHz) with common test set-up in semi-anechoic chamber.....	53
7.5.1	Applicability	53
7.5.2	EUT perimeter definition and antenna-to-EUT separation distance.....	53
7.5.3	Uniform test volume	54
7.5.4	Specifications for EUT set-up in common emissions/immunity test set-up.....	55
7.5.5	Measurement uncertainty for common emission/immunity set-up and method	61
7.6	Fully-anechoic room and absorber-lined OATS/SAC measurements (1 GHz to 18 GHz)	61
7.6.1	Measurand.....	61
7.6.2	Measurement distance	62
7.6.3	Set-up and operating conditions of the equipment under test (EUT).....	62
7.6.4	Measurement site	63
7.6.5	Measurement instrumentation	63
7.6.6	Measurement procedure	63
7.6.7	Measurement uncertainty for FAR.....	69
7.7	<i>In situ</i> measurements (9 kHz to 18 GHz).....	69
7.7.1	Applicability of and preparation for <i>in situ</i> measurements.....	69
7.7.2	Field-strength measurements <i>in situ</i> in the frequency range 9 kHz to 30 MHz.....	70
7.7.3	Field-strength measurements <i>in situ</i> in the frequency range above 30 MHz.....	71
7.7.4	<i>In situ</i> measurement of the disturbance effective radiated power using the substitution method.....	72

7.7.5	Documentation of the measurement results	76
7.7.6	Measurement uncertainty for <i>in situ</i> method	76
7.8	Substitution measurements (30 MHz to 18 GHz)	76
7.8.1	General	76
7.8.2	Test site	76
7.8.3	Test antennas	77
7.8.4	EUT configuration	77
7.8.5	Test procedure	77
7.8.6	Measurement uncertainty for substitution method	78
7.9	Reverberation chamber measurements (80 MHz to 18 GHz)	78
7.10	TEM waveguide measurements (30 MHz to 18 GHz)	78
8	Automated measurement of emissions	78
8.1	Introduction – Precautions for automated measurements	78
8.2	Generic measurement procedure	79
8.3	Pre-scan measurements	79
8.3.1	General	79
8.3.2	Determination of the required measurement time	79
8.3.3	Pre-scan requirements for different types of measurements	80
8.4	Data reduction	81
8.5	Emission maximization and final measurement	82
8.6	Post-processing and reporting	83
8.7	Emission measurement strategies with FFT-based measuring instruments	83
Annex A (informative)	Measurement of disturbances in the presence of ambient emissions	84
A.1	General	84
A.2	Terms and definitions	84
A.3	Problem description	84
A.4	Proposed solution	84
A.4.1	Overview	84
A.4.2	Pre-testing the EUT in a shielded room	87
A.4.3	Method of measurement of EUT disturbances in the presence of narrowband ambient emissions	88
A.4.4	Method of measurement of EUT disturbance in the presence of broadband ambient emissions	91
A.5	Determination of the EUT disturbance in case of superposition	93
Annex B (informative)	Use of spectrum analyzers and scanning receivers	98
B.1	General	98
B.2	Overload	98
B.3	Linearity test	98
B.4	Selectivity	98
B.5	Normal response to pulses	98
B.6	Peak detection	98
B.7	Frequency scan rate	99
B.8	Signal interception	99
B.9	Average detection	99
B.10	Sensitivity	99
B.11	Amplitude accuracy	100
Annex C (informative)	Scan rates and measurement times for use with the average detector	101

C.1	Purpose	101
C.2	Suppression of disturbances	101
C.2.1	Suppression of impulsive disturbance	101
C.2.2	Suppression of impulsive disturbance by digital averaging	102
C.2.3	Suppression of amplitude modulation.....	102
C.3	Measurement of slowly intermittent, unsteady or drifting narrowband disturbances	102
C.4	Recommended procedure for automated or semi-automated measurements	104
Annex D (informative)	Explanation of the APD measurement method applying to the compliance test.....	105
Annex E (normative)	Determination of suitability of spectrum analyzers for compliance tests	107
Annex F (informative)	Background for EUT-volume specifications depending on measurement distance and frequency range	108
F.1	General.....	108
F.2	Criterion 1 – Limitation of field-strength underestimations due to a large ratio of EUT volume diameter-to-measurement distance for short-distance measurements	108
F.2.1	General	108
F.2.2	9 kHz to 30 MHz	108
F.2.3	30 MHz to 1 000 MHz	109
F.2.4	1 GHz to 18 GHz	109
F.3	Criterion 2 – Limitation due to near-field effects	110
F.3.1	General	110
F.3.2	9 kHz to 30 MHz	110
F.3.3	30 MHz to 1 000 MHz	110
F.3.4	1 GHz to 18 GHz	112
F.4	Criterion 3 – Limitation due to receive antenna beamwidth.....	113
F.4.1	General	113
F.4.2	9 kHz to 30 MHz	113
F.4.3	30 MHz to 1 000 MHz	113
F.4.4	1 GHz to 18 GHz	115
F.5	Criterion 4 – Limitation due to the results of test site validation.....	118
F.5.1	General	118
F.5.2	9 kHz to 30 MHz	118
F.5.3	30 MHz to 1 000 MHz	118
F.5.4	1 GHz to 6 GHz or to 18 GHz.....	118
Bibliography.....		119
Figure 1 – Measurement of a combination of a CW signal (NB) and an impulsive signal (BB) using multiple sweeps with maximum hold		29
Figure 2 – Example of a timing analysis		30
Figure 3 – A broadband spectrum measured with a stepped receiver		31
Figure 4 – Intermittent narrowband disturbances measured using fast short repetitive sweeps with maximum hold function to obtain an overview of the emission spectrum.....		32
Figure 5 – FFT scan in segments		34
Figure 6 – Frequency resolution enhanced by FFT-based measuring instrument.....		35
Figure 7 – Concept of magnetic field induced current measurements made with the loop antenna system.....		40

Figure 8 – Measurement distance	42
Figure 9 – Separation distance relative to the phase centre of an LPDA antenna	44
Figure 10 – Concept of electric field strength measurements made on an open-area test site (OATS) or semi-anechoic chamber (SAC) showing the direct and reflected rays arriving at the receiving antenna	45
Figure 11 – Position of CMAD for table-top equipment on OATS or in SAC	48
Figure 12 – Typical FAR site geometry, where a , b , c , e depend upon the room performance	49
Figure 13 – Typical test set-up for table-top equipment within the test volume of a FAR	50
Figure 14 – Typical test set-up for floor-standing equipment within the test volume of a FAR	51
Figure 15 – Positions of reference planes for uniform field calibration (top-view)	54
Figure 16 – Test set-up for table-top equipment	58
Figure 17 – Test set-up for table-top equipment – Top view	59
Figure 18 – Test set-up for floor-standing equipment	60
Figure 19 – Test set-up for floor-standing equipment – Top view	61
Figure 20 – Measurement method above 1 GHz, receive antenna in vertical polarization	64
Figure 22 – Determination of the transition distance	75
Figure 23 – Substitution method set-up geometries for: a) measurement, b) calibration	77
Figure 24 – Process to give reduction of measurement time	79
Figure A.1 – Flow diagram for the selection of bandwidths and detectors and the estimated measurement errors due to that selection	86
Figure A.2 – Relative difference in adjacent emission amplitudes during preliminary testing	88
Figure A.3 – Disturbance by an unmodulated signal (dotted line)	89
Figure A.4 – Disturbance by an amplitude-modulated signal (dotted line)	89
Figure A.5 – Indication of an amplitude-modulated signal as a function of modulation frequency with the QP detector in CISPR bands B, C and D	90
Figure A.6 – Indication of a pulse-modulated signal (pulse width 50 μ s) as a function of pulse repetition frequency with peak, QP and average detectors	91
Figure A.7 – Disturbance by a broadband signal (dotted line)	91
Figure A.8 – Unmodulated EUT disturbance (dotted line)	92
Figure A.9 – Amplitude-modulated EUT disturbance (dotted line)	93
Figure A.10 – Increase of peak value with superposition of two unmodulated signals	94
Figure A.11 – Determination of the amplitude of the disturbance signal by means of the amplitude ratio d and the factor i (see Equation (A.3) and Equation (A.6))	95
Figure A.12 – Increase of average indication measured with a real receiver and calculated from Equation (A.8)	96
Figure C.1 – Weighting function of a 10 ms pulse for peak (PK) and average detections with (CISPR AV) and without (AV) peak reading: meter time constant 160 ms	103
Figure C.2 – Weighting functions of a 10 ms pulse for peak (PK) and average detections with (CISPR AV) and without (AV) peak reading: meter time constant 100 ms	103
Figure C.3 – Example of weighting functions (of a 1 Hz pulse) for peak (PK) and average detections as a function of pulse width: meter time constant 160 ms	104
Figure C.4 – Example of weighting functions (of a 1 Hz pulse) for peak (PK) and average detections as a function of pulse width: meter time constant 100 ms	104

Figure D.1 – Example of APD measurement Method 1 for fluctuating disturbances	105
Figure D.2 – Example of APD measurement Method 2 for fluctuating disturbances	106
Figure F.1 – Comparison of field strength given by Equation (C.17) of CISPR 16-1-6:2014 versus near-field region given by Equation (C.31) of CISPR 16-1-6:2014	112
Figure F.2 – Deviation of near-field AFs from free space AFs of a biconical antenna (from Figure C.5.b) of CISPR 16-1-6:2014)	112
Figure F.3 – Radius r of the test volume for a given distance d and antenna beamwidth of 60°	114
Figure F.4 – Effect of antenna directivity	115
Figure F.5 – HPBWs (E-plane/H-plane) of a V-type LPDA antenna	115
Figure F.6 – Measuring receiver with external preamplifier	116
Figure F.7 – Noise level E_{Nlinav} (example for $10\lg F_{tot} = 4$ dB) compared with the disturbance limit E_{LAv} for the linear average detector for 3 m, 5 m, and 10 m distances in the frequency range 1 GHz to 6 GHz	117
Figure F.8 – Noise level E_{Nlogav} (example for $10\lg F_{tot} = 4$ dB) compared with the disturbance limit E_{LAv} for the logarithmic average detector for 3 m, 5 m, and 10 m distances in the frequency range 1 GHz to 18 GHz	118
Table 1 – Minimum measurement times for the four CISPR bands	26
Table 2 – Minimum scan times for the three CISPR bands with peak and quasi-peak detectors	26
Table 5 – Example values of w for three antenna types	65
Table 6 – Horizontal polarization correction factors as a function of frequency	74
Table 7 – Recommended antenna heights to guarantee signal interception (for pre-scan) in the frequency range 30 MHz to 1 000 MHz	81
Table 8 – Applicable frequency ranges and document references for CISPR radiated disturbance test sites and measurement methods	36
Table 9 – Maximum EUT dimensions for different LLAS diameters, 9 kHz to 30 MHz	37
Table 10 – Recommended maximum EUT-volume diameter D (in m) and height h (in m), OATS/SAC and outdoor site, 9 kHz to 30 MHz	37
Table 11 – Maximum EUT-volume diameter D (in m) and height h (in m), OATS/SAC and FAR, 30 MHz to 1 000 MHz	38
Table 12 – Recommended maximum EUT-volume diameter D (in m) and height h (in m) – for reduced near-field uncertainty; absorber-lined OATS/SAC and FAR, 1 GHz to 18 GHz	38
Table A.1 – Combinations of EUT disturbance and ambient emissions	85
Table A.2 – Measurement error depending on the detector type and on the combination of ambient and disturbing signal spectra	97
Table C.1 – Pulse suppression factors and scan rates for a 100 Hz video bandwidth	102
Table C.2 – Meter time constants and the corresponding video bandwidths and minimum scan times	102
Table E.1 – Maximum amplitude difference between peak and quasi-peak detected signals	107
Table F.1 – Maximum EUT volume diameters (D_{max}) and heights (h_{max}) per Formula (F.1) for various measurement distances (d)	111

INTERNATIONAL ELECTROTECHNICAL COMMISSION
INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY
MEASURING APPARATUS AND METHODS –**

**Part 2-3: Methods of measurement of disturbances and immunity –
Radiated disturbance measurements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard CISPR 16-2-3 has been prepared by CISPR subcommittee A: Radio-interference measurements and statistical methods.

This fourth edition edition cancels and replaces the third edition published in 2010, its Amendment 1:2010 and its Amendment 2:2014. This edition constitutes a technical revision.

This edition includes the following significant technical change with respect to the previous edition: addition of content on correction of the electric field strength to account for phase centre of log-periodic dipole array antennas.

CISPR 16-2-3:2016+A2:2023
© IEC 2023

It has the status of a basic EMC publication in accordance with IEC Guide 107, *Electromagnetic compatibility – Guide to the drafting of electromagnetic compatibility publications*.

The text of this standard is based on the following documents:

FDIS	Report on voting
CISPR/A/1176A/FDIS	CISPR/A/1182/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the CISPR 16 series, published under the general title *Specification for radio disturbance and immunity measuring apparatus and methods*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Amendment of CISPR 16-2-3 regarding EUT volume specifications for radiated disturbance measurements depending on test method and on measurement distance

SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY MEASURING APPARATUS AND METHODS –

Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements

1 Scope

This part of CISPR 16 specifies the methods of measurement of radiated disturbance phenomena in the frequency range of 9 kHz to 18 GHz. The aspects of measurement uncertainty are specified in CISPR 16-4-1 and CISPR 16-4-2.

NOTE In accordance with IEC Guide 107 [13]¹, CISPR 16-2-3 is a basic EMC publication for use by product committees of the IEC. As stated in Guide 107, product committees are responsible for determining the applicability of the EMC standard. CISPR and its subcommittees are prepared to co-operate with product committees in the evaluation of the value of particular EMC tests for specific products.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 14-1:2016, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 16-1-1, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus*

CISPR 16-1-2:2014, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Coupling devices for conducted disturbance measurements*

A2 CISPR 16-1-4:2019, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-4: Radio disturbance and immunity measuring apparatus – Antennas and test sites for radiated disturbance measurements*

CISPR 16-1-4:2019/AMD1:2020

CISPR 16-1-4:2019/AMD2:2023 **A2**

CISPR 16-2-1:2014, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements*

CISPR TR 16-4-1, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-1: Uncertainties, statistics and limit modelling – Uncertainties in standardized EMC tests*

¹ Numbers in square brackets refer to the Bibliography.