

American Nuclear Society


WITHDRAWN

May 2, 1996
ANSI/ANS-59.1-1986

**nuclear safety related cooling water
systems for light water reactors**

an American National Standard

**No longer being maintained as an
American National Standard. This
standard may contain outdated material
or may have been superseded by
another standard. Please contact the
ANS Standards Administrator for
details.**



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

**American National Standard
for Nuclear Safety Related Cooling Water
Systems for Light Water Reactors**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-59.1**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA**

Approved May 2, 1986
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to assure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Copyright © 1986 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-59.1-1986 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

FOREWORD (This foreword is not a part of American National Standard for Nuclear Safety Related Cooling Water Systems for Light Water Reactors, ANSI/ANS 59.1-1986)

This standard is applicable to light water reactor nuclear power plants.

This standard was originally issued in 1979 and has been completely revised to conform to the latest revisions of American National Standards Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants, ANSI/ANS-51.1-1983, and Nuclear Safety Criteria for the Design of Stationary Boiling Water Reactor Plants, ANSI/ANS-52.1-1983, and to the latest design concepts developed since the 1979 TMI-II accident. A draft of this revision was submitted to the ANS-52 Subcommittee in 1983, who also obtained comments from ANS-4 and ANS-51 Subcommittees.

The membership of ANS-52, the BWR Criteria Committee, at the time of its review in 1983 had the following membership:

W. H. D'Ardenne, Chairman, General Electric Company	P. D. Metcalf, Jr., Tennessee Valley Authority
D. M. Crowe, Southern Company Services	P. M. Pivawer, Power Authority of the State of New York
O. J. Foster, General Electric Company	H. A. Putre, Cleveland Electric Illuminating
E. E. Fricks, Stone & Webster Engineering Corporation	T. J. Raney, Ebasco Services Incorporated
H. B. Friend, Bechtel Corporation	R. E. Scott, General Electric Company
R. J. Mazza, Sargent & Lundy	H. C. Shaffer, Yankee Atomic Electric Company

Comments from this review were incorporated and a revised draft of this standard was submitted to the American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) for ballot in 1984. All "disapproved" votes were resolved and other comments incorporated into this revision.

Working Group ANS-59.1 of the Standards Committee of the American Nuclear Society had the following membership at the time it developed this standard:

J. Klein, Chairman, Ebasco Services Incorporated	G. Bramblett, GA Technologies, Inc.
R. Etling, Westinghouse Electric Company	W. N. (Norm) Prillaman, Babcock & Wilcox Company

Former Members:

A. W. Flynn, Chairman Emeritus,
General Interest

A. Cesnavicius, Ebasco Services
Incorporated

E. Swanson, Babcock & Wilcox Company

M. S. Smolik, Chairman,
Consolidated Edison Company

N. Rudikoff, Stone and
Webster Engineering
Corporation

V. C. Kobold, General
Electric Company

Contributors:

P. Tanguy, Commissariat A L'Energie
Atomic, France

Sub-Committee 6 of the
Nuclear Power Engineering
Committee of IEEE.

The American Nuclear Society's Nuclear Power Plant Standards
Committee (NUPPSCO) had the following membership at the time of its
approval of this standard:

L. J. Cooper, Chairman
M. D. Weber, Secretary

Representative

Organization

R. V. Bettinger.....	Pacific Gas and Electric Company
F. A. Boorboor.....	United Engineers and Constructors
W. S. Brown.....	Westinghouse Electric Corporation
C. O. Coffey.....	Pacific Gas and Electric Company
L. J. Cooper.....	Nebraska Public Power District (for the American Nuclear Society)
J. D. Crawford.....	Combustion Engineering, Inc.
W. H. D'Ardenne.....	General Electric Company
S. B. Gerges.....	NUS Corporation
C. J. Gill.....	Bechtel National, Inc.
C. E. Johnson.....	U.S. Nuclear Regulatory Commission
J. F. Mallay.....	Management Analysis Company
L. M. Mills.....	Tennessee Valley Authority
P. T. Reichert.....	Stearns Catalytic Corporation
B. M. Rice.....	Duke Power Company (for the Institute of Electrical and Electronics Engineers, Inc.)
W. J. Rowan.....	Electric Power Research Institute
M. O. Sanford.....	GPU Service Corporation
S. L. Stamm.....	Stone & Webster Engineering Corporation
J. D. Stevenson.....	Structural Mechanics Associates (for the American Society of Civil Engineers)
T. J. Sullivan.....	Institute of Nuclear Power Operations
C. D. Thomas.....	Yankee Atomic Electric Company
W. T. Ullrich.....	Philadelphia Electric Company
G. P. Wagner.....	Commonwealth Edison Company
G. P. Wessman.....	Torrey Pines Technology
J. E. Windhorst.....	Southern Company Services, Inc.
G. A. Zimmerman.....	Portland General Electric Company

CONTENTS	Section	Page
1.	Scope and Function.....	1
1.1	Scope	1
1.2	System Nuclear Safety Functions.....	1
2.	Definitions.....	1
3.	System Description.....	1
4.	System Performance Criteria.....	1
4.1	Design Capacity.....	1
4.2	Protection Against Effects of Natural Phenomena.....	2
4.3	System Protection Criteria.....	2
4.4	Power Supply Criteria.....	3
4.5	Instrument Requirements.....	3
4.6	System Design Pressure and Overpressure Protection.....	3
4.7	Valve and Operator Design Criteria.....	4
4.8	Corrosion and Erosion Protection.....	4
4.9	Radiation and Monitoring.....	4
4.10	Pump Criteria.....	4
4.11	Screens, Strainers or Filters.....	5
4.12	Heat Exchangers.....	5
4.13	Atmospheric Cooling Equipment.....	6
4.14	Vents.....	6
4.15	Tanks.....	6
5.	Design Requirements.....	6
5.1	Equipment Classes.....	6
5.2	Plant Conditions.....	6
5.3	Interfaces.....	7
5.4	Testing and Maintenance Requirements.....	7
5.5	Design Documentation.....	9
6.	Quality Assurance.....	9
7.	References.....	9