

American Nuclear Society


WITHDRAWN

**August 30, 2012
ANSI/ANS-59.3-1992 (R2002)**

**nuclear safety criteria for
control air systems**

an American National Standard

No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.



published by the
American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA

**American National Standard
Nuclear Safety Criteria for
Control Air Systems**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-59.3**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60525 USA**

Approved July 28, 1992
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

American Nuclear Society
555 North Kensington Avenue, La Grange Park, Illinois 60525 USA

Copyright © 1993 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-59.3-1992 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Foreword

(This foreword is not part of American National Standard Safety Criteria for Control Air Systems, ANSI/ANS-59.3-1992.)

This standard was initially issued in 1977 and applied only to nuclear safety-related control air systems. It was expanded in 1984 to include the non-nuclear safety-related control air system that supplies air to nuclear safety-related equipment. This revision has been further expanded to include recommended design criteria for non-nuclear safety-related portions of control air systems.

This standard applies to the control air system that furnishes air to nuclear safety-related components in nuclear power plants and does not apply to the air-operated device itself. It does not overlap or replace any other code or standard (i.e., any standard for air-operated actuators) but should be used in conjunction with these standards or codes since other system requirements must be considered in the design of the control air system.

This standard is written for new nuclear power plants. A plant owner may elect to apply this standard in whole or in part to an existing licensed plant if the application is consistent with the requirements and commitments in the plant specific licensing and design bases.

This standard was developed by Working Group ANS-59.3 of the Standards Committee of the American Nuclear Society, which had the following membership:

K. V. Allen, Chairman, <i>GENSYS</i>	D. E. Sexton, Secretary, <i>TENERA, L.P.</i>
R. L. Klug, <i>H. G. Klug Company</i>	A. C. Tan, <i>Southern California Edison Company</i>
P. S. Kish, <i>Sargent & Lundy</i>	R. Tassel, <i>Detroit Edison Company</i>
H. McShane (Former Member), <i>Southern California Edison Company</i>	

The membership of MC-1, LWR Criteria Management Committee, at the time of its approval of the standard was as follows:

W. H. D'Ardenne, Chairman, *General Electric Company*
E. J. Borella, *Ebasco Services, Inc.*
R. Fortier, *Stone & Webster Engineering Corporation*
J. C. Glynn, *U.S. Nuclear Regulatory Commission*
P. Hepner, *Combustion Engineering, Inc.*
D. G. Keith, *Bechtel Power Corporation*
H. G. O'Brien, *Tennessee Valley Authority*
H. C. Shaffer III, *Yankee Atomic Electric Company*
D. J. Spellman, *Advanced Technologies Engineering Systems, Inc.*
R. C. Surman, *Westinghouse Electric Corporation*
E. W. Swanson, *Babcock & Wilcox Company*

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time of its ballot for approval of this standard:

W. T. Ullrich, Chairman

M. D. Weber, Secretary

F. Boorboor	United Engineers & Constructors
J. C. Bradford	Bechtel National, Inc.
L. J. Cooper	Nebraska Public Power District
J. D. Crawford	Combustion Engineering, Inc.
R. G. Domer	Pacific Gas & Electric Company
W. H. D'Ardenne (Vice Chairman)	General Electric Company
S. N. Ehrenpreis	Westinghouse Electric Corporation
S. B. Gerges	NUS Corporation
D. L. Gillispie	Institute of Nuclear Power Operations
C. E. Johnson, Jr.	U.S. Nuclear Regulatory Commission
R. T. Lancet	Rockwell International Corporation
J. F. Mallay	Advanced Technology Engineering Systems, Inc.
R. E. Miller	Duke Power Company
J. A. Nevshemal	Toledo Edison Company
T. T. Robin	Southern Company Services, Inc.
D. R. Roth	General Physics Corporation
J. C. Saldarini	Ebasco Services, Inc.
S. L. Stamm	Stone & Webster Engineering Corporation
J. D. Stevenson	Stevenson & Associates
C. D. Thomas, Jr.	Yankee Atomic Electric Company
W. T. Ullrich	Philadelphia Electric Company (for the American Nuclear Society)
(vacant)	Tennessee Valley Authority
G. P. Wagner	Commonwealth Edison Company
N. Weber	Sargent & Lundy
G. J. Wrobel	Rochester Gas & Electric Corporation

Contents	Section	Page
	1. Scope	1
	2. Definitions	1
	3. System Function	3
	3.1 Nuclear Safety-Related	3
	3.2 Non-Nuclear Safety-Related	3
	4. System Definition	3
	5. System Performance Requirements	3
	6. Design Requirements	3
	6.1 Safety Class and Applicable Standards	3
	6.2 Conditions of Design	3
	6.3 Interface	5
	6.4 System and Component Testing Provisions	6
	6.5 Quality Assurance	7
	7. References	7
 Figures		
	Figure 1 Examples of Redundant Control Air Systems	2