

Guidelines and Methods for Inspection of Existing Atmospheric and Low-pressure Storage Tanks

API RECOMMENDED PRACTICE 575
SECOND EDITION, MAY 2005



Guidelines and Methods for Inspection of Existing Atmospheric and Low-pressure Storage Tanks

Downstream Segment

API RECOMMENDED PRACTICE 575
SECOND EDITION, MAY 2005



SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Standards department telephone (202) 682-8000. A catalog of API publications, programs and services is published annually and updated biannually by API, and available through Global Engineering Documents, 15 Inverness Way East, M/S C303B, Englewood, CO 80112-5776.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the Director of the Standards department, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should be addressed to the Director, Business Services.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.

FOREWORD

This recommended practice is based on the accumulated knowledge and experience of engineers and inspectors in the petroleum and chemical industries.

Some of the information contained in this publication was previously presented as Chapter XIII of the *API Guide for Inspection of Refinery Equipment*, which is being reorganized as an individual recommended practice. The information in this recommended practice does not constitute and should not be construed as a code of rules, regulations, or minimum safe practices. The practices described in this publication are not intended to supplant other practices that have proven satisfactory, nor is this publication intended to discourage innovation and originality in inspection. Users of this recommended practice are reminded that no book or manual is a substitute for the judgment of a responsible, qualified person.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the standardization manager, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005, standards@api.org.

IMPORTANT INFORMATION CONCERNING USE OF ASBESTOS OR ALTERNATIVE MATERIALS

Asbestos is specified or referenced for certain components of the equipment described in some API standards. It has been of extreme usefulness in minimizing fire hazards associated with petroleum processing. It has also been a universal sealing material, compatible with most refining fluid services.

Certain serious adverse health effects are associated with asbestos, among them the serious and often fatal diseases of lung cancer, asbestosis, and mesothelioma (a cancer of the chest and abdominal linings). The degree of exposure to asbestos varies with the product and the work practices involved.

Consult the most recent edition of the Occupational Safety and Health Administration (OSHA), U.S. Department of Labor, Occupational Safety and Health Standard for Asbestos, Tremolite, Anthophyllite, and Actinolite, 29 *Code of Federal Regulations* Section 1910.1001; the U.S. Environmental Protection Agency, National Emission Standard for Asbestos, 40 *Code of Federal Regulations* Sections 61.140 through 61.156; and the U.S. Environmental Protection Agency (EPA) rule on labeling requirements and phased banning of asbestos products (Sections 763.160-179).

There are currently in use and under development a number of substitute materials to replace asbestos in certain applications. Manufacturers and users are encouraged to develop and use effective substitute materials that can meet the specifications for, and operating requirements of, the equipment to which they would apply.

SAFETY AND HEALTH INFORMATION WITH RESPECT TO PARTICULAR PRODUCTS OR MATERIALS CAN BE OBTAINED FROM THE EMPLOYER, THE MANUFACTURER OR SUPPLIER OF THAT PRODUCT OR MATERIAL, OR THE MATERIAL SAFETY DATA SHEET.

CONTENTS

	Page
1 SCOPE.....	1
2 REFERENCES	1
2.1 Codes, Standards, and Related Publications	1
2.2 Other References	2
3 DEFINITIONS.....	2
4 TYPES OF STORAGE TANKS.....	3
4.1 General.....	3
4.2 Atmospheric Storage Tanks.....	4
4.3 Low-pressure Storage Tanks	12
5 REASONS FOR INSPECTION AND CAUSES OF DETERIORATION.....	13
5.1 Reasons for Inspection.....	13
5.2 Deterioration of Tanks	15
5.3 Deterioration of Other Than Flat Bottom and Non-steel Tanks	17
5.4 Leaks, Cracks, and Mechanical Deterioration	17
5.5 Deterioration and Failure of Auxiliary Equipment	20
5.6 Similar Service Methodology for Establishing Tank Corrosion Rates.....	20
6 INSPECTION FREQUENCY AND SCHEDULING	21
6.1 Frequency of Inspection.....	21
6.2 Condition-based Inspection Scheduling	22
6.3 Risk-based Inspection	25
6.4 Fitness-for-Service Evaluation	25
7 METHODS OF INSPECTION.....	25
7.1 Preparation for Inspections	25
7.2 External Inspection of an In-service Tank.....	26
7.3 External Inspection of Out-of-Service Tanks	36
7.4 Internal Inspection	38
7.5 Testing of Tanks	47
7.6 Inspection Checklists.....	48
8 LEAK TESTING AND HYDRAULIC INTEGRITY OF THE BOTTOM	48
8.1 General.....	48
8.2 Leak Integrity Methods Available during Out-of-Service Periods.....	50
8.3 Leak Detection Methods Available during In-service Periods	53
9 INTEGRITY OF REPAIRS AND ALTERATIONS.....	55
9.1 General.....	55
9.2 Repairs	55
9.3 Special Repair Methods.....	57
10 RECORDS	58
10.1 General.....	58
10.2 Records and Reports	58
10.3 Form and Organization	59

APPENDIX A	SELECTED NON-DESTRUCTIVE EXAMINATION (NDE)	
	METHODS	61
APPENDIX B	SIMILAR SERVICE EVALUATION TABLES	63
APPENDIX C	SELECTED BIBLIOGRAPHY	67

Figures

1	Cone Roof Tank	5
2	Umbrella Roof Tank	5
3	Geodesic Dome Roof Tank	5
4	Self-supporting Dome Roof	6
5	Pan-type Floating-roof Tank	6
6	Annular-pontoon Floating-roof Tank	6
7	Double-deck Floating-roof Tank	6
8	Cross-section Sketches of Floating-roof Tanks Showing the Most Important Features	7
9	Floating-roof Shoe Seal	8
10	Floating-roof Foam Log Seal	8
11	Floating Roof Using Counterweights to Maintain Seal	9
12	Floating Roof Using Resilient Tube-type Seal	9
13	Typical Internal Floating-roof Components	10
14	Typical Arrangement for Metallic Float Internal Floating-roof Seals	11
15	Plain Breather Roof Tanks	12
16	Balloon Roof Tank	12
17	Tank with Vapor Dome Roof	13
18	Cutaway View of Vapor Dome Roof	13
19	Welded Horizontal Tank Supported on Saddles	14
20	Plain Hemispheroids	14
21	Noded Hemispheroids	14
22	Drawing of Hemispheroid	15
23	Plain Hemispheroid with Knuckle Radius	15
24	Plain Spheroid	15
25	Noded Spheroid	15
26	Drawing of Noded Spheroid	16
27	Foundation Seal	16
28	Extensive Destruction from Instantaneous Failure	18
29	Cracks in Tank Shell Plate	19
30	Cracks in Bottom Plate Welds Near the Shell-to-Bottom Joint	19
31	Cracks in Tank at Riveted Lap Joint to Tank Shell	20
32	Hypothetical Corrosion Rate Curves for Top Course of Storage Tank	23
33	Failure of Concrete Ringwall	27
34	Anchor Bolt	27
35	Corrosion of Anchor Bolts	27
36	Corrosion under Insulation	29
37	Close-up of Corrosion under Insulation	30
38	Corrosion (External) at Grade	31
39	Caustic Stress Corrosion Cracks	32
40	Small Hydrogen Blisters on Shell Interior	32
41	Large Hydrogen Blisters on Shell Interior	32
42	Tank Failure Caused by Inadequate Vacuum Venting	33
43	Roof Overpressure	34
44	Example of Severe Corrosion of Tank Roof	36
45	Deterioration of Floating-roof Seal	37

46	Collapse of Pan-type Roof from Excessive Weight of Water While the Roof was Resting on its Supports	38
47	Pontoon Floating-roof Failure.	39
48	Tank Buggy Used for Inspection and Repairs Inside of Tank	40
49	Remote-control Automated Crawler.	41
50	Example of Vapor-liquid Line Corrosion	41
51	Corrosion behind Floating-roof Seal	42
52	Localized Corrosion-erosion at Riveted Seam in a Tank Bottom	43
53	Example of Extensive Corrosion of a Tank Bottom.	44
54	Shell-to-Bottom Weld Corrosion	45
55	External View of Corrosion-erosion Completely Through a Tank Shell.	45
56	Deterioration of Lining on Roof of Tank Caused by Leaks in Lining.	46
57	Internal Corrosion on Rafters and Roof Plates	46
58	Failure of Roof Supports.	46
59	Fin-tube Type of Heaters Commonly Used in Storage Tanks	46
60	Example of Corrosion of Steam Heating Coil	47
61	Hydraulic Integrity Test Procedures	49
62	Vacuum Box Used for Testing Leaks	51
63	Vacuum Test Box Arrangement for Detection of Leaks in Vacuum Seals.	51
64	Helium Tester	52
65	Method of Repairing Tank Bottoms	57
66	Temporary “Soft Patch” over Leak in Tank Roof.	58
67	Mastic Roof Coating	58
68	Tank Jacked Up for Repairing Pad	58
A-1	Automatic UT	62
A-2	MFL Scanner.	62
A-3	UT Scrub	62
A-4	Robotic Inspection Tool	62

Tables

1	Tools for Tank Inspection	25
2	Tools to Be Available in Case Needed for Tank Inspection	26
B-1	Selected Factors for Using Similar Service Principles in Estimating Corrosion Rates for Tank Bottoms	64
B-2	Similar Service Example for Product-side Corrosion	66

Guidelines and Methods for Inspection of Existing Atmospheric and Low-pressure Storage Tanks

1 Scope

This document provides useful information and recommended practices for the maintenance and inspection of atmospheric and low-pressure storage tanks. While some of these guidelines may apply to other types of tanks, these practices are intended primarily for existing tanks that were constructed to API Spec 12A or API Spec 12C, and API Std 620 or API Std 650. This recommended practice includes:

- a. Descriptions of the various types of storage tanks.
- b. Construction standards.
- c. Maintenance practices.
- d. Reasons for inspection.
- e. Causes of deterioration.
- f. Frequency of inspection.
- g. Methods of inspection.
- h. Inspection of repairs.
- i. Preparation of records and reports.
- j. Safe and efficient operations.
- k. Leak prevention methods.

This recommended practice is intended to supplement API Std 653, which provides minimum requirements for maintaining the integrity of storage tanks after they have been placed in service.

2 References

2.1 CODES, STANDARDS, AND RELATED PUBLICATIONS

The following standards, codes, publications, and specifications are cited in this recommended practice. The latest edition or revision shall be used unless otherwise noted.

API

Spec 12A	<i>Specification for Oil Storage Tanks with Riveted Shells (out of print)</i>
Spec 12B	<i>Bolted Tanks for Storage of Production Liquids</i>
Spec 12C	<i>API Specification for Welded Oil Storage Tanks (out of print)</i>
Spec 12D	<i>Field Welded Tanks for Storage of Production Liquids</i>
Spec 12E	<i>Specification for Wooden Production Tanks (out of print)</i>
Spec 12F	<i>Shop Welded Tanks for Storage of Production Liquids</i>

RP 12R1	<i>Recommended Practice for Setting, Maintenance, Inspection, Operation and Repair of Tanks in Production Service</i>
Publ 306	<i>An Engineering Assessment of Volumetric Methods of Leak Detection In Above-ground Storage Tanks</i>
Publ 307	<i>An Engineering Assessment of Acoustic Methods of Leak Detection In Above-ground Storage Tanks</i>
Publ 315	<i>Assessment of Tankfield Dike Lining Materials and Methods</i>
Publ 322	<i>An Engineering Evaluation of Acoustic Methods of Leak Detection In Above-ground Storage Tanks</i>
Publ 323	<i>An Engineering Evaluation of Volumetric Methods of Leak Detection In Above-ground Storage Tanks</i>
Publ 325	<i>An Evaluation of a Methodology for the Detection of Leaks in Aboveground Storage Tanks</i>
Publ 334	<i>A Guide to Leak Detection for Above-ground Storage Tanks</i>
Publ 340	<i>Liquid Release Prevention and Detection Measures for Aboveground Storage Facilities</i>
Publ 341	<i>A Survey of Diked-Area Liner Use at Aboveground Storage Tank Facilities</i>
API 570	<i>Inspection, Repair, Alteration, and Rerating of In-Service Piping Systems</i>
RP 571	<i>Damage Mechanisms Affecting Fixed Equipment in the Refining Industry</i>
RP 572	<i>Inspection of Pressure Vessels</i>
RP 576	<i>Inspection of Pressure-Relieving Devices</i>
RP 579	<i>Fitness-for-Service</i>
RP 580	<i>Risk-Based Inspection</i>
Publ 581	<i>Risk-Based Inspection—Base Resource Document</i>
Std 620	<i>Design and Construction of Large, Welded, Low-Pressure Storage Tanks</i>
Std 650	<i>Welded Steel Tanks for Oil Storage</i>
RP 651	<i>Cathodic Protection of Aboveground Petroleum Storage Tanks</i>
RP 652	<i>Lining of Aboveground Petroleum Storage Tank Bottoms</i>
Std 653	<i>Tank Inspection, Repair, Alteration, and Reconstruction</i>