

# IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations

IEEE Power and Energy Society

Sponsored by the  
Nuclear Power Engineering Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA

**IEEE Std 497™-2016**  
(Revision of  
IEEE Std 497-2010)

**IEEE Std 497™-2016**

(Revision of  
IEEE Std 497-2010)

# **IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations**

Sponsor

**Nuclear Power Engineering Committee  
of the  
IEEE Power and Energy Society**

Approved 15 May 2016

**IEEE-SA Standards Board**

**Abstract:** Established in this standard are criteria for variable selection, performance, design, and qualification of accident monitoring instrumentation for anticipated operational, design basis events and severe accidents.

**Keywords:** accident monitoring, design criteria, display criteria, IEEE 497™, performance criteria, selection criteria, severe accidents, type variables

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2016 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 29 July 2016. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-5044-1810-2      STD20910  
Print: ISBN 978-0-5044-1811-9      STDPD20910

*IEEE prohibits discrimination, harassment, and bullying.*

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

## **Important Notices and Disclaimers Concerning IEEE Standards Documents**

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

### **Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents**

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

### **Translations**

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

## **Official statements**

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

## **Comments on standards**

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854 USA

## **Laws and regulations**

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## **Copyrights**

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## **Photocopies**

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/Xplore/home.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

## Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this IEEE standard was completed, the Accident Monitoring Instrumentation Working Group had the following membership:

**Greg M. Hostetter, Chair**

Michiaki Akiyama  
Jeri Chadwick  
Alexander Duchac  
James Gleason

Takeshi Ikeuchi  
Gary Johnson  
Jason Karns  
Alex Klemptner

**Daryl Harmon, Vice Chair**

Wolfgang Koenig  
Ifti Rana  
Yumi Sato  
Deirdre Spaulding-  
Yeoman  
Steve Wyman

At the time this IEEE standard was submitted to the IEEE-SA Standards Board for approval, the Nuclear Power Engineering Committee had the following membership:

**Stephen Fleger, Chair**

Satish Aggarwal  
Ijaz Ahmad  
George Ballassi  
Royce Beacom  
Mark Bowman  
Keith Bush  
Robert C. Carruth  
John P. Carter  
Suresh  
Channarasappa  
Paul Colaianni  
Tom Crawford  
Dennis Dellinger  
David R. Desaulniers

**Thomas Koshy, Vice Chair**

John Disosway  
Kenneth Fleischer  
Robert J. Fletcher  
Robert Francis  
Cristopher H.  
Georgeson  
James F. Gleason  
Dale Goodney  
Robert Hall  
David Herrell  
Dirk Hopp  
Greg M. Hostetter  
Steven Hutchins  
Gary Johnson

**Daryl Harmon, Secretary**

Chris Kerr  
Wolfgang Koenig  
Robert Konnik  
James K. Liming  
Bruce Lord  
Scott Malcolm  
Kenneth Miller  
Michael H. Miller  
Edward R.  
Mohtashemi  
Yasushi Nakagawa  
Warren R. Odess-  
Gillett  
Ted Riccio  
Mitchell L.  
Staskiewicz  
Rebecca Steinman  
John A. Stevens  
Marek Tengler  
Sudhir Thakur  
James E. Thomas  
Masafumi Utsumi  
Tammy Womack  
John White  
Yvonne Williams  
Paul L. Yanosy, Sr.

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman	John Disosway	Gary Johnson	Robert Queenan
Satish Aggarwal	Stephen Fleger	Piotr Karocki	Ted Riccio
George Ballassi	James Gleason	Robert Konnik	Bartien Sayogo
Royce Beacom	Randall Groves	Thomas Koshy	Deirdre Spaulding- Yeoman
William Bloethe	Ajit Gwal	G. Lang	Rebecca Steinman
Thomas Brewington	Daryl Harmon	Jang-Soo Lee	John Stevens
Daniel Brosnan	Hamidreza	William Lumpkins	John Vergis
Nissen Burstein	Heidarisaifa	John Macdonald	John White
Robert Carruth	Raymond Herb	Phillip McClure	Yvonne Williams
Suresh	David Herrell	Kirklyn Melson	Shuhui Zhang
Channarasappa	Werner Hoelzl	Michael Newman	
Weijen Chen	David Horvath	Warren Odess-Gillett	
Tom Crawford	Greg M. Hostetter	Jan Pirrong	

When the IEEE-SA Standards Board approved this standard on 15 May 2016, it had the following membership:

**Jean-Philippe Faure, Chair**

**Ted Burse, Vice Chair**

Chuck Adams  
Masayuki Ariyoshi  
Stephen Dukes  
Jianbin Fan  
J. Travis Griffith  
Gary Hoffman

Ronald W. Hotchkiss  
Michael Janezic  
Joseph L.  
Koepfinger\*  
Hung Ling  
Kevin Lu

**John Kulick, Past Chair**

**Konstantinos Karachalios, Secretary**

Annette D. Reilly  
Gary Robinson  
Mehmet Ulema  
Yingli Wen  
Philip Winston  
Howard Wolfman  
Don Wright  
Yu Yuan  
Daidi Zhong

\*Member Emeritus

## Introduction

This introduction is not part of IEEE Std 497™-2016, IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations.

## History

This standard evolved from IEEE Std 497™-2010 [B4]<sup>1</sup>. It represents a continued effort by IEEE to support the specification, design, and implementation of accident monitoring instrumentation of nuclear power generating stations.

IEEE Std 497-2010 [B4] was developed to provide criteria for advanced instrumentation system designs and design modifications based on modern digital technology. It marked a clear path forward for the application of new technology. Though still maintaining applicability to existing systems, this version of IEEE Std 497 provides more current guidance based on historically related standards and guidance.

It was the working group's intention that the criteria of this standard address the variety of possible accident monitoring channel configurations that current technology affords. It was also the working group's intention to address the display of information using computer generated displays and calculated values. The criteria presented in this standard provide guidance in this area without limiting the types of displays that can be made available to accident management personnel.

Although written primarily for new plant designs, existing plants may also use the guidance and applicable criteria in this standard. The use of applicable plant procedures to determine the requirements of the accident monitoring instrumentation provides the necessary flexibility for useful design criteria. This standard can be used to help address the necessary changes to the plant configuration that occur over the operating life of any plant.

Historically the standard addressed accident monitoring instrumentation used for anticipated operating occurrences (AOOs) and design basis events (DBEs). To address lessons learned from various industry events, the scope of this standard has evolved to now include severe accidents. This evolution was intended to provide a broader applicability to cover both preventative and mitigative phases of potential plant events. A broader applicability of the standard was also achieved by moving to a more international, technology neutral approach to the standard. This approach was achieved by changing to International Atomic Energy Agency (IAEA) definitions of terms, where applicable; the removal, where appropriate, of U.S. specific references; and involvement in the working group of members of other standards organizations. Furthermore, the corresponding International Electrotechnical Commission (IEC) counterparts to the IEEE standards referenced were investigated and introduced as a second set of normative references. This opens the possibility to apply this standard in the IEC domain. The individual IEEE and IEC reference sets in whole are individually appropriate for use in the application of the standard, but inclusion of the IEEE and IEC references does not imply equivalency between the individual references of the two sets.

## Intended use

The standard applies to instrumentation intended for use during anticipated operational occurrences (AOO), design basis events (DBE), and design extension conditions (DEC) including severe accidents.

This standard defines severe accidents as a subset of design extension conditions during which fuel damage has occurred. Operationally, severe accidents and design extension conditions without fuel damage are distinguished by the procedures and guidelines used to manage the event, with emergency operating

---

<sup>1</sup> The numbers in brackets correspond to those of the bibliography in Annex D.



procedures (EOP) used for design extension conditions without fuel damage and severe accident mitigation guidelines (SAMG) used for severe accidents (see Annex C).

The standard is to be applied to instruments designated for severe accidents (Type F variables); however, use of non-designated instruments during a severe accident is not precluded if these instruments are available and can aid in the accident mitigation. Design extension conditions that are not severe accidents are not covered by this standard.

This standard is intended to be used for both new plant designs and major modifications or upgrades of existing nuclear power generating stations. The standard can be applied to various reactor types used for power generation; however, development of the standard focused on light water reactors and application of the standard to reactor technologies beyond light water reactors should be evaluated prior to initial use.

## Revision summary

Since IEEE Std 497 was approved in 2010, industry events have occurred that highlighted the need for the standard to address not just design basis events but severe accidents as well. The working group has considered and incorporated appropriate changes related to the following significant items:

- Lessons learned from industry events including Fukushima (earthquake and tsunami), Browns Ferry (tornado), Salem (loss of RPS due to CCF), and North Anna (earthquake)
- Accident monitoring instrument requirements based on emergency procedures and guidelines (EOPs and SAMGs)
- Reactor technology neutral approach
- International usability
- User feedback
- Requirements for severe accidents instrumentation
- IAEA definitions

Other minor editorial improvements throughout the standard were also incorporated.

## Future work

As the use of digital technology in the nuclear plant is a dynamic area of design, the working group intends to keep this area as an ongoing future task.

Since no counterpart to this standard exists in the IEC domain, this standard was identified as a potential candidate for a dual-logo standard to be applied in both the IEEE and the IEC domain early in the course of this revision. A joint group of both organizations identified topics and aspects to be harmonized and recommended to proceed. Thus the recent revision was performed with the intent and the spirit to prepare and facilitate the application for the IEC domain. Formal involvement of the IEC was delayed. This revision of the standard is, therefore, still an IEEE standard, but may be further modified in the future after closer investigation by and discussion with IEC experts on its potential as a dual-logo standard.

Another area that the working group believes should be considered in a future revision to the standard is how to adopt risk-informed techniques into accident monitoring criteria.

Additionally, user feedback related to the implementation of the standard on non-light water reactors and implementation of Type F variables will be reviewed and considered for a future revision.

## Contents

1. Overview .....	11
1.1 Scope .....	11
1.2 Purpose .....	11
1.3 Application .....	11
2. Normative references.....	12
2.1 Normative references for IEEE domain.....	12
2.2 Normative references for IEC domain.....	13
3. Definitions.....	13
4. Selection criteria.....	16
4.1 Type A variables.....	16
4.2 Type B variables.....	16
4.3 Type C variables.....	17
4.4 Type D variables.....	17
4.5 Type E variables.....	17
4.6 Type F variables.....	18
4.7 Documentation of selection criteria.....	18
5. Performance criteria.....	19
5.1 Range.....	19
5.2 Accuracy.....	19
5.3 Response time.....	20
5.4 Required operating time.....	20
5.5 Reliability.....	20
5.6 Documentation of performance criteria.....	20
6. Design criteria.....	21
6.1 Single failure.....	21
6.2 Common cause failure.....	21
6.3 Independence and physical separation.....	21
6.4 Isolation.....	22
6.5 Information ambiguity.....	22
6.6 Power supply.....	23
6.7 Calibration.....	23
6.8 Testability.....	23
6.9 Direct measurement.....	24
6.10 Control of access.....	24
6.11 Maintenance and repair.....	24
6.12 Minimizing measurements.....	24
6.13 Auxiliary supporting features.....	24
6.14 Portable instruments.....	25
6.15 Documentation of design criteria.....	25
7. Qualification criteria.....	25
7.1 Type A variables.....	25
7.2 Type B variables.....	25
7.3 Type C variables.....	26
7.4 Type D variables.....	26
7.5 Type E variables.....	26

7.6 Type F variables .....	26
7.7 Portable instruments .....	27
7.8 Operating time .....	27
7.9 Documentation of qualification criteria .....	27
8. Display criteria .....	27
8.1 Display characteristics .....	27
8.2 Trend or rate information.....	28
8.3 Display identification .....	28
8.4 Type of monitoring channel display .....	28
8.5 Display location.....	28
8.6 Information ambiguity .....	29
8.7 Recording .....	29
8.8 Digital display signal validation .....	29
8.9 Documentation of display criteria.....	29
9. Quality assurance.....	29
Annex A (informative) Accident monitoring instrument channel accuracy .....	30
A.1 Introduction .....	30
A.2 Accuracy requirement groupings according to usage .....	30
A.3 Typical accuracy requirements .....	30
Annex B (informative) Examples of monitoring channel displays.....	31
Annex C (informative) Operational state diagram .....	33
Annex D (informative) Bibliography .....	34

# IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations

*IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

### 1.1 Scope

This standard contains the functional and design criteria for accident monitoring instrumentation for new plant designs and nuclear power generating stations desiring to perform design modifications.

### 1.2 Purpose

The purpose of this standard is to establish selection, design, performance, qualification, and display criteria for accident monitoring instrumentation for anticipated operational occurrences, design basis events, and severe accidents.

### 1.3 Application

This standard applies to accident monitoring instrumentation intended for use during the following operations:

- As required for planned operator action related to accident mitigation