

IEEE Standard for Requirements for Conversion of Power Switchgear Equipment

IEEE Power and Energy Society

Sponsored by the
Switchgear Committee

IEEE Standard for Requirements for Conversion of Power Switchgear Equipment

Sponsor

Switchgear Committee
of the
IEEE Power and Energy Society

Approved 14 June 2018

IEEE-SA Standards Board

Abstract: Directions and requirements are provided for the conversion of qualified power switchgear equipment. Examples such as low-voltage power circuit breakers; high-voltage outdoor, and medium-voltage indoor drawout power circuit breakers; medium-voltage fused contactors; medium-voltage ground and test devices; medium-voltage fused load interrupter switches; and metal-enclosed switchgear are covered in this standard. Existing design standards are referenced with appropriate guidance on design testing necessary to design-verify the conversions. Reconditioning, which concerns the maintenance of existing equipment without alteration, is not covered.

Keywords: circuit breakers, compartment adapter, conversion, definite-purpose switching device, IEEE C37.59™, interrupters, modular assembly, power switchgear equipment, qualified design, remote racking device, retrofill, retrofit, switchgear, vacuum

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2018 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 17 August 2018. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code, NEC, NFPA 70, and NFPA 70E are registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association.

PDF: ISBN 978-1-5044-5009-6 STD23181
Print: ISBN 978-1-5044-5010-2 STDPD23181

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. A current IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Xplore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the Conversion of Power Switchgear Equipment Working Group had the following membership:

Dean Sigmon, *Chair*
Doug Edwards, *Vice Chair*

Paul Barnhart	Lou Grahor	T. W. Olsen
Ted Burse	Paul Grein	Anthony Ricciuti
Stephen Cary	Michael Lafond	Richard Rohr
Robert Cohn	David Lemmerman	Tim Rohrer
Daniel Delfino	Albert Livshitz	Paul Sullivan
Tanner Esco	Jeffrey Mizener	Jey Thayalan
Keith Flowers	Charles A. Morse	Larry Yonce
	Darryl Moser	

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Ali AlAwazi	Lou Grahor	James O'Brien
Saleman Alibhay	Stephen Grier	T. W. Olsen
Thomas Barnes	Randall Groves	Lorraine Padden
Paul Barnhart	Ajit Gwal	Bansi Patel
W. J. (Bill) Bergman	John Harley	Christopher Petrola
Wallace Binder	Thomas Hawkins	Iulian Profir
Gustavo Brunello	Werner Hoelzl	Aaron Rexroad
Demetrio Bucaneg Jr.	Robert Hoerauf	Anthony Ricciuti
Ted Burse	Todd Irwin	Timothy Robirds
Eldridge Byron	Richard Jackson	Richard Rohr
Paul Cardinal	Laszlo Kadar	Tim Rohrer
Suresh Channarasappa	Uwe Kaltenborn	Rodrigo Ronchi
Nancy Chilton	John Kay	Thomas Rozek
Michael Chirico	Yuri Khersonsky	Ryandi Ryandi
Kurt Clemente	Hermann Koch	Daniel Sabin
Robert Cohn	Boris Kogan	Bartien Sayogo
Stephen Conrad	Jim Kulchisky	Robert Schuerger
Ray Davis	Mikhail Lagoda	Nikunj Shah
Stephen DeRoche	James Lagree	John Shullaw
Anil Dhawan	Chung-Yiu Lam	Michael Sigmon
Gary Donner	Raluca Lascu	Garett Sims
Edgar Dullni	Hua Liu	Veselin Skendzic
David Dunne	Albert Livshitz	Jeremy Smith
Douglas J. Edwards	Reginaldo Maniego	Jerry Smith
Donald Elliott	Jose Marrero	Gary Smullin
Ronald Esco	Hugo Marroquin	Paul Sullivan
Michael Flack	William McBride	C. Tailor
Sergio Flores	Jeffrey Mcelray	David Tepen
Keith Flowers	Nigel McQuin	Wayne Timm
Rabiz Foda	Steven Meiners	Namgay Tshering
Paul Found	C. Michael Miller	Marcelo Valdes
Brian Gerzeny	Charles Morse	Roger Verdolin
David Gilmer	Darryl Moser	John Vergis
Mietek Glinkowski	Dennis Neitzel	Michael Wactor
Jalal Gohari	George Nourse	Paul Wasacz
Edwin Goodwin	Michael Novev	Keith Waters

John Webb
Kenneth White
William Wilkie

Terry Woodyard
Dean Yager

Larry Yonce
Jian Yu
Matthew Zeedyk

When the IEEE-SA Standards Board approved this standard on 14 June 2018, it had the following membership:

Jean-Phillipe Faure, *Chair*
Gary Hoffman, *Vice Chair*
John D. Kulick, *Past Chair*
Konstantinos Karachalios, *Secretary*

Ted Burse
Guido R. Hiertz
Christel Hunter
Joseph L. Koepfinger*
Thomas Koshy
Hung Ling
Dong Liu

Xiaohui Liu
Kevin Lu
Daleep Mohla
Andrew Myles
Paul Nikolich
Ronald C. Petersen
Annette D. Reilly

Robby Robson
Dorothy Stanley
Mehmet Ulema
Phil Wennblom
Philip Winston
Howard Wolfman
Jingyi Zhou

*Member Emeritus

Introduction

This introduction is not part of IEEE Std C37.59-2018, IEEE Standard for Requirements for Conversion of Power Switchgear Equipment.

This edition of the standard continues to cover conversions of power switchgear equipment only, rather than complete power switchgear equipment replacement. A conversion of power switchgear equipment reuses some portion of the qualified design switchgear.

The technology and extent of conversions is a continually changing and expanding practice. This revised standard addresses clarifications needed on the required performance of a converted product such as those involved in low-voltage power circuit breaker control system replacements, medium-voltage (up to 7.2 kV) alternating current (ac)-fused contactors, as well as new information on conversions of low-voltage direct-current (dc) general-purpose circuit breakers. [Subclause 6.7](#) was amended to add medium-voltage compartment adaptor requirements using concepts based on low-voltage adaptor applications. New guidance has been added in [6.8](#) on energy storage systems installed in dc transit systems. [Subclause 6.9](#) adds new testing requirements for switchgear when viewing windows and ports are added.

Converted circuit breakers may or may not be interchangeable with existing non-converted circuit breakers. Where converted circuit breakers are not interchangeable with non-converted circuit breakers, it shall be so indicated in the converter's instruction book and the blocking/rejection interlock shall be changed. Clarification has been provided for interlocking where compartment adapters are used.

With personal safety at the forefront of all applications, the minimum design tests recommended and outlined in specific references are to be carried out as applicable on each differing design (or model) of a converted device. Reliance only on production tests with statements that the conversion has been "ANSI tested," unsubstantiated by formal documented design verification, can mislead users and may result in field failures. Production tests are not design tests. The basic and fundamental philosophy of this standard is that a converted product is a new design and shall be design verified to substantiate that it meets its nameplate ratings as well as applicable standards. A recommended design verification form is included. This revision of the standard includes the design verification form as a downloadable electronic document available at the IEEE Standards Association website.

The lack of design verification of some conversions was the reason for the creation of the original 1991 version of this document. Experience gained with use of the original document and the 1996, 2002, and 2007 revisions is incorporated into this revision of the standard.

Many forms of conversion exist, and this document provides the logic that should cover all power switchgear equipment conversions, with examples of current areas of conversion and testing. As additional types of switchgear products are converted, criteria for the new conversion products will be added in future revisions of this standard.

[Annex A](#), although not a normative part of this standard, is provided for guidance in the design verification of the converted power switchgear equipment. It provides additional guidance regarding conversion examples and the minimum testing required for design verifications. This revision adds new sections on dc overcurrent trip system conversions, test requirements for metal-enclosed switchgear conversions, test requirements for viewing windows and ports, additional information and requirements for compartment adapters, and updates in test requirements for medium-voltage ac fused contactors.

Examples of components that may be converted include but are not limited to the following:

- Circuit breakers
 - Frame
 - Insulation structures

- Contacts, supports, and primary disconnecting devices
- High-voltage arc-interrupting structures
- Low-voltage arc-interrupting structures
 - NOTE—Medium- and low-voltage arc-interrupting structure conversions include substitution of low-voltage (up to 600 V ac) and medium-voltage (up to 7.2 kV) ac-fused contactors in place of circuit breaker elements.¹
- Low-voltage direct-acting trip systems
- Drawout parts/interlocking and auxiliary functions
- Mechanism parts and control wiring
- Low- and high-voltage conversions using circuit-breaker compartment adapters
- Switchgear vertical sections
 - Drawout parts/interlocking and auxiliary functions
 - Frame
 - Bus, bus connections, and insulation
 - Instrumentation and control wiring
- Ground and test devices
- Definite-purpose switching devices
 - Low-voltage (600 V ac and below)
- AC fused contactors
 - Medium-voltage (7200 V ac and below)
- Metal-enclosed interrupter switchgear
 - Addition or substitution of power fuses

This standard is not intended to cover maintenance procedures when reconditioning power switchgear equipment in accordance with the manufacturer’s instruction manuals.

Although “conversion” is the preferred term, conversions may be categorized by numerous other names by the manufacturers of those conversions. [Clause 3](#) provides the preferred names for the various categories of conversions. Reflecting the changes in the marketplace since the first edition of this standard was issued, the term “retrofit” does not accurately describe the conversions now available as this standard is written.

The bibliography (see [Annex B](#)) is updated to provide list of documents with their reference dates. [Clause 2](#) and [Clause 5](#) include statements that require reference to the standards that were in effect at the time of the original equipment’s manufacture. The bibliography provides a list of dated standards associated with the types of equipment covered by this standard.

¹Notes in text, tables, and figures of a standard are given for information only and do not contain requirements needed to implement this standard.

Contents

1. Overview	11
1.1 General	11
1.2 Scope	12
1.3 Other conversions	12
1.4 Word usage	12
2. Normative references	12
3. Definitions	14
4. Service conditions	16
5. Ratings	16
6. Conversion and testing	16
6.1 General	16
6.2 Circuit breakers and related conversions	17
6.3 Switchgear vertical sections	27
6.4 Metal-enclosed interrupter switchgear conversions	28
6.5 Conversion of switchgear for arc-resistant performance	30
6.6 Modifications of arc-resistant switchgear	32
6.7 Conversions using a compartment adaptor	32
6.8 Conversions related to energy storage systems	34
6.9 Addition of inspection windows and ports to switchgear	34
7. Production testing	35
8. Nameplates and third party labels	35
8.1 Nameplates	35
8.2 Converted equipment door labels	36
8.3 Third-party labels	36
9. Manuals	37
10. Design verification form	37
Annex A (informative) Clarification of conversion processes	38
Annex B (informative) Bibliography	49

IEEE Standard for Requirements for Conversion of Power Switchgear Equipment

1. Overview

1.1 General

Current industry conversions involve low- and medium-voltage power circuit breakers used in metal-clad, and metal-enclosed switchgear (including interrupter switchgear), low- and medium-voltage fused contactors, switchgear vertical sections, power fuse addition or substitution in metal-enclosed interrupter switchgear, traction power energy storage systems integration, and certain ratings of other circuit breakers.

This standard cannot detail each test that is necessary to be carried out to qualify a conversion. The specific tests shall be selected by the converter considering exact changes made from the previously qualified design. The converter shall conduct thorough and formal design verification for the completed conversion, and the converter shall perform all additional tests determined to be necessary.

Example:

- A vital part of the circuit breaker conversion process is the electrical and mechanical coordination of the mechanism-operated cell (MOC) switches with the converted circuit breaker. New, sealed interrupter modular assemblies may have much less mechanism power than that of the circuit breakers they replace and may not have the ability to operate all installed MOC switches. Accordingly, this situation may necessitate substantial revision to or replacement of the MOC switches and their operating linkage in the existing vertical sections to maintain proper operation of the circuit breaker.

For any conversions performed on third-party certified (labeled, listed, or otherwise certified) equipment, or equipment requiring Nuclear Regulatory Commission conformance, that voids the label, listing, or certification of the equipment, it is necessary to reapply to the third party for continued certification of the equipment. For example, if an Underwriters Laboratories (UL)-listed switchgear assembly is converted to use a non-UL-listed circuit breaker, then the converted switchgear assembly shall be submitted to UL and approved to maintain the UL listing. Another example is if a low-voltage power circuit breaker is converted to change the direct-acting trip system, then the converted circuit breaker shall be submitted to UL to maintain the UL listing (see [8.3](#)).

A converter shall not convert a design that the converter knows to be defective without taking or verifying that appropriate actions were taken to correct the defect in any assembly being converted.