

ANSI/ASHRAE Standard 15-2001  
(Including ANSI/ASHRAE Addenda listed in Appendix J)



# ASHRAE<sup>®</sup> STANDARD

## Safety Standard for Refrigeration Systems

See Appendix J for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, and the American National Standards Institute.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines are given at the back of this document and may be obtained in electronic form from ASHRAE's Internet Home Page, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard and printed copies of a public review draft may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in U.S. and Canada).

©Copyright 2001 American Society of Heating,  
Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**AMERICAN SOCIETY OF HEATING,  
REFRIGERATING AND  
AIR-CONDITIONING ENGINEERS, INC.**

1791 Tullie Circle, NE • Atlanta, GA 30329

**ASHRAE Standard Project Committee 15**  
**Cognizant TCs: TC 10.1, Custom Engineered Refrigeration Systems,**  
**and TC 9.1, Large Building Air-Conditioning Systems**  
**Standards Project Committee Liaison: Dean Borges**

Jay A. Kohler, *Chair\**  
James M. Calm\*  
Dennis R. Dorman\*  
Daniel R. Kuespert\*  
Norman W. Panabaker\*  
Rudolph Stegman\*  
John I. Vucci\*

Thomas E. Watson\*  
George C. Briley  
James Hasbrouck  
William V. Richards  
Kenneth M. Schoonover  
Michael H. Tavares  
Gary W. Westermeyer

\*Denotes voting members.

**ASHRAE STANDARDS COMMITTEE 2000-2001**

Martha J. Hewett, Chair  
Nance C. Lovvorn, Vice-Chair  
Van D. Baxter  
Dean S. Borges  
Waller S. Clements  
Piotr A. Domanski  
Richard A. Evans  
John F. Hogan  
Ronald E. Jarnagin  
David E. Knebel  
Frederick H. Kohloss  
William J. Landman  
Rodney H. Lewis

Ross D. Montgomery  
Davor Novosel  
Joseph A. Pietsch  
James A. Ranfone  
Michael Tavares  
Steve A. Taylor  
James K. Vallort  
Thomas E. Watson  
Bruce A Wilcox  
J. Richard Wright  
Gerald C. Groff, *CO*  
William J. Buck, *ExO*

Claire B. Ramspeck, *Manager of Standards*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

# CONTENTS

## ANSI/ASHRAE Standard 15-2001, Safety Standard for Refrigeration Systems

SECTION	PAGE
Foreword .....	3
1. Purpose .....	4
2. Scope .....	4
3. Definitions .....	4
4. Occupancy Classification .....	6
5. Refrigerating System Classification .....	7
6. Refrigerant Classification .....	9
7. Restrictions on Refrigerant Use .....	9
8. Installation Restrictions .....	11
9. Design and Construction of Equipment and Systems .....	13
10. Operation and Testing .....	23
11. General Requirements .....	24
12. Precedence with Conflicting Requirements .....	25
13. Listed Equipment .....	25
Appendix A: Calculations of the Maximum Allowable Concentration ( $C_m$ ) of a Blend.....	26
Appendix B: Guidelines for Emergency Discharge of Refrigerants When Required by Local Codes.....	26
Appendix C: Refrigeration Classification Scheme .....	27
Appendix D: Informative References .....	27
Appendix E: Normative References.....	28
Appendix F: Method for Calculating Discharge Capacity of Positive Displacement Compressor Pressure-Relief Device .....	28
Appendix G: Table, <i>Paragraph Number Comparison of ASHRAE 15-1992 With ASHRAE 15-1994</i> .....	29
Appendix H: Allowable Equivalent Length of Discharge Piping (Normative) .....	30
Appendix I: Emergencies in Refrigerating Machinery Rooms .....	31
Appendix J: Addenda Description Information .....	32



(This foreword is not part of this standard but is included for information purposes only.)

## FOREWORD

ANSI/ASHRAE 15-2001 is the newest version of one of ASHRAE's oldest standards, now titled "Safety Standard for Refrigeration Systems." This version is a republication of ANSI/ASHRAE 15-1994, including addenda a, b, c, and d. The reader is referred to those addenda for changes that have been made since the original publication of ANSI/ASHRAE 15-1994. Among those changes were a new Title, which replaces the former Title, "Safety Code for Mechanical Refrigeration." The new Title is indicative of its broader application and inclusion of nonmechanical refrigeration systems, specifically absorption equipment.

This standard is directed toward the safety of persons and property on or near the premises where refrigeration facilities are located. It includes specifications for fabrication of tight systems but does not address the effects of refrigerant emissions on the environment. For information on the environmental effects of refrigerant emissions, see ASHRAE Guideline 3-1996, *Reducing Emission of Halogenated Refrigerants in Refrigeration and Air-Conditioning Equipment and Systems*.

While the user must be familiar with the entire document, the following major topic grouping allows quicker location of information. The subtopics included in these major groupings are:

- **GENERAL:** Purpose, Scope, Definitions, Occupancy Classification, Refrigerating System Classification, Refrigerant Classification, Precedence with Conflicting Requirements, Listed Equipment.
- **RESTRICTIONS:** Restrictions on Refrigerant Use, Installation Restrictions.
- **DESIGN AND CONSTRUCTION:** Materials, System Design Pressure, Refrigerant-Containing Pressure Vessels, Pressure Relief Protection, Setting of Pressure-Relief Devices, Marking of Pressure-Relief Devices and Fusible Plugs, Pressure Vessel Protection, Positive Displacement Compressor Protection, Pressure-Limiting Devices, Refrigerant Piping, Valves, Fittings and Related Parts, Components Other than Pressure Vessels and Piping, Service Provisions, Fabrication, Factory Tests, and Nameplate.
- **OPERATION AND TESTING:** Field Tests, General Requirements.

In the text of the standard, superscripts indicate the references included in Appendices D and E.

As discussed above, the user is referred to addenda of ANSI/ASHRAE 15-1994 for changes that have been made since the original publication of ANSI/ASHRAE 15-1994. Some of those changes are:

- Section 2—The Scope was revised and some portions were moved to new sections (Sections 12 and 13). The exemption for systems with water as the refrigerant was removed.

- Section 3—Several definitions were added, deleted, or revised.
- Section 6—The Refrigerant Classification Scheme is now in Appendix C.
- Section 7—This section was substantially revised including the rewriting of the former "Rules" section in a form that will make it easier to use.
- Section 8—Several requirements were revised or deleted. Ventilation requirements were revised.
- Section 9—Additional refrigerants were included in the table of relief valve "f" factors. Relief valve discharge piping requirements were revised and incorporated into Appendix H. The factory testing procedure was revised.
- Section 10—Field test procedures were revised.
- Section 11—Requirements for SCBA equipment were deleted.

The hazards of refrigerants are related to their physical and chemical characteristics as well as to the pressures and temperatures occurring in refrigerating and air-conditioning systems. Personal injury and property damage from inadequate precautions may occur from the following:

- Rupture of a part or an explosion with risk from flying debris or from structural collapse.
- Release of refrigerant from a fracture, due to a leaking seal, or from incorrect operation.
- Fire resulting from or intensified by burning or deflagration of escaping refrigerant or lubricant.

Personal injury from accidental release of refrigerants may also occur from the following:

- Suffocation from heavier-than-air refrigerants in inadequate ventilated spaces.
- Narcotic and cardiac sensitization effects.
- Toxic effects of vapor or the decomposition products due to vapor contact with flames or hot surfaces.
- Corrosive attack on the eyes, skin, or other tissue.
- Freezing of tissue by contact with liquid.

While ANSI/ASHRAE 15-1994 is written as a self-standing document, it includes references to other standards. One of those standards is ANSI/ASHRAE 34-2001, which prescribes the Refrigerant Classification System and Table 1 quantities, which are important to the use of this standard. Changes to ANSI/ASHRAE 15 are closely coordinated with those to ANSI/ASHRAE 34.

Table 1 shows the amount of refrigerant in a given space that, when exceeded, requires a machinery room. When a refrigerant is not classified in ASHRAE 34-2001 or addenda or shown in Table 1, it is the responsibility of the owner of a refrigerating system to make this judgement. For blends, Appendix A is offered to aid in determining allowable concentrations.

Care should be taken to avoid stagnant pockets of refrigerant vapors by proper location of ventilation inlet and exhaust openings (all commonly used refrigerants except

ammonia (R-717) and water (R-718) are heavier than air). All machinery rooms are required to have detectors that will activate on alarm and mechanical ventilation at a value not greater than the corresponding TLV-TWV (or toxicity measure consistent therewith). Informative Appendix I provides guidance on integrating the requirements of this standard with occupational health and safety programs.

A short publishing history of this code traces the origins of these safety provisions. In 1919, the American Society of Refrigerating Engineers (ASRE) proposed a Tentative Code for the Regulation of Refrigerating Machines and Refrigerants. Over the next 11 years, representatives from the American Gas Association, American Institute of Electrical Engineers, American Institute of Refrigeration, American Chemical Society, American Society of Heating and Ventilation Engineers, American Society of Mechanical Engineers, National Electrical Refrigerator Manufacturers Association, National Fire Protection Association, and ASRE met to expand the code to address all of the issues raised on the use of refrigeration equipment. The first Safety Code for Mechanical Refrigeration, recognized as American Standard B9 in October 1930, appeared in the first edition, 1932-1933, of the ASRE Refrigerating Handbook and Catalog. ASRE revisions designated ASA B9 appeared in 1933 and 1939. ASRE revisions designated ASA B9.1 appeared in 1950, 1953, and 1958. After the formation of ASHRAE, editions appeared as ASA B9.1-1964, ANSI B9.1-1971, ANSI/ASHRAE 15-1978, ANSI/ASHRAE 15-1989, ANSI/ASHRAE 15-1992, and ANSI/ASHRAE 15-1994.

## 1. PURPOSE

This standard specifies safe design, construction, installation, and operation of refrigeration systems.

## 2. SCOPE

**2.1** This standard establishes safeguards for life, limb, health, and property and prescribes safety requirements.

**2.2** This standard applies

- (a) to the design, construction, test, installation, operation, and inspection of mechanical and absorption refrigeration systems including heat pump systems used in stationary applications,
- (b) to modifications including replacement of parts or components if they are not identical in function and capacity, and
- (c) to substitutions of refrigerant having a different designation.

## 3. DEFINITIONS

**approved:** acceptable to the authority having jurisdiction.

**approved, nationally recognized laboratory:** one that is acceptable to the authority having jurisdiction, which provides uniform testing and examination procedures and standards for meeting design, manufacturing, and factory testing

requirements of this code; is organized, equipped, and qualified for testing; and has a follow-up inspection service of the current production of the listed products.

**back pressure:** the static pressure existing at the outlet of an operating pressure-relief device due to pressure in the discharge line.

**balanced relief valve:** a pressure-relief valve that incorporates means of minimizing the effect of back pressure on the operational characteristics of the valve (opening pressure, closing pressure, and relieving capacity).

**blends:** refrigerants consisting of mixtures of two or more different chemical compounds, often used individually as refrigerants for other applications.

**brazed joint:** a gas-tight joint obtained by the joining of metal parts with metallic mixtures or alloys that melt at temperatures above 1000°F (537.7°C) but less than the melting temperatures of the joined parts.

**companion or block valves:** pairs of mating stop valves that allow sections of a system to be joined before opening these valves or separated after closing them.

**compressor:** a machine used to compress refrigerant vapor.

**compressor unit:** a compressor with its prime mover and accessories.

**condenser:** that part of the refrigerating system where refrigerant is liquefied by the removal of heat.

**condenser coil:** a condenser constructed of pipe or tubing, not enclosed in a pressure vessel.

**condensing unit:** a combination of one or more power-driven compressors, condensers, liquid receivers (when required), and regularly furnished accessories.

**containers, refrigerant:** a cylinder for the transportation of refrigerant.

**corridor:** an enclosed passageway that limits travel to a single path.

**critical pressure, critical temperature, and critical volume:** a point on the saturation curve where the refrigerant liquid and vapor have identical volume, density, and enthalpy, and there is no latent heat.

**design pressure:** the maximum pressure for which a specific part of a refrigerating system is designed.

**dual pressure-relief device:** two pressure-relief devices mounted on a three-way valve that allows one device to remain active while the other is isolated.

**duct:** a tube or conduit used to convey or encase: (a) *air duct* is a tube or conduit used to convey air (air passages in self-contained systems are not air ducts); (b) *pipe duct* is a tube or conduit used to encase pipe or tubing.

**evaporator:** that part of the refrigerating system designed to vaporize liquid refrigerant to produce refrigeration.