


β

# Rules for Construction of Nuclear Facility Components











AN INTERNATIONAL CODE

# 2013 ASME Boiler & Pressure Vessel Code

2013 Edition July 1, 2013

# RULES FOR CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS

### **Division 1 - Subsection NF**

## **Supports**

ASME Boiler and Pressure Vessel Committee on Nuclear Power



Date of Issuance: July 1, 2013

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the publicat-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes in this document are part of this American National Standard.



ASME collective membership mark



Certification Mark

The above ASME symbol is registered in the U.S. Patent Office.

"ASME" is the trademark of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934 Printed in the United States of America

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2013.

The American Society of Mechanical Engineers Two Park Avenue, New York, NY 10016-5990

Copyright © 2013 by THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS All rights reserved

### **TABLE OF CONTENTS**

| List of Sections              |   | VII  |
|-------------------------------|---|------|
|                               |   | 7    |
| •                             | Jse of the Certification Mark and Code Authorization in Advertising                   | xi   |
| Statement of Policy on the U  | Jse of ASME Marking to Identify Manufactured Items                                    | xi   |
| Submittal of Technical Inqui  | ries to the Boiler and Pressure Vessel Standards Committees                           | xii  |
| Personnel                     |   | XV   |
| Organization of Section III . |   | XXX  |
| Summary of Changes            | х   | xxii |
|                               |   | XXXV |
|                               |   | XXXV |
| Article NF-1000               | Introduction  | _    |
| NF-1100                       | Scope and General Requirements  | 1    |
| NF-1110                       | Aspects of Construction Covered by These Rules  | 1    |
| NF-1120                       | Rules for Supports and Their Classification   | 1    |
| NF-1130                       | Boundaries of Jurisdiction  | 2    |
| NF-1200                       | Types of Supports and Attachments   | 2    |
| NF-1210                       | Types of Supports   | 2    |
| NF-1230                       | Welding Between Types of Supports   | 8    |
| NF-1240                       | Attachments   | 8    |
| Article NF-2000               | Material  | ç    |
| NF-2100                       | General Requirements for Material   | ç    |
| NF-2110                       | Scope of Principal Terms Employed   | ç    |
| NF-2120                       | Support Material  | ç    |
| NF-2130                       | Certification of Material   | 10   |
| NF-2140                       | Welding Material  | 11   |
| NF-2150                       | Material Identification   | 11   |
| NF-2160                       | Deterioration of Material in Service  | 11   |
| NF-2170                       | Heat Treatment to Enhance Impact Properties   | 11   |
| NF-2180                       | Procedures for Heat Treatment of Material   | 11   |
| NF-2200                       | Material Test Coupons and Specimens for Ferritic Steel Material                       | 11   |
| NF-2210                       | Heat Treatment Requirements   | 11   |
| NF-2220                       | Procedure for Obtaining Test Coupons and Specimens for Quenched and Tempered Material | 12   |
| NF-2300                       | Fracture Toughness Requirements for Material  | 13   |
| NF-2310                       | Material to Be Impact Tested  | 13   |
| NF-2320                       | Impact Test Procedures  | 14   |
| NF-2330                       | Test Requirements and Acceptance Standards  | 16   |
| NF-2340                       | Number of Impact Tests Required   | 17   |
| NF-2350                       | Retests   | 18   |
| NF-2360                       | Calibration of Instruments and Equipment  | 21   |
| NF-2400                       | Welding Material  | 21   |
| NF-2410                       | General Requirements  | 21   |
| NF-2420                       | Required Tests  | 21   |
| NF-2430                       | Weld Metal Tests  | 22   |
| NF-2440                       | Storage and Handling of Welding Material  | 25   |
| NF-2500                       | Examination and Repair of Material  | 25   |
| NF-2510                       | Examination and Repair of Material Other Than Bolting                                 | 25   |
| NF 2520                       | Programmed Examination and Accordance Standards for Class 1 Springs                   | 20   |

| NF-2530            | Required Examination and Acceptance Standards for Coiled Wire Rope          |
|--------------------|---|
| NB 2522            | Used As a Spring  |
| NF-2580            | Examination of Bolting Material and Rods                                    |
| NF-2600            | Material Manufacturer's Quality System Programs                             |
| NF-2610            | Documentation and Maintenance of Quality System Programs                    |
| Article NF-3000    | <b>Design</b>   |
| NF-3100            | General Design Requirements   |
| NF-3110            | Loading Criteria  |
| NF-3120            | Design Considerations   |
| NF-3130            | General Design Requirements   |
| NF-3140            | General Design Procedures   |
| NF-3200            | Design Rules for Plate- and Shell-Type Supports                             |
| NF-3210            | General Requirements  |
| NF-3220            | Design by Analysis for Class 1  |
| NF-3250            | Design by Analysis for Class 2 and MC                                       |
| NF-3260            | Design by Analysis for Class 3  |
| NF-3270            | Experimental Stress Analysis  |
| NF-3280            | Design by Load Rating   |
| NF-3300            | Design Rules for Linear-Type Supports                                       |
| NF-3310            | General Requirements  |
| NF-3320            | Design by Linear Elastic Analysis for Class 1                               |
| NF-3330            | High Cycle Fatigue Design for Class 1                                       |
| NF-3340            | Limit Analysis Design for Class 1   |
| NF-3350            |   |
|                    |   |
| NF-3360<br>NF-3370 |   |
|                    | ı   |
| NF-3380            | Design by Load Rating   |
| NF-3400<br>NF-3410 | 8   |
| NF-3410<br>NF-3420 |   |
|                    | 8 4 7   |
| NF-3450            | Design by Analysis for Class 2  |
| NF-3460            | Design by Analysis for Class 3  |
| NF-3470            | Design by Experimental Stress Analysis                                      |
| NF-3480            | Procedure for Load Rating   |
| NF-3500            | Design Rules for Component Supports   |
| NF-3510            | General Requirements  |
| NF-3520            | Design by Analysis for Class 1  |
| NF-3550            | Design by Analysis for Class 2, 3, and MC                                   |
| NF-3570            | Experimental Stress Analysis  |
| NF-3580            | Design by Load Rating   |
| NF-3600            | Design Rules for Piping Supports  |
| NF-3610            | General Requirements  |
| NF-3620            | Design by Analysis for Class 1  |
| NF-3650            | Design by Analysis for Class 2 and 3  |
| NF-3670            | Experimental Stress Analysis83  |
| NF-3680            | Design by Load Rating83   |
| Article NF-4000    | Fabrication and Installation84  |
| NF-4100            | General Requirements 84   |
| NF-4110            | Introduction 84   |
| NF-4120            | Certification of Materials and Fabrication by Support Certificate Holder 84 |
| NF-4130            | Repair of Material84  |
| NF-4200            | Forming, Fitting, and Aligning85  |
| NF-4210            | Cutting, Forming, and Bending85   |
| NF-4220            | Support Tolerances  |
| NF-4230            | Fitting and Aligning  |
|                    |   |

| NF-4240                    | Requirements for Welded Joints   | 87  |
|----------------------------|--|-----|
| NF-4300                    | Welding Qualifications   | 87  |
| NF-4310                    | General Requirements   | 87  |
| NF-4320                    | Welding Qualifications and Records                                       | 87  |
| NF-4330                    | General Requirements for Welding Procedure Qualification Tests           | 88  |
| NF-4400                    | Rules Governing Making and Repairing Welds                               | 90  |
| NF-4410                    | Precautions to Be Taken Before Welding                                   | 90  |
| NF-4420                    | Rules for Making Welded Joints   | 90  |
| NF-4430                    | Welding of Attachments   | 91  |
| NF-4440                    | Special Requirements for Welding   | 91  |
| NF-4450                    | Repair of Weld Metal Defects   | 91  |
| NF-4500                    | Brazing  | 93  |
| NF-4510                    | Rules for Brazing  | 93  |
| NF-4600                    | Heat Treatment   | 94  |
| NF-4610                    | Welding Preheat and Interpass Requirements                               | 94  |
| NF-4620                    | Postweld Heat Treatment  | 94  |
| NF-4660                    | Heat Treatment of Electroslag Welds                                      | 99  |
| NF-4700                    | Requirements for Bolted Construction                                     | 99  |
| NF-4710                    | Bolting and Threading  | 99  |
| NF-4720                    | Bolting  | 99  |
| Anti-la NE E000            | -  | 100 |
| Article NF-5000            | Examination  | 102 |
| NF-5100                    | General Requirements for Examination                                     | 102 |
| NF-5110                    | Procedures, Qualifications, and Evaluations                              | 102 |
| NF-5200                    | Required Examination of Welds  | 102 |
| NF-5210                    | Examination of Class 1 Support Welds                                     | 102 |
| NF-5220                    | Examination of Class 2 and MC Support Welds                              | 103 |
| NF-5230                    | Examination of Class 3 Support Welds                                     | 103 |
| NF-5240                    | Inertia and Continuous Drive Friction Welds                              | 103 |
| NF-5300                    | Acceptance Standards   | 103 |
| NF-5320                    | Radiographic Acceptance Standards  | 103 |
| NF-5330                    | Ultrasonic Acceptance Standards  | 104 |
| NF-5340                    | Magnetic Particle Acceptance Standards                                   | 104 |
| NF-5350                    | Liquid Penetrant Acceptance Standards                                    | 104 |
| NF-5360                    | Visual Acceptance Standards  | 105 |
| NF-5500                    | Qualifications and Certification of Nondestructive Examination Personnel | 105 |
| NF-5510                    | General Requirements   | 105 |
| NF-5520                    | Personnel Qualification, Certification, and Verification                 | 105 |
| NF-5530                    | Records  | 106 |
| Article NF-8000            | Certificates of Authorization and Certification Documents                | 107 |
| NF-8100                    | General Requirements   | 107 |
| Mandatory Appendix NF-I    |  | 108 |
| Mandatory Appendix NF-II   | Design of Single Angle Members   | 109 |
| Mandatory Appendix NF-III  | Energy Absorbing Support Material  | 116 |
| Nonmandatory Appendix NF-A | Structural Bolt Preloading   | 120 |
| Nonmandatory Appendix NF-B | Design Allowable Stresses for Plate and Shell and Linear Type Sup-       |     |
|                            | ports  | 124 |
| Nonmandatory Appendix NF-C | Design Basis for Linear-Type Supports                                    | 131 |
| Nonmandatory Appendix NF-D | Tolerances   | 137 |
| Nonmandatory Appendix NF-E | Dampers, Energy Absorbers, and Snubbers                                  | 143 |

#### **FIGURES** NF-1132-1 Typical Examples of Jurisdictional Boundaries Between Piping Supports and the Building Structure ..... 3 NF-1132-2 Typical Example of Jurisdictional Boundary Between Component Support and the Building Structure ..... 6 NF-1214-1 Typical Standard Support Units ..... 7 Impact Test Exemption Curves for Materials for Class 2, 3, and MC Supports ...... NF-2311(b)-1 15 Required C<sub>v</sub> Energy Values for Class 2 and MC Support Material Other Than Bolting ... 19 NF-2331(a)-1 Required C<sub>v</sub> Energy Values for Class 3 support Material Other Than Bolting ...... 20 NF-2331(a)-2 Delta Ferrite Content ..... NF-2433.1-1 25 NF-3226.1-1 Permissible Welded Joints for Class 1 Plate- and Shell-Type Supports ...... 35 NF-3226.1(a)-1 36 NF-3226.1(a)-2 Butt Welding of Plates of Unequal Thickness ..... 37 NF-3256.1-1 Permissible Welded Joints for Class 2, 3, and MC Plate- and Shell-Type Supports ..... 39 Typical Friction-Type Connections Using High Strength Bolts ..... NF-3324.1(a)(1) 61 NF-3332.3-1 Illustrative Examples ..... 71 Additional Permissible Welded Joints for Class 1 Standard Supports ..... NF-3426.1-1 79 NF-3626(a)-1 Additional Permissible Welded Joints for Class 1 Piping Supports ...... 82 NF-4427-1 Fillet Weld Dimensions 92 NF-4441-1 Weld Joint Producing Through-Thickness Loading ..... 93 NF-II-3510 Equal Leg Single Angle Limits for $F_b = 0.66S_y$ ..... 113 ..... NF-A-1311 121 Effective Length Factor for Various End Conditions ..... NF-B-2400-1 126 Alignment Chart for Effective Length of Columns in Continuous Frames ...... 127 NF-B-2400-2 **TABLES** 10 NF-2121(a)-1 Material Tables Required for Supports ...... Exemptions From Impact Testing Under NF-2311(b)(9) and NF-2311(b)(10) for Mate-NF-2311(b)-1 rial Thickness to $2\frac{1}{2}$ in. (64 mm), Inclusive ...... 14 Required C<sub>v</sub> Lateral Expansion Values for Class 1 Support Material Other Than Bolting NF-2331(a)-1 17 NF-2331(a)-2 Required C<sub>v</sub> Lateral Expansion Values for Class 2 And MC Support Material Other Than Bolting ..... 17 NF-2331(a)-3 Required C<sub>v</sub> Lateral Expansion Values for Class 3 Support Material Other Than Bolting 17 NF-2331(a)-4 Required C<sub>v</sub> Energy Values for Class 1 Support Material Other Than Bolting ....... 18 NF-2333-1 Required C<sub>v</sub> Values for Bolting Material ..... 21 NF-2432.1-1 Sampling of Welding Materials for Chemical Analysis ..... 24 Welding Material Chemical Analysis ..... NF-2432.2(a)-1 24 Reference Paragraphs for Procedures for Design of Component Supports, Piping Sup-NF-3131(a)-1 ports, and Standard Supports ..... 30 NF-3221.2-1 Elastic Analysis Stress Categories and Stress Limit Factors for Class 1 Plate- And Shell-Type Supports Designed by Analysis ..... 32 NF-3225.2-1 Stress Limit Factors for Class 1, 2, 3, and MC Bolt Design by Analysis ..... 34 NF-3251.2-1 Elastic Analysis Stress Categories and Stress Limit Factors for Class 2, 3, and MC Plate-And Shell-Type Supports Designed by Analysis ..... 38 NF-3312.1(b)-1 Elastic Analysis Stress Categories and Stress Limit Factors for Class 1, 2, 3, and MC Linear-Type Supports Designed by Analysis ..... 43 NF-3322.2(e)(2)-1 Limiting Proportions for Channels and Tees ..... 52 NF-3324.5(a)-1 Allowable Stress Limits for Class 1 Linear-Type Support Welds ...... 63 Effective Slip Coefficient Versus Surface Condition ...... NF-3324.6(a)(4)-1 66 Minimum Edge Distances ..... NF-3324.6(b)(1)-1 66 NF-3332.2-1 Classification of Loading Conditions ..... 67 Stress Categories ..... NF-3332.3-1 68 NF-3332.4-1 Allowable Stress Ranges ..... 73 NF-3611-1 Suggested Piping Support Spacing ...... 81 NF-4232-1 Maximum Allowable Offset in Final Butt Welded Joints ..... 86

| NF-4622.1-1    | Mandatory Requirements for Postweld Heat Treatment (PWHT) of Welds   | 95  |
|----------------|--|-----|
| NF-4622.4(c)-1 |  | 96  |
| NF-4622.7(b)-1 | Exemptions to Mandatory PWHT   | 97  |
| NF-4721(a)-1   | Bolt Hole Sizes  | 99  |
| NF-4721(b)-1   | Tolerances on Oversized Holes  | 100 |
| NF-II-3532-1   | B <sub>w</sub> Values for Angles                                     | 114 |
| NF-B-4000      | Factors of Safety for a Material With a Low Value of $S_u/S_v$ Ratio | 129 |
| NF-C-4000      | Design Basis for Linear-Type Supports                                | 135 |
| NF-D-1320-1    | Clamp Tolerances   | 138 |
| NF-D-1330-1    | Local Installation Tolerances for Supports                           | 139 |
|                |  |     |
| ENDNOTES       |  | 145 |

#### **LIST OF SECTIONS**

#### SECTIONS

**(13)** 

- I Rules for Construction of Power Boilers
- II Materials
  - Part A Ferrous Material Specifications
  - Part B Nonferrous Material Specifications
  - Part C Specifications for Welding Rods, Electrodes, and Filler Metals
  - Part D Properties (Customary)
  - Part D Properties (Metric)
- III Rules for Construction of Nuclear Facility Components
  - Subsection NCA General Requirements for Division 1 and Division 2
  - Appendices
  - Division 1
    - Subsection NB Class 1 Components
    - Subsection NC Class 2 Components
    - Subsection ND Class 3 Components
    - Subsection NE Class MC Components
    - Subsection NF Supports
    - Subsection NG Core Support Structures
    - Subsection NH Class 1 Components in Elevated Temperature Service
  - Division 2 Code for Concrete Containments
  - Division 3 Containments for Transportation and Storage of Spent Nuclear Fuel and High Level Radioactive Material and Waste
  - Division 5 High Temperature Reactors
- IV Rules for Construction of Heating Boilers
- V Nondestructive Examination
- VI Recommended Rules for the Care and Operation of Heating Boilers
- VII Recommended Guidelines for the Care of Power Boilers
- VIII Rules for Construction of Pressure Vessels
  - Division 1
  - Division 2 Alternative Rules
  - Division 3 Alternative Rules for Construction of High Pressure Vessels
- IX Welding and Brazing Qualifications
- X Fiber-Reinforced Plastic Pressure Vessels
- XI Rules for Inservice Inspection of Nuclear Power Plant Components
- XII Rules for Construction and Continued Service of Transport Tanks

#### INTERPRETATIONS

ASME issues written replies to inquiries concerning interpretation of technical aspects of the Code. Interpretations of the Code are posted in January and July at http://cstools.asme.org/interpretations.cfm. Any Interpretations issued during the previous two calendar years are included with the publication of the applicable Section of the Code. Interpretations of Section III, Divisions 1 and 2 and Section III Appendices are included with Subsection NCA.

#### **CODE CASES**

The Boiler and Pressure Vessel Code committees meet regularly to consider proposed additions and revisions to the Code and to formulate Cases to clarify the intent of existing requirements or provide, when the need is urgent, rules for materials or constructions not covered by existing Code rules. Those Cases that have been adopted will appear in the appropriate 2013 Code Cases book: "Boilers and Pressure Vessels" or "Nuclear Components." Supplements will be sent automatically to the purchasers of the Code Cases books up to the publication of the 2015 Code.

#### (13) FOREWORD

(This Foreword is provided as an aid to the user and is not part of the rules of this Code.)

In 1911, The American Society of Mechanical Engineers established the Boiler and Pressure Vessel Committee to formulate standard rules for the construction of steam boilers and other pressure vessels. In 2009, the Boiler and Pressure Vessel Committee was superseded by the following committees:

- (a) Committee on Power Boilers (I)
- (b) Committee on Materials (II)
- (c) Committee on Construction of Nuclear Facility Components (III)
- (d) Committee on Heating Boilers (IV)
- (e) Committee on Nondestructive Examination (V)
- (f) Committee on Pressure Vessels (VIII)
- (g) Committee on Welding and Brazing (IX)
- (h) Committee on Fiber-Reinforced Plastic Pressure Vessels (X)
- (i) Committee on Nuclear Inservice Inspection (XI)
- (j) Committee on Transport Tanks (XII)

Where reference is made to "the Committee" in this Foreword, each of these committees is included individually and collectively.

The Committee's function is to establish rules of safety relating only to pressure integrity, which govern the construction\* of boilers, pressure vessels, transport tanks, and nuclear components, and the inservice inspection of nuclear components and transport tanks. The Committee also interprets these rules when questions arise regarding their intent. This Code does not address other safety issues relating to the construction of boilers, pressure vessels, transport tanks, or nuclear components, or the inservice inspection of nuclear components or transport tanks. Users of the Code should refer to the pertinent codes, standards, laws, regulations, or other relevant documents for safety issues other than those relating to pressure integrity. Except for Sections XI and XII, and with a few other exceptions, the rules do not, of practical necessity, reflect the likelihood and consequences of deterioration in service related to specific service fluids or external operating environments. In formulating the rules, the Committee considers the needs of users, manufacturers, and inspectors of pressure vessels. The objective of the rules is to afford reasonably certain protection of life and property, and to provide a margin for deterioration in service to give a reasonably long, safe period of usefulness. Advancements in design and materials and evidence of experience have been recognized.

This Code contains mandatory requirements, specific prohibitions, and nonmandatory guidance for construction activities and inservice inspection and testing activities. The Code does not address all aspects of these activities and those aspects that are not specifically addressed should not be considered prohibited. The Code is not a handbook and cannot replace education, experience, and the use of engineering judgment. The phrase *engineering judgment* refers to technical judgments made by knowledgeable engineers experienced in the application of the Code. Engineering judgments must be consistent with Code philosophy, and such judgments must never be used to overrule mandatory requirements or specific prohibitions of the Code.

The Committee recognizes that tools and techniques used for design and analysis change as technology progresses and expects engineers to use good judgment in the application of these tools. The designer is responsible for complying with Code rules and demonstrating compliance with Code equations when such equations are mandatory. The Code neither requires nor prohibits the use of computers for the design or analysis of components constructed to the requirements of the Code. However, designers and engineers using computer programs for design or analysis are cautioned that they are responsible for all technical assumptions inherent in the programs they use and the application of these programs to their design.

<sup>\*</sup> Construction, as used in this Foreword, is an all-inclusive term comprising materials, design, fabrication, examination, inspection, testing, certification, and pressure relief.

The rules established by the Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way the manufacturer's freedom to choose any method of design or any form of construction that conforms to the Code rules.

The Committee meets regularly to consider revisions of the rules, new rules as dictated by technological development, Code Cases, and requests for interpretations. Only the Committee has the authority to provide official interpretations of this Code. Requests for revisions, new rules, Code Cases, or interpretations shall be addressed to the Secretary in writing and shall give full particulars in order to receive consideration and action (see Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees). Proposed revisions to the Code resulting from inquiries will be presented to the Committee for appropriate action. The action of the Committee becomes effective only after confirmation by ballot of the Committee and approval by ASME. Proposed revisions to the Code approved by the Committee are submitted to the American National Standards Institute (ANSI) and published at http://cstools.asme.org/csconnect/public/index.cfm?PublicReview=Revisions to invite comments from all interested persons. After public review and final approval by ASME, revisions are published at regular intervals in Editions of the Code.

The Committee does not rule on whether a component shall or shall not be constructed to the provisions of the Code. The scope of each Section has been established to identify the components and parameters considered by the Committee in formulating the Code rules.

Questions or issues regarding compliance of a specific component with the Code rules are to be directed to the ASME Certificate Holder (Manufacturer). Inquiries concerning the interpretation of the Code are to be directed to the Committee. ASME is to be notified should questions arise concerning improper use of an ASME Certification Mark.

When required by context in this Section, the singular shall be interpreted as the plural, and vice versa, and the feminine, masculine, or neuter gender shall be treated as such other gender as appropriate.

# STATEMENT OF POLICY ON THE USE OF THE CERTIFICATION MARK AND CODE AUTHORIZATION IN ADVERTISING

ASME has established procedures to authorize qualified organizations to perform various activities in accordance with the requirements of the ASME Boiler and Pressure Vessel Code. It is the aim of the Society to provide recognition of organizations so authorized. An organization holding authorization to perform various activities in accordance with the requirements of the Code may state this capability in its advertising literature.

Organizations that are authorized to use the Certification Mark for marking items or constructions that have been constructed and inspected in compliance with the ASME Boiler and Pressure Vessel Code are issued Certificates of Authorization. It is the aim of the Society to maintain the standing of the Certification Mark for the benefit of the users, the enforcement jurisdictions, and the holders of the Certification Mark who comply with all requirements.

Based on these objectives, the following policy has been established on the usage in advertising of facsimiles of the Certification Mark, Certificates of Authorization, and reference to Code construction. The American Society of Mechanical Engineers does not "approve," "certify," "rate," or "endorse" any item, construction, or activity and there shall be no statements or implications that might so indicate. An organization holding the Certification Mark and/or a Certificate of Authorization may state in advertising literature that items, constructions, or activities "are built (produced or performed) or activities conducted in accordance with the requirements of the ASME Boiler and Pressure Vessel Code," or "meet the requirements of the ASME Boiler and Pressure Vessel Code." An ASME corporate logo shall not be used by any organization other than ASME.

The Certification Mark shall be used only for stamping and nameplates as specifically provided in the Code. However, facsimiles may be used for the purpose of fostering the use of such construction. Such usage may be by an association or a society, or by a holder of the Certification Mark who may also use the facsimile in advertising to show that clearly specified items will carry the Certification Mark. General usage is permitted only when all of a manufacturer's items are constructed under the rules.

# STATEMENT OF POLICY ON THE USE OF ASME MARKING TO IDENTIFY MANUFACTURED ITEMS

The ASME Boiler and Pressure Vessel Code provides rules for the construction of boilers, pressure vessels, and nuclear components. This includes requirements for materials, design, fabrication, examination, inspection, and stamping. Items constructed in accordance with all of the applicable rules of the Code are identified with the official Certification Mark described in the governing Section of the Code.

Markings such as "ASME," "ASME Standard," or any other marking including "ASME" or the Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code.

Items shall not be described on ASME Data Report Forms nor on similar forms referring to ASME that tend to imply that all Code requirements have been met when, in fact, they have not been. Data Report Forms covering items not fully complying with ASME requirements should not refer to ASME or they should clearly identify all exceptions to the ASME requirements.

# SUBMITTAL OF TECHNICAL INQUIRIES TO THE BOILER AND PRESSURE VESSEL STANDARDS COMMITTEES

#### 1 INTRODUCTION

- (a) The following information provides guidance to Code users for submitting technical inquiries to the committees. See Guideline on the Approval of New Materials Under the ASME Boiler and Pressure Vessel Code in Section II, Parts C and D for additional requirements for requests involving adding new materials to the Code. Technical inquiries include requests for revisions or additions to the Code rules, requests for Code Cases, and requests for Code Interpretations, as described below.
- (1) Code Revisions. Code revisions are considered to accommodate technological developments, address administrative requirements, incorporate Code Cases, or to clarify Code intent.
- (2) Code Cases. Code Cases represent alternatives or additions to existing Code rules. Code Cases are written as a question and reply, and are usually intended to be incorporated into the Code at a later date. When used, Code Cases prescribe mandatory requirements in the same sense as the text of the Code. However, users are cautioned that not all jurisdictions or owners automatically accept Code Cases. The most common applications for Code Cases are:
  - (-a) to permit early implementation of an approved Code revision based on an urgent need
  - (-b) to permit the use of a new material for Code construction
  - (-c) to gain experience with new materials or alternative rules prior to incorporation directly into the Code
- (3) Code Interpretations. Code Interpretations provide clarification of the meaning of existing rules in the Code, and are also presented in question and reply format. Interpretations do not introduce new requirements. In cases where existing Code text does not fully convey the meaning that was intended, and revision of the rules is required to support an interpretation, an Intent Interpretation will be issued and the Code will be revised.
- (b) The Code rules, Code Cases, and Code Interpretations established by the committees are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code rules.
- (c) Inquiries that do not comply with these provisions or that do not provide sufficient information for a committee's full understanding may result in the request being returned to the inquirer with no action.

#### 2 INQUIRY FORMAT

Submittals to a committee shall include:

- (a) Purpose. Specify one of the following:
  - (1) revision of present Code rules
  - (2) new or additional Code rules
  - (3) Code Case
  - (4) Code Interpretation
- (b) Background. Provide the information needed for the committee's understanding of the inquiry, being sure to include reference to the applicable Code Section, Division, Edition, Addenda (if applicable), paragraphs, figures, and tables. Preferably, provide a copy of the specific referenced portions of the Code.
- (c) Presentations. The inquirer may desire or be asked to attend a meeting of the committee to make a formal presentation or to answer questions from the committee members with regard to the inquiry. Attendance at a committee meeting shall be at the expense of the inquirer. The inquirer's attendance or lack of attendance at a meeting shall not be a basis for acceptance or rejection of the inquiry by the committee.