

INTERNATIONAL  
STANDARD

ISO  
16773-2

Second edition  
2016-04-01

---

---

---

**Electrochemical impedance  
spectroscopy (EIS) on coated and  
uncoated metallic specimens —**

**Part 2:  
Collection of data**

*Spectroscopie d'impédance électrochimique (SIE) sur des éprouvettes  
métalliques revêtues et non revêtues —*

*Partie 2: Recueil des données*

---

---

---

Reference number  
ISO 16773-2:2016(E)



© ISO 2016



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

## Contents

	Page
<b>Foreword</b>	<b>iv</b>
<b>1 Scope</b>	<b>1</b>
<b>2 Normative references</b>	<b>1</b>
<b>3 Terms and definitions</b>	<b>1</b>
<b>4 Principle</b>	<b>1</b>
<b>5 Electrochemical cell</b>	<b>2</b>
5.1 General	2
5.2 Electrodes	3
5.3 Exposed area	3
5.4 Electrolyte	3
<b>6 Procedure</b>	<b>4</b>
6.1 Grounding	4
6.2 Shielding	4
6.3 Cell cable ground contacts	4
6.4 Local conditions	4
6.5 Measurement equipment characteristics	5
6.6 Confidence test	5
6.6.1 General	5
6.6.2 Use of interlaboratory test cells for confidence test	6
6.6.3 Error estimate and accuracy	6
6.7 Specimens	6
6.7.1 Preconditioning of specimens	6
6.7.2 Environmental control	6
6.8 Evaluation of laboratory and field coating specimens	6
6.9 Number of specimens and repeatability of results	7
<b>7 Instrumental parameters</b>	<b>7</b>
7.1 General	7
7.2 Conditioning potential and conditioning time	8
7.3 Frequency spectrum	8
7.4 Data point spacing and points per decade	8
7.5 D.C. potential control	8
7.6 Amplitude of perturbation	9
7.7 Current range settings	9
7.8 Data averaging settings	9
<b>8 Data presentation</b>	<b>9</b>
8.1 General	9
8.2 Bode plot	9
8.3 Nyquist plot	10
<b>9 Exchange file format</b>	<b>11</b>
<b>10 Test report</b>	<b>11</b>
<b>Annex A (informative) Determination of maximum measurable impedance with the open-lead test</b>	<b>13</b>
<b>Annex B (normative) Data exchange file format</b>	<b>15</b>
<b>Annex C (informative) Considerations about the precise determination of the exposed area</b>	<b>19</b>
<b>Bibliography</b>	<b>24</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 35, *Paints and varnishes*, Subcommittee SC 9, *General test methods for paints and varnishes*.

This second edition cancels and replaces the first edition (ISO 16773-2:2007), which has been technically revised. The main changes are the following:

- a) the introductory element of the title, *Paints and varnishes*, has been omitted, because the scope is broadened to include metals and alloys and the main element of the title has been changed to: *Electrochemical impedance spectroscopy (EIS) on coated and uncoated metallic specimens*;
- b) a reference to ISO/TR 16208 has been added;
- c) considerations about the precise determination of the exposed area have been added as an informative annex;
- d) a test report has been added.

ISO 16773 consists of the following parts, under the general title *Electrochemical impedance spectroscopy (EIS) on coated and uncoated metallic specimens*:

- *Part 1: Terms and definitions*
- *Part 2: Collection of data*
- *Part 3: Processing and analysis of data from dummy cells*
- *Part 4: Examples of spectra of polymer-coated and uncoated specimens*

# Electrochemical impedance spectroscopy (EIS) on coated and uncoated metallic specimens —

## Part 2: Collection of data

### 1 Scope

This part of ISO 16773 gives guidelines for optimizing the collection of EIS data with focus on high-impedance systems. High impedance in the context of intact coatings refers to systems with an impedance greater than  $10^9 \Omega \cdot \text{cm}^2$ . This does not preclude measurements on systems with lower impedance. For uncoated samples extra information can be found in ISO/TR 16208.

This part of ISO 16773 deals with the following:

- instrumental set-up: requirements and pit-falls;
- data validation: checking the measurement range and the accuracy of the data;
- performing an EIS measurement: specimen considerations and instrumental parameters;
- the experimental results: different methods of presenting EIS data.

These guidelines are intended to ensure the acquisition of EIS data that can be used to study the performance of the specimen. This part of ISO 16773 does not give guidelines for the interpretation of the data.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 16773-1, *Electrochemical impedance spectroscopy (EIS) on coated and uncoated metallic specimens — Part 1: Terms and definitions*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16773-1 apply.

### 4 Principle

A so-called “confidence” test is described in order to check the suitability of the entire set-up and recommendations are given as to how to perform EIS experiments. For convenience, only potentiostatically controlled EIS measurements are described, although it is also possible to make EIS measurements under galvanostatic control.

A potentiostat is connected either to a dummy cell or to an electrochemical cell (with working, counter- and reference electrodes). A single-sinusoidal- or multi-sinusoidal-waveform potential, either in conjunction with a d.c. offset or not, is applied by the potentiostat to the dummy cell or to the electrochemical cell, and the resulting a.c. current is measured. Both potential and a.c. current data are collected and analysed for amplitude and phase shift. This can be done in a variety of ways, depending