

**SECTION III**  
Rules for Construction of  
Nuclear Facility Components

**2021** ASME Boiler and  
Pressure Vessel Code  
An International Code

**Division 1 — Subsection NCD**  
Class 2 and Class 3 Components

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME,” ASME logos, or the ASME Single Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code or Standard. Use of the ASME Single Certification Mark requires formal ASME certification; if no certification program is available, such ASME markings may not be used. (For Certification and Accreditation Programs, see <https://www.asme.org/certification-accreditation>.)

Items produced by parties not formally possessing an ASME Certificate may not be described, either explicitly or implicitly, as ASME certified or approved in any code forms or other document.

AN INTERNATIONAL CODE

# 2021 ASME Boiler & Pressure Vessel Code

2021 Edition

July 1, 2021



## RULES FOR CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS

### Division 1 - Subsection NCD

---

### Class 2 and Class 3 Components

ASME Boiler and Pressure Vessel Committee  
on Construction of Nuclear Facility Components



The American Society of  
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 1, 2021

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark



ASME Single Certification Mark

"ASME" and the above ASME symbols are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934  
Printed in the United States of America

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2021.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2021 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved

# TABLE OF CONTENTS

List of Sections .....	xi
Foreword .....	xiii
Statement of Policy on the Use of the ASME Single Certification Mark and Code Authorization in Advertising .....	xv
Statement of Policy on the Use of ASME Marking to Identify Manufactured Items .....	xv
Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees .....	xvi
Personnel .....	xix
Organization of Section III .....	xl
Summary of Changes .....	xliv
NC- and ND- Paragraphs, Figures, and Tables Renumbered for Subsection NCD .....	xlvi
Cross-Referencing and Stylistic Changes in the Boiler and Pressure Vessel Code .....	xlix
<b>Article NCD-1000</b>	
NCD-1100	
<b>Article NCD-2000</b>	
NCD-2100	
NCD-2200	
NCD-2300	
NCD-2400	
NCD-2500	
NCD-2600	
NCD-2700	
<b>Article NCD-3000</b>	
NCD-3100	
NCD-3200	
NCD-3300	
NCD-3400	
NCD-3500	
NCD-3600	
NCD-3700	
NCD-3800	
NCD-3900	
<b>Article NCD-4000</b>	
NCD-4100	
NCD-4200	
NCD-4300	
NCD-4400	
NCD-4500	
NCD-4600	
<b>Introduction</b> .....	1
Scope .....	1
<b>Material</b> .....	6
General Requirements for Material .....	6
Material Test Coupons and Specimens for Ferritic Steel Material .....	9
Fracture Toughness Requirements for Material .....	13
Welding Material .....	20
Examination and Repair of Pressure-Retaining Material .....	24
Material Organizations' Quality System Programs .....	37
Dimensional Standards .....	37
<b>Design</b> .....	38
General Design .....	38
Alternative Design Rules for Class 2 Vessels .....	46
Vessel Design .....	79
Pump Design .....	117
Valve Design .....	143
Piping Design .....	152
Electrical and Mechanical Penetration Assemblies .....	189
Design of Atmospheric Storage Tanks .....	189
Design of 0 psi to 15 psi (0 kPa to 100 kPa) Storage Tanks .....	202
<b>Fabrication and Installation</b> .....	242
General Requirements .....	242
Forming, Cutting, and Aligning .....	243
Welding Qualifications .....	279
Rules Governing Making, Examining, and Repairing Welds .....	288
Brazing .....	294
Heat Treatment .....	297

NCD-4700	Mechanical Joints . . . . .	303
NCD-4800	Expansion Joints . . . . .	304
<b>Article NCD-5000</b>	<b>Examination</b> . . . . .	<b>305</b>
NCD-5100	General Requirements for Examination . . . . .	305
NCD-5200	Examination of Welds . . . . .	307
NCD-5300	Acceptance Standards . . . . .	312
NCD-5400	For Class 3 Only — Spot Examination of Welded Joints . . . . .	314
NCD-5500	Qualifications and Certification of Nondestructive Examination Personnel	315
NCD-5600	For Class 2 Only — Final Examination of Components . . . . .	316
NCD-5700	Examination Requirements for Expansion Joints . . . . .	316
<b>Article NCD-6000</b>	<b>Testing</b> . . . . .	<b>318</b>
NCD-6100	General Requirements . . . . .	318
NCD-6200	Hydrostatic Tests . . . . .	320
NCD-6300	Pneumatic Tests . . . . .	321
NCD-6400	Pressure Test Gages . . . . .	321
NCD-6500	Atmospheric and 0 psig to 15 psig (0 kPa gage to 100 kPa gage) Storage Tanks . . . . .	322
NCD-6600	Special Test Pressure Situations . . . . .	324
NCD-6900	Proof Tests to Establish Design Pressure . . . . .	324
<b>Article NCD-7000</b>	<b>Overpressure Protection</b> . . . . .	<b>329</b>
NCD-7100	General Requirements . . . . .	329
NCD-7200	Overpressure Protection Report . . . . .	331
NCD-7300	Relieving Capacity Requirements . . . . .	332
NCD-7400	Set Pressures of Pressure Relief Devices . . . . .	333
NCD-7500	Operating and Design Requirements for Pressure and Vacuum Relief Valves . . . . .	333
NCD-7600	Nonreclosing Pressure Relief Devices . . . . .	338
NCD-7700	Certification . . . . .	340
NCD-7800	Marking, Stamping With Certification Mark, and Data Reports . . . . .	342
<b>Article NCD-8000</b>	<b>Nameplates, Stamping With Certification Mark, and Reports</b> . . . .	<b>344</b>
NCD-8100	General Requirements . . . . .	344
 <b>Figures</b>		
NCD-1132.2-1	Attachments in the Component Support Load Path That Do Not Perform a Pressure-Retaining Function . . . . .	3
NCD-1132.2-2	Attachments That Do Not Perform a Pressure-Retaining Function and Are Not in the Component Support Load Path (Nonstructural Attachments)	4
NCD-1132.2-3	Attachments That Perform a Pressure-Retaining Function . . . . .	5
NCD-2433.1-1	Weld Metal Delta Ferrite Content . . . . .	23
NCD-2575.2-1	Typical Pressure-Retaining Parts of Pumps and Valves . . . . .	35
NCD-3133.4-1	For Class 3 Only — Length <i>L</i> of Some Typical Conical Sections . . . . .	43
NCD-3133.8-1	Chart for Determining Wall Thickness of Tubes Under External Pressure	47
NCD-3217-1	Example of Acceptable Local Primary Membrane Stress Due to Pressure	51
NCD-3224.6-1	Design Curves for Torispherical Heads and 2:1 Ellipsoidal Heads for Use With NCD-3224.8 and NCD-3224.6 . . . . .	56
NCD-3224.13(b)(6)(-a)-1	Inherent Reinforcement for Large End of Cone-Cylinder Junction . . . .	58

NCD-3224.13(b)(6)(-b)-1	Values for $Q$ for Large End of Cone–Cylinder Junction . . . . .	59
NCD-3224.13(c)(6)(-a)-1	Inherent Reinforcement for Small End of Cone–Cylinder Junction . . . .	60
NCD-3224.13(c)(6)(-b)-1	Values for $Q$ for Small End of Cone–Cylinder Junction . . . . .	61
NCD-3224.13(d)-1	Cone–Cylinder Junction at Small End Treated as Opening . . . . .	62
NCD-3225-1	Typical Flat Heads and Supported and Unsupported Tubesheets With Hubs	64
NCD-3225-2	Some Acceptable Types of Unstayed Flat Heads and Covers . . . . .	65
NCD-3225-3	Attachment of Pressure Parts to Plates to Form a Corner Joint . . . . .	66
NCD-3234.2(a)-1	Nozzle Nomenclature and Dimensions . . . . .	69
NCD-3239.1(b)-1	Examples of Acceptable Transition Details . . . . .	70
NCD-3239.4-1	Limits of Reinforcing Zone . . . . .	72
NCD-3324.2-1	Principal Dimensions of Typical Heads . . . . .	81
NCD-3324.11(a)(6)-1	Large Head Openings, Reverse Curve, and Conical Shell Reducer Sections	86
NCD-3325-1	Some Acceptable Types of Unstayed Flat Heads and Covers . . . . .	88
NCD-3326.1-1	Spherically Dished Covers With Bolting Flanges . . . . .	92
NCD-3329.1(b)-1	Example of Tube Spacing With Pitch of Holes Equal in Every Row . . . .	94
NCD-3329.1(b)-2	Example of Tube Spacing With Pitch of Holes Unequal in Every Second Row	95
NCD-3329.1(b)-3	Example of Tube Spacing With Pitch of Holes Varying in Every Second and Third Row . . . . .	95
NCD-3329.1(d)-1	Example of Tube Spacing With Tube Holes on Diagonal Lines . . . . .	96
NCD-3329.1(d)-2	Diagram for Determining the Efficiency of Longitudinal and Diagonal Ligaments Between Openings in Cylindrical Shells . . . . .	97
NCD-3329.1(g)-1	Diagram for Determining Equivalent Longitudinal Efficiency of Diagonal Ligaments . . . . .	99
NCD-3329.2.1-1	Acceptable Proportions for Ends or Through Stays . . . . .	100
NCD-3332.2-1	Chart for Determining Value of $F$ . . . . .	102
NCD-3335.1(b)-1	Some Representative Configurations Describing the $t_e$ Reinforcement Dimension . . . . .	104
NCD-3335.2-1	Arrangement of Multiple Openings . . . . .	105
NCD-3335.3(b)-1	Minimum Depth for Flange of Flued Openings . . . . .	106
NCD-3351-1	Welded Joint Locations Typical of Categories A, B, C, and D . . . . .	107
NCD-3352-1	Typical Butt Joints . . . . .	108
NCD-3358.1(a)-1	Heads Attached to Shells . . . . .	112
NCD-3361.1-1	Butt Welding of Plates of Unequal Thicknesses . . . . .	115
NCD-3423-1	Typical Single Volute Casing . . . . .	119
NCD-3423-2	Typical Double Volute Casing . . . . .	119
NCD-3433.4-1	Minimum Tangential Inlet and Outlet Wall Thickness . . . . .	120
NCD-3441.1-1	Type A Pump . . . . .	121
NCD-3441.1-2	Type A Pump . . . . .	122
NCD-3441.1(a)-1	Type A Pump . . . . .	122
NCD-3441.2-1	Type B Pump . . . . .	123
NCD-3441.3-1	Type C Pump . . . . .	123
NCD-3441.3-2	Type C Pump . . . . .	124
NCD-3441.4(a)-1	Type D Pump . . . . .	125
NCD-3441.5-1	Type E Pump . . . . .	125
NCD-3441.6(a)-1	Type F Pump . . . . .	126
NCD-3441.7(a)-1	Axially Split Casing, Volute Pump, Type G . . . . .	126

NCD-3441.7(a)-2	Axially Split Casing, Volute Pump, Type G . . . . .	127
NCD-3441.7(c)-1	Axially Split Casing, Volute Pump, Type G . . . . .	127
NCD-3441.7(c)(2)-1	Typical Section of Type G Pumps . . . . .	128
NCD-3441.7(c)(2)-2	Typical Section of Type G Pumps . . . . .	128
NCD-3441.7(c)(2)-3	Typical Loads on Type G Pumps . . . . .	129
NCD-3441.8-1	Longitudinal Section Through Type H Pump . . . . .	131
NCD-3441.8-2	Transverse Section Through Type H Pump . . . . .	131
NCD-3441.9-1	Type K Pump . . . . .	132
NCD-3441.9-2	Type K Pump . . . . .	133
NCD-3441.10-1	Type L Pump . . . . .	137
NCD-3441.10-2	Type L Pump Bowl . . . . .	139
NCD-3441.11-1	Type N Pump . . . . .	141
NCD-3451(a)-1	Horizontal Single-Acting Power Pump Liquid Ends . . . . .	142
NCD-3521-1	Typical Sections of Valve Bodies . . . . .	146
NCD-3591.2-1	Typical Pressure Relief Devices . . . . .	149
NCD-3591.2-2	Typical Pressure Relief Devices . . . . .	150
NCD-3595.3-1	Valve Nozzle . . . . .	151
NCD-3622-1	Examples of Reversing and Nonreversing Dynamic Loads . . . . .	156
NCD-3643.2(b)-1	Typical Welded Branch Connections . . . . .	159
NCD-3643.2(b)-2	Typical Right Angle Branch Connections Made Using a Fillet Weld or a Partial Penetration Weld . . . . .	160
NCD-3643.3(c)(1)-1	Reinforcement of Branch Connections . . . . .	162
NCD-3643.3(c)(1)-2	Some Representative Configurations Describing the $t_e$ Reinforcement Dimension . . . . .	163
NCD-3643.4(a)-1	Reinforced Extruded Outlets . . . . .	165
NCD-3647.2-1	Types of Permanent Blanks . . . . .	167
NCD-3653.3-1	Reducing or Full Outlet Branch Connections, or Tees . . . . .	173
NCD-3673.2(b)-2	Branch Connection Nomenclature . . . . .	187
NCD-3861-1	Roof Manholes . . . . .	203
NCD-3862(a)-1	Flanged Roof Nozzles . . . . .	204
NCD-3862(a)-2	Screwed or Socket Weld Roof Nozzles . . . . .	205
NCD-3863-1	Welded Bottom Outlet Elbow . . . . .	206
NCD-3922.1-1	Biaxial Stress Chart for Combined Tension and Compression, 30,000 psi to 38,000 psi (205 MPa to 260 MPa) Yield Strength Steels . . . . .	210
NCD-3922.1-2	Reduction of Design Stresses Required to Allow for Biaxial Stresses of Opposite Sign . . . . .	211
NCD-3932.1-1	Some Typical Free Body Diagrams for Certain Shapes of Tanks . . . . .	217
NCD-3933.4(a)-1	Compression Ring Region . . . . .	222
NCD-3933.5(d)-1	Permissible Details of Compression Ring Construction . . . . .	224
NCD-3944-1	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 25 ksi at Temperatures $\leq 300^\circ\text{F}$ . . . . .	229
NCD-3944-1M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 175 MPa at Temperatures $\leq 150^\circ\text{C}$ . . . . .	230



NCD-3944-2	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 30 ksi at Temperatures $\leq 300^{\circ}\text{F}$ . . . . .	231
NCD-3944-2M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 210 MPa at Temperatures $\leq 150^{\circ}\text{C}$ . . . . .	232
NCD-3944-3	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 35 ksi at Temperatures $\leq 300^{\circ}\text{F}$ . . . . .	233
NCD-3944-3M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 245 MPa at Temperatures $\leq 150^{\circ}\text{C}$ . . . . .	234
NCD-3944-4	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 40 ksi at Temperatures $\leq 300^{\circ}\text{F}$ . . . . .	235
NCD-3944-4M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 280 MPa at Temperatures $\leq 150^{\circ}\text{C}$ . . . . .	236
NCD-3944-5	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 45 ksi at Temperatures $\leq 300^{\circ}\text{F}$ . . . . .	237
NCD-3944-5M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 315 MPa at Temperatures $\leq 150^{\circ}\text{C}$ . . . . .	238
NCD-3944-6	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 50 ksi at Temperatures $\leq 300^{\circ}\text{F}$ . . . . .	239
NCD-3944-6M	Design Factor Times Allowable Axial Membrane Compressive Stress Versus Radius Over Thickness for Ferrous Materials With Yield Strengths of 350 MPa at Temperatures $\leq 150^{\circ}\text{C}$ . . . . .	240
NCD-3947-1	Meridional Straightness Tolerance . . . . .	241
NCD-4221.1-1	Maximum Difference in Cross-Sectional Diameters . . . . .	245
NCD-4221.2(a)-1	Maximum Permissible Deviation $e$ From a True Circular Form . . . . .	246
NCD-4221.2(a)-2	Maximum Arc Length for Determining Plus or Minus Deviation . . . . .	247
NCD-4233-1	Butt Weld Alignment and Mismatch Tolerances for Unequal I.D. and O.D. When Components Are Welded From One Side and Fairing Is Not Performed . . . . .	249
NCD-4243.1-1	For Class 2 Only — Acceptable Full Penetration Weld Details for Category C Joints . . . . .	251
NCD-4243.1-2	For Class 2 Only — Attachment of Pressure Parts to Plates to Form a Corner Joint . . . . .	252
NCD-4243.2-1	For Class 3 Only — Attachment of Pressure Parts to Plates to Form a Corner Joint . . . . .	253
NCD-4243.3-1	Typical Flat Heads and Supported and Unsupported Tubesheet With Hubs	255
NCD-4244.1-1	Nozzles, Branch, and Piping Connections Joined by Full Penetration Butt Welds . . . . .	256
NCD-4244.1-2	Nozzles, Branch, and Piping Connections Joined by Full Penetration Corner Welds . . . . .	257
NCD-4244.1-3	Deposited Weld Metal Used as Reinforcement of Openings for Nozzles, Branch, and Piping Connections . . . . .	258

NCD-4244.1-4	Some Acceptable Types of Welded Nozzles, Branch, and Piping Connections . . . . .	259
NCD-4244.1-5	Some Acceptable Types of Welded Nozzles . . . . .	261
NCD-4244.1-6	Some Acceptable Types of Small Fitting . . . . .	262
NCD-4244.2-1	Tube Connections . . . . .	263
NCD-4244.2-2	Some Acceptable Types of Welded Nozzles, and Branch and Piping Connections . . . . .	264
NCD-4245.2-1	Attachment Welds . . . . .	266
NCD-4246.1(a)-1	Typical Bottom and Bottom-to-Shell Joints . . . . .	269
NCD-4246.3-1	Typical Roof and Roof-to-Shell Joints . . . . .	270
NCD-4246.5-1	Roof Manholes . . . . .	271
NCD-4246.5-2	Flanged Roof Nozzles . . . . .	272
NCD-4246.5-3	Screwed or Socket Weld Roof Nozzles . . . . .	272
NCD-4246.5-4	Welded Bottom Outlet Elbow . . . . .	273
NCD-4250-1	Welding End Transitions Maximum Envelope . . . . .	274
NCD-4265-1	Acceptable Full Penetration Details to Form a Corner Joint . . . . .	276
NCD-4265-2	Acceptable Full Penetration Weld Details for Category C Joints . . . . .	277
NCD-4266(a)-1	Nozzles Attached by Full Penetration Butt Welds . . . . .	277
NCD-4266(b)-1	Full Penetration Corner Welded Attachments . . . . .	278
NCD-4266(c)-1	Pad and Screwed Fitting Types of Welded Nozzles and Other Connections to Shells, Drums, and Headers . . . . .	280
NCD-4266(d)-1	Partial Penetration Weld Connections . . . . .	281
NCD-4267-1	Attachments . . . . .	282
NCD-4427-1	Fillet and Socket Weld Details and Dimensions . . . . .	290
NCD-4433-1	Types of Attachment Welds . . . . .	292
NCD-4437.2(b)-1	Some Acceptable Methods of Attaching Stiffening Rings to Shells of Cylindrical Vessels Subjected to External Pressure . . . . .	293
NCD-4470-1	For Class 3 Only — Welded Stayed Construction . . . . .	295
NCD-4511-1	Brazed Connections for Appurtenances and Piping . . . . .	296
NCD-4730-1	Penetration Assembly . . . . .	304
NCD-4810(c)-1	Permissible Attachment Welds for Bellows . . . . .	304

**Tables**

NCD-2311-1	For Class 2 Only — Exemptions From Impact Testing Under NCD-2311(a)(8) . . . . .	14
NCD-2311-2	For Class 3 Only — Exemptions From Impact Testing Under NCD-2311(a)(9) . . . . .	15
NCD-2332.1-1	For Class 2 Only — Required $C_v$ Lateral Expansion Values for Pressure-Retaining Material Other Than Bolting Material . . . . .	15
NCD-2332.1-2	For Class 2 Only — Required $C_v$ Energy Values for Pressure-Retaining Material Other Than Bolting Material . . . . .	16
NCD-2332.3-1	For Class 2 Only — Required $C_v$ Values for Bolting Material Tested in Accordance With NCD-2332.3 . . . . .	16
NCD-2333.1-1	For Class 3 Only — Required $C_v$ Lateral Expansion Values for Pressure-Retaining Material Other Than Bolting Material . . . . .	17
NCD-2333.1-2	For Class 3 Only — Required $C_v$ Energy Values for Pressure-Retaining Material Other Than Bolting Material . . . . .	18

NCD-2333.2-1	For Class 3 Only — Required $C_v$ Values for Bolting Material . . . . .	18
NCD-2432.1-1	Sampling of Welding Materials for Chemical Analysis . . . . .	22
NCD-2432.2-1	Welding Material Chemical Analysis . . . . .	22
NCD-2571.1-1	Required Examinations for Class 2 Castings . . . . .	30
NCD-2571.2-1	Required Examinations for Class 3 Castings . . . . .	31
NCD-3215.1(a)-1	Pressure and Temperature Relationships . . . . .	49
NCD-3217-1	Stress Intensity $k$ Factors for Design and Service Load Combinations . . . . .	50
NCD-3239.3(a)-1	Required Minimum Reinforcing Area, $A_r$ . . . . .	71
NCD-3239.7-1	Stress Indices for Internal Pressure Loading . . . . .	72
NCD-3266-1	Minimum Number of Pipe Threads for Connections . . . . .	78
NCD-3321-1	Stress Limits for Design and Service Loadings . . . . .	79
NCD-3321-2	Classification of Stress in Vessels for Some Typical Cases . . . . .	80
NCD-3324.2-1	Values of Factor $K$ . . . . .	82
NCD-3324.8(b)-1	Values of Factor $M$ . . . . .	84
NCD-3324.11(b)(2)-1	Values of $\Delta$ for Junctions at the Large Cylinder for $\alpha \leq 30$ deg . . . . .	86
NCD-3324.11(b)(3)-1	Values of $\Delta$ for Junctions at the Small Cylinder for $\alpha \leq 30$ deg . . . . .	86
NCD-3332.2-1	Values of Spherical Radius Factor $K_1$ . . . . .	102
NCD-3361.2.2-1	Minimum Number of Pipe Threads for Connections . . . . .	115
NCD-3416-1	Stress and Pressure Limits for Design and Service Loadings . . . . .	118
NCD-3521-1	Service Loading Limits . . . . .	147
NCD-3592.2(b)-1	Pressure Relief Devices Service Loading Limits . . . . .	151
NCD-3611.2(e)-1	Stress Range Reduction Factors . . . . .	152
NCD-3613.4-1	For Class 3 Only — Weld Joint Efficiency Factor . . . . .	154
NCD-3641.1(a)-1	Values of $A$ . . . . .	157
NCD-3673.2(b)-1	Stress Indices, Flexibility, and Stress Intensification Factors . . . . .	181
NCD-3821.5-1	Design and Service Limits . . . . .	190
NCD-3852.7-1	For Class 3 Aluminum Storage Tanks Only — Allowable Tensile Stresses for Roof Supports . . . . .	194
NCD-3852.7-2	For Class 3 Aluminum Storage Tanks Only — Allowable Axial Compression Stresses for Roof Supports . . . . .	195
NCD-3852.7-3	For Class 3 Aluminum Storage Tanks Only — Allowable Bending Stresses for Roof Supports . . . . .	197
NCD-3852.7-4	For Class 3 Aluminum Storage Tanks Only — Allowable Shear Stresses for Roof Supports . . . . .	199
NCD-3852.7-5	For Class 3 Aluminum Storage Tanks Only — Allowable Shear and Tension Stresses for Bolts for Roof Supports . . . . .	200
NCD-3852.7-6	For Class 3 Aluminum Storage Tanks Only — Allowable Bearing Stresses for Bolts for Roof Supports . . . . .	200
NCD-3861-1	Roof Manholes . . . . .	204
NCD-3862(a)-1	Flanged Roof Nozzles . . . . .	204
NCD-3862(a)-2	Screwed or Socket Weld Roof Nozzles . . . . .	205
NCD-3863-1	Welded Bottom Outlet Elbow . . . . .	206
NCD-3865-1	Platforms and Walkways . . . . .	207
NCD-3865-2	Stairways . . . . .	207
NCD-3865-3	Stairway Rise, Run, and Angle Relationships . . . . .	208
NCD-3921.8-1	Design and Service Limits for Steel Tanks . . . . .	209

NCD-3923.1-1	Maximum Allowable Stress Values for Structural Members . . . . .	214
NCD-3932.2(d)-1	Factors for Determining Values of $R_1$ and $R_2$ for 2:1 Ellipsoidal Roofs and Bottoms . . . . .	218
NCD-3933.5(h)-1	Some Values for $k$ Based on $n, \theta$ . . . . .	225
NCD-4232(a)-1	Maximum Allowable Offset in Final Welded Joints . . . . .	248
NCD-4245.2-1	. . . . .	265
NCD-4247.6(d)-1	Minimum Size for Fillet Welds . . . . .	273
NCD-4524-1	Maximum Design Temperatures for Brazing Filler Metal, °F (°C) . . . . .	297
NCD-4622.1-1	Mandatory Requirements for Postweld Heat Treatment of Welds . . . . .	298
NCD-4622.4(c)-1	Alternative Holding Temperatures and Times . . . . .	299
NCD-4622.7(b)-1	Exemptions to Mandatory PWHT . . . . .	300
NCD-5111.1-1	Thickness, IQI Designations, and Essential Holes, and Wire Diameters . . . . .	305
NCD-5211.2-1	For Class 3 Only — Thickness Above Which Full Radiographic Examination of Butt-Welded Joint Is Mandatory . . . . .	308
<b>Endnotes</b>	. . . . .	345

# LIST OF SECTIONS

(21)

## SECTIONS

- I Rules for Construction of Power Boilers
- II Materials
  - Part A — Ferrous Material Specifications
  - Part B — Nonferrous Material Specifications
  - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
  - Part D — Properties (Customary)
  - Part D — Properties (Metric)
- III Rules for Construction of Nuclear Facility Components
  - Subsection NCA — General Requirements for Division 1 and Division 2
  - Appendices
  - Division 1
    - Subsection NB — Class 1 Components
    - Subsection NCD — Class 2 and Class 3 Components\*
    - Subsection NE — Class MC Components
    - Subsection NF — Supports
    - Subsection NG — Core Support Structures
  - Division 2 — Code for Concrete Containments
  - Division 3 — Containment Systems for Transportation and Storage of Spent Nuclear Fuel and High-Level Radioactive Material
  - Division 5 — High Temperature Reactors
- IV Rules for Construction of Heating Boilers
- V Nondestructive Examination
- VI Recommended Rules for the Care and Operation of Heating Boilers
- VII Recommended Guidelines for the Care of Power Boilers
- VIII Rules for Construction of Pressure Vessels
  - Division 1
  - Division 2 — Alternative Rules
  - Division 3 — Alternative Rules for Construction of High Pressure Vessels
- IX Welding, Brazing, and Fusing Qualifications
- X Fiber-Reinforced Plastic Pressure Vessels
- XI Rules for Inservice Inspection of Nuclear Power Plant Components
  - Division 1 — Rules for Inspection and Testing of Components of Light-Water-Cooled Plants
  - Division 2 — Requirements for Reliability and Integrity Management (RIM) Programs for Nuclear Power Plants
- XII Rules for Construction and Continued Service of Transport Tanks
- XIII Rules for Overpressure Protection

---

\* In the 2021 Edition, Subsections NC and ND have been incorporated into one publication, Subsection NCD (BPVC.III.1.NCD), Class 2 and Class 3 Components.

## **INTERPRETATIONS**

Interpretations are issued in real time in ASME's Interpretations Database at <http://go.asme.org/Interpretations>. Historical BPVC interpretations may also be found in the Database.

## **CODE CASES**

The Boiler and Pressure Vessel Code committees meet regularly to consider proposed additions and revisions to the Code and to formulate Cases to clarify the intent of existing requirements or provide, when the need is urgent, rules for materials or constructions not covered by existing Code rules. Those Cases that have been adopted will appear in the appropriate 2021 Code Cases book: "Boilers and Pressure Vessels" or "Nuclear Components." Each Code Cases book is updated with seven Supplements. Supplements will be sent or made available automatically to the purchasers of the Code Cases books up to the publication of the 2023 Code. Annulments of Code Cases become effective six months after the first announcement of the annulment in a Code Case Supplement or Edition of the appropriate Code Case book. Code Case users can check the current status of any Code Case at <http://go.asme.org/BPVCCDatabase>. Code Case users can also view an index of the complete list of Boiler and Pressure Vessel Code Cases and Nuclear Code Cases at <http://go.asme.org/BPVCC>.

# FOREWORD\*

(21)

In 1911, The American Society of Mechanical Engineers established the Boiler and Pressure Vessel Committee to formulate standard rules for the construction of steam boilers and other pressure vessels. In 2009, the Boiler and Pressure Vessel Committee was superseded by the following committees:

- (a) Committee on Power Boilers (I)
- (b) Committee on Materials (II)
- (c) Committee on Construction of Nuclear Facility Components (III)
- (d) Committee on Heating Boilers (IV)
- (e) Committee on Nondestructive Examination (V)
- (f) Committee on Pressure Vessels (VIII)
- (g) Committee on Welding, Brazing, and Fusing (IX)
- (h) Committee on Fiber-Reinforced Plastic Pressure Vessels (X)
- (i) Committee on Nuclear Inservice Inspection (XI)
- (j) Committee on Transport Tanks (XII)
- (k) Committee on Overpressure Protection (XIII)
- (l) Technical Oversight Management Committee (TOMC)

Where reference is made to “the Committee” in this Foreword, each of these committees is included individually and collectively.

The Committee’s function is to establish rules of safety relating to pressure integrity, which govern the construction\*\* of boilers, pressure vessels, transport tanks, and nuclear components, and the inservice inspection of nuclear components and transport tanks. For nuclear items other than pressure-retaining components, the Committee also establishes rules of safety related to structural integrity. The Committee also interprets these rules when questions arise regarding their intent. The technical consistency of the Sections of the Code and coordination of standards development activities of the Committees is supported and guided by the Technical Oversight Management Committee. This Code does not address other safety issues relating to the construction of boilers, pressure vessels, transport tanks, or nuclear components, or the inservice inspection of nuclear components or transport tanks. Users of the Code should refer to the pertinent codes, standards, laws, regulations, or other relevant documents for safety issues other than those relating to pressure integrity and, for nuclear items other than pressure-retaining components, structural integrity. Except for Sections XI and XII, and with a few other exceptions, the rules do not, of practical necessity, reflect the likelihood and consequences of deterioration in service related to specific service fluids or external operating environments. In formulating the rules, the Committee considers the needs of users, manufacturers, and inspectors of components addressed by the Code. The objective of the rules is to afford reasonably certain protection of life and property, and to provide a margin for deterioration in service to give a reasonably long, safe period of usefulness. Advancements in design and materials and evidence of experience have been recognized.

This Code contains mandatory requirements, specific prohibitions, and nonmandatory guidance for construction activities and inservice inspection and testing activities. The Code does not address all aspects of these activities and those aspects that are not specifically addressed should not be considered prohibited. The Code is not a handbook and cannot replace education, experience, and the use of engineering judgment. The phrase *engineering judgment* refers to technical judgments made by knowledgeable engineers experienced in the application of the Code. Engineering judgments must be consistent with Code philosophy, and such judgments must never be used to overrule mandatory requirements or specific prohibitions of the Code.

The Committee recognizes that tools and techniques used for design and analysis change as technology progresses and expects engineers to use good judgment in the application of these tools. The designer is responsible for complying with Code rules and demonstrating compliance with Code equations when such equations are mandatory. The Code neither requires nor prohibits the use of computers for the design or analysis of components constructed to the requirements of the Code. However, designers and engineers using computer programs for design or analysis are cautioned that they are

---

\* The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI’s requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Code.

\*\* *Construction*, as used in this Foreword, is an all-inclusive term comprising materials, design, fabrication, examination, inspection, testing, certification, and overpressure protection.

responsible for all technical assumptions inherent in the programs they use and the application of these programs to their design.

The rules established by the Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way the manufacturer's freedom to choose any method of design or any form of construction that conforms to the Code rules.

The Committee meets regularly to consider revisions of the rules, new rules as dictated by technological development, Code Cases, and requests for interpretations. Only the Committee has the authority to provide official interpretations of this Code. Requests for revisions, new rules, Code Cases, or interpretations shall be addressed to the Secretary in writing and shall give full particulars in order to receive consideration and action (see Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees). Proposed revisions to the Code resulting from inquiries will be presented to the Committee for appropriate action. The action of the Committee becomes effective only after confirmation by ballot of the Committee and approval by ASME. Proposed revisions to the Code approved by the Committee are submitted to the American National Standards Institute (ANSI) and published at <http://go.asme.org/BPVCPublicReview> to invite comments from all interested persons. After public review and final approval by ASME, revisions are published at regular intervals in Editions of the Code.

The Committee does not rule on whether a component shall or shall not be constructed to the provisions of the Code. The scope of each Section has been established to identify the components and parameters considered by the Committee in formulating the Code rules.

Questions or issues regarding compliance of a specific component with the Code rules are to be directed to the ASME Certificate Holder (Manufacturer). Inquiries concerning the interpretation of the Code are to be directed to the Committee. ASME is to be notified should questions arise concerning improper use of the ASME Single Certification Mark.

When required by context in this Section, the singular shall be interpreted as the plural, and vice versa, and the feminine, masculine, or neuter gender shall be treated as such other gender as appropriate.

The words "shall," "should," and "may" are used in this Standard as follows:

- *Shall* is used to denote a requirement.
- *Should* is used to denote a recommendation.
- *May* is used to denote permission, neither a requirement nor a recommendation.



# **STATEMENT OF POLICY ON THE USE OF THE ASME SINGLE CERTIFICATION MARK AND CODE AUTHORIZATION IN ADVERTISING**

ASME has established procedures to authorize qualified organizations to perform various activities in accordance with the requirements of the ASME Boiler and Pressure Vessel Code. It is the aim of the Society to provide recognition of organizations so authorized. An organization holding authorization to perform various activities in accordance with the requirements of the Code may state this capability in its advertising literature.

Organizations that are authorized to use the ASME Single Certification Mark for marking items or constructions that have been constructed and inspected in compliance with the ASME Boiler and Pressure Vessel Code are issued Certificates of Authorization. It is the aim of the Society to maintain the standing of the ASME Single Certification Mark for the benefit of the users, the enforcement jurisdictions, and the holders of the ASME Single Certification Mark who comply with all requirements.

Based on these objectives, the following policy has been established on the usage in advertising of facsimiles of the ASME Single Certification Mark, Certificates of Authorization, and reference to Code construction. The American Society of Mechanical Engineers does not “approve,” “certify,” “rate,” or “endorse” any item, construction, or activity and there shall be no statements or implications that might so indicate. An organization holding the ASME Single Certification Mark and/or a Certificate of Authorization may state in advertising literature that items, constructions, or activities “are built (produced or performed) or activities conducted in accordance with the requirements of the ASME Boiler and Pressure Vessel Code,” or “meet the requirements of the ASME Boiler and Pressure Vessel Code.” An ASME corporate logo shall not be used by any organization other than ASME.

The ASME Single Certification Mark shall be used only for stamping and nameplates as specifically provided in the Code. However, facsimiles may be used for the purpose of fostering the use of such construction. Such usage may be by an association or a society, or by a holder of the ASME Single Certification Mark who may also use the facsimile in advertising to show that clearly specified items will carry the ASME Single Certification Mark.

# **STATEMENT OF POLICY ON THE USE OF ASME MARKING TO IDENTIFY MANUFACTURED ITEMS**

The ASME Boiler and Pressure Vessel Code provides rules for the construction of boilers, pressure vessels, and nuclear components. This includes requirements for materials, design, fabrication, examination, inspection, and stamping. Items constructed in accordance with all of the applicable rules of the Code are identified with the ASME Single Certification Mark described in the governing Section of the Code.

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME” or the ASME Single Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code.

Items shall not be described on ASME Data Report Forms nor on similar forms referring to ASME that tend to imply that all Code requirements have been met when, in fact, they have not been. Data Report Forms covering items not fully complying with ASME requirements should not refer to ASME or they should clearly identify all exceptions to the ASME requirements.

(21) **SUBMITTAL OF TECHNICAL INQUIRIES TO THE BOILER AND PRESSURE VESSEL STANDARDS COMMITTEES**

**1 INTRODUCTION**

(a) The following information provides guidance to Code users for submitting technical inquiries to the applicable Boiler and Pressure Vessel (BPV) Standards Committee (hereinafter referred to as the Committee). See the guidelines on approval of new materials under the ASME Boiler and Pressure Vessel Code in Section II, Part D for requirements for requests that involve adding new materials to the Code. See the guidelines on approval of new welding and brazing materials in Section II, Part C for requirements for requests that involve adding new welding and brazing materials (“consumables”) to the Code.

Technical inquiries can include requests for revisions or additions to the Code requirements, requests for Code Cases, or requests for Code Interpretations, as described below:

(1) *Code Revisions*. Code revisions are considered to accommodate technological developments, to address administrative requirements, to incorporate Code Cases, or to clarify Code intent.

(2) *Code Cases*. Code Cases represent alternatives or additions to existing Code requirements. Code Cases are written as a Question and Reply, and are usually intended to be incorporated into the Code at a later date. When used, Code Cases prescribe mandatory requirements in the same sense as the text of the Code. However, users are cautioned that not all regulators, jurisdictions, or Owners automatically accept Code Cases. The most common applications for Code Cases are as follows:

(-a) to permit early implementation of an approved Code revision based on an urgent need

(-b) to permit use of a new material for Code construction

(-c) to gain experience with new materials or alternative requirements prior to incorporation directly into the Code

(3) *Code Interpretations*

(-a) Code Interpretations provide clarification of the meaning of existing requirements in the Code and are presented in Inquiry and Reply format. Interpretations do not introduce new requirements.

(-b) Interpretations will be issued only if existing Code text is ambiguous or conveys conflicting requirements. If a revision of the requirements is required to support the Interpretation, an Intent Interpretation will be issued in parallel with a revision to the Code.

(b) Code requirements, Code Cases, and Code Interpretations established by the Committee are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or Owners to choose any method of design or any form of construction that conforms to the Code requirements.

(c) Inquiries that do not comply with the following guidance or that do not provide sufficient information for the Committee’s full understanding may result in the request being returned to the Inquirer with no action.

**2 INQUIRY FORMAT**

Submittals to the Committee should include the following information:

(a) *Purpose*. Specify one of the following:

(1) request for revision of present Code requirements

(2) request for new or additional Code requirements

(3) request for Code Case

(4) request for Code Interpretation

(b) *Background*. The Inquirer should provide the information needed for the Committee’s understanding of the Inquiry, being sure to include reference to the applicable Code Section, Division, Edition, Addenda (if applicable), paragraphs, figures, and tables. This information should include a statement indicating why the included paragraphs, figures, or tables are ambiguous or convey conflicting requirements. Preferably, the Inquirer should provide a copy of, or relevant extracts from, the specific referenced portions of the Code.