

CONTENTS
ANSI/ASHRAE Standard 41.6-2021
Standard Methods for Humidity Measurements

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Classifications	3
5 Requirements	4
6 Instruments and Calibration	13
7 Humidity Measurement Methods	13
8 Uncertainty Analysis	14
9 Test Report	15
10 References	15
Informative Appendix A: References and Bibliography	16
Informative Appendix B: Primary Humidity Calibrators	17
Informative Appendix C: User Guidance Regarding Humidity Measurements	20
Informative Appendix D: Humidity Measurement Methods Accuracies and Operating Ranges	21
Informative Appendix E: Tips to Specifying the Accuracy Requirement in Section 5.1	22
Informative Appendix F: Example of an Uncertainty Estimate for a Wet-Bulb Measurement	23

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2021 ASHRAE

180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.
ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Selecting an appropriate psychrometer or hygrometer can be daunting given the wide variety of operating principles, measurement precision, and costs. Whether humidity measurements are to be taken in a laboratory or in the field, selecting the appropriate hygrometer should be based on the required measurement accuracy.

Users need to construct a psychrometer or hygrometer in accordance with the specifications defined in this in this standard, select a psychrometer or hygrometer from commercial products, or obtain a psychrometer or hygrometer from other sources. Next, the user may need to consult with the source of the a psychrometer or hygrometer regarding installation specifics, operating range limits, calibration limits, and other similar specifics in order to obtain the expected measurement accuracy.

The 2021 edition of the standard includes an improved method for determining when steady-state operation has been achieved for data recording, changes to make it easier for higher-tier standards to adopt this standard by reference, and a new uncertainty example prepared in accordance with the latest uncertainty methods. This edition of ASHRAE Standard 41.6 meets ASHRAE's mandatory language requirements.

1. PURPOSE

This standard prescribes methods for measuring the humidity of moist air with instruments.

2. SCOPE

2.1 This standard applies to the measurement of humidity of moist air from sea level to 3048 m (10,000 ft) within the dry-bulb temperature range of -50°C to 160°C (-58°F to 320°F) and within the dew-point temperature range of -50°C to 99°C (-58°F to 210°F).

2.2 This standard applies to methods for the measurement of wet-bulb temperature, dew-point temperature, and relative humidity.

2.3 This standard requires determining the uncertainty of direct humidity measurements due to various sources of errors.

3. DEFINITIONS

accuracy: the degree of conformity of an indicated value to the corresponding true value.

error: the difference between the test result and its corresponding true value.

frost point: the temperature where visible frost forms on a surface being chilled.

humidity: the moisture content of an air/water mixture

absolute humidity: in a mixture of water vapor and dry air, the ratio of the mass of water vapor to the total volume of the sample.

relative humidity:

- a. ratio of the partial pressure of water vapor to the saturation pressure in a given moist-air sample at the same dry-bulb temperature.
- b. ratio of the density of water vapor to the air density at the same dry-bulb temperature and ambient-air barometric pressure.
- c. ratio of the mole fraction of water vapor to the mole fraction of water vapor saturated at the same temperature and barometric pressure.

hygrometer: an instrument used to measure humidity in the atmosphere.

measurement system: the instruments, signal conditioning systems if any, and data acquisition system if any.

operating tolerance limit: the upper or lower value of an operating tolerance that is associated with a test point or a targeted set point.