

ANSI/ASHRAE Standard 41.9-2000 (RA 2006)
Reaffirmation of ANSI/ASHRAE Standard 41.9-2000



ASHRAE STANDARD

Calorimeter Test Methods for Mass Flow Measurements of Volatile Refrigerants

This standard was approved by the ASHRAE Standards Committee on June 25, 2000, and reaffirmed October 2, 2005; by the ASHRAE Board of Directors on June 29, 2000, and reaffirmed January 22, 2006; and by the American National Standards Institute on October 6, 2000, and reaffirmed January 23, 2006.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2006 ASHRAE, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329

www.ashrae.org

ASHRAE Standard Project Committee 41.9
Cognizant TC: TC 8.1, Positive Displacement Compressors
SPLS Liaison: James K. Vallort

Richard L. Hall, *Chair**
Patrick E. Collins*
Albert A. Domingorena*
James L. Douglas*
Richard J. Dunklau*
Georgi S. Kazachki*
Alexander D. Leyderman*

John A. O'Brien*
Mark W. Paquette*
Joseph W. Pillis*
Dean H. Rizzo*
Bert Stenzel*
Michael A. Wegenka*
Jaroslav Wurm*

*Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2005-2006

Richard D. Hermans, *Chair*
David E. Knebel, *Vice-Chair*
Donald L. Brandt
Steven T. Bushby
Paul W. Cabot
Hugh F. Crowther
Samuel D. Cummings, Jr.
Robert G. Doerr
Hakim Elmahdy
Roger L. Hedrick
John F. Hogan
Frank E. Jakob

Stephen D. Kennedy
Jay A. Kohler
James D. Lutz
Merle F. McBride
Mark P. Modera
Cyrus H. Nasseri
Stephen V. Santoro
Steven V. Skalko
David R. Tree
Jerry W. White, Jr.
James E. Woods
William E. Murphy, *BOD ExO*
Ronald E. Jarnagin, *CO*

Claire B. Ramspeck, *Assistant Director of Technology for Standards and Special Projects*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 41.9-2000 (RA 2006) Calorimeter Test Methods for Mass Flow Measurement of Volatile Refrigerants

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Classifications.....	3
5 Requirements	3
6 Instruments.....	4
7 Secondary Refrigerant Calorimeter Method.....	4
8 Secondary Fluid Calorimeter Method.....	6
9 Primary Refrigerant Calorimeter Method.....	8
10 Condenser Calorimeter Method.....	9
11 Oil Circulation Measurements.....	10
12 Uncertainty Calculations.....	12
13 Test Report	13
14 References	14
Appendix A: Error Analysis for an Evaporator Calorimeter.....	14
Appendix B: Example of Uncertainty Estimate for a Secondary Refrigerant Calorimeter or a Primary Refrigerant Calorimeter	16
Appendix C: Example of Uncertainty Estimate for a Condenser Calorimeter.....	17

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at <http://www.ashrae.org>.

© Copyright 2006 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org

All rights reserved.

(This foreword is not a part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process.)

FOREWORD

This is a reaffirmation of ASHRAE Standard 41.9-2000. This standard falls under the Standards Committee classification of Standard Method of Measurement. This standard was prepared under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.

The changes made for the 2006 reaffirmation were that dates throughout the standard were updated, including those in the references section.

1. PURPOSE

This standard provides recommended practices for measuring the mass flow rate of volatile refrigerants using calorimeters.

2. SCOPE

2.1 This standard applies to the measurement of the flow of a volatile refrigerant in the following cases and no others:

- a. where the entire flow stream of the volatile refrigerant enters the calorimeter as a subcooled liquid and leaves as a superheated vapor (evaporator-type) and
- b. where the entire flow stream of the volatile refrigerant enters the calorimeter as a superheated vapor and leaves as a subcooled liquid (condenser-type).

2.2 This standard applies to all of the refrigerants listed in the *ASHRAE Handbook—Fundamentals*¹ and in *ANSI/ASHRAE Standard 34*.²

3. DEFINITIONS

The following definitions apply to the terms used in this standard. Additional definitions are given in the *ASHRAE Terminology of Heating, Ventilation, Air Conditioning, & Refrigeration*.³

azeotropic refrigerant: an azeotropic blend contains two or more refrigerants whose equilibrium-vapor and liquid-phase compositions are the same at a given pressure. The temperature of an azeotropic refrigerant remains constant as it evaporates or condenses at constant pressure (compare to zeotropic refrigerant).

bubble-point temperature: a liquid-vapor equilibrium point for a volatile pure liquid or for a multi-component mixture of miscible, volatile pure component liquids, in the absence of noncondensables, where the temperature of the mixture at a defined pressure is the minimum temperature required for a vapor bubble to form in the liquid.

calorimeter: a thermally insulated apparatus containing a heat exchanger that determines the mass flow rate of a volatile refrigerant by measuring the heat input/output that will result in a known enthalpy change for the volatile refrigerant.

dew-point temperature: a vapor-liquid equilibrium point for a volatile pure liquid or for a multi-component mixture of miscible, volatile pure component liquids, in the absence of noncondensables, where the temperature of the mixture at a defined pressure is the maximum temperature required for a liquid drop to form in the vapor.

enthalpy (heat content): thermodynamic quantity equal to the sum of the internal energy of a system plus the product of the pressure-volume work done on the system.

error: the difference between the true value of the quantity measured and the observed value. All errors in experimental data can be classified as one of two types: systematic (fixed) errors or random (precision) errors. The terms *accuracy* and *precision* are often used to distinguish between systematic and random errors. A measurement with small systematic errors is said to be unbiased. A measurement with small random errors is said to have high precision. A measurement that is unbiased and precise is said to be accurate.

fixed error: same as systematic error.

fractionation: a change in composition of a refrigerant blend by preferential evaporation of the more volatile component(s) or condensation of the less volatile component(s).

glide: the absolute value of the difference between the starting and ending temperatures of a phase-change process (condensation or evaporation) for a zeotropic refrigerant exclusive of any liquid subcooling or vapor superheating.

near-azeotropic: a zeotropic refrigerant blend with a temperature glide sufficiently small that it may be disregarded without consequential error in analysis for a given application.

nonazeotropic: a synonym for zeotropic (zeotropic is the preferred term).

oil circulation: the ratio of the mass of oil circulating through a refrigerant system to the total mass of refrigerant and oil flowing through the system at a specified set of operating conditions.

precision error: same as random error.

random error: an error that causes readings to take random values on either side of a mean value. The random error is quantified based on how well an instrument can reproduce subsequent readings for an unchanging input. Random errors cannot be corrected through calibration.

refrigerant blend (or mixture): a refrigerant composed of two or more different chemical compounds, often used individually as refrigerants for other applications.

refrigerant mass flow rate: the mass flow rate of volatile refrigerant potentially mixed with lubricant up to the oil circulation limits defined in 5.2.2.

saturation temperature: the equilibrium temperature of an azeotropic refrigerant resulting from a two-phase mixture of a vapor and liquid at a given absolute pressure.