

2013


ASME Boiler and Pressure Vessel Code

AN INTERNATIONAL CODE

III

Rules for Construction of Nuclear Facility Components

Division 2 Code for Concrete Containments



ACI Standard 359-13



INTENTIONALLY LEFT BLANK

AN INTERNATIONAL CODE

2013 ASME Boiler & Pressure Vessel Code

2013 Edition

July 1, 2013

(ACI Standard 359-13)



RULES FOR CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS

Division 2

Code for Concrete Containments

ASME Boiler and Pressure Vessel Committee
on Nuclear Power

ACI-ASME Joint Technical Committee



The American Society of
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 1, 2013

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes in this document are part of this American National Standard.



ASME collective membership mark



Certification Mark

The above ASME symbol is registered in the U.S. Patent Office.

“ASME” is the trademark of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934
Printed in the United States of America

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2013.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2013 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved

TABLE OF CONTENTS

List of Sections		ix
Foreword		xi
Statement of Policy on the Use of the Certification Mark and Code Authorization in Advertising		xiii
Statement of Policy on the Use of ASME Marking to Identify Manufactured Items		xiii
Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees		xiv
Personnel		xvi
Introduction to Section III, Division 2		xxxii
Organization of Section III		xxxiii
Summary of Changes		xxxvi
List of Changes in Record Number Order		xxxix
Cross-Referencing and Stylistic Changes in the Boiler and Pressure Vessel Code		xli
Subsection CC	Concrete Containments (Prestressed or Reinforced)	1
Article CC-1000	Introduction	1
CC-1100	Scope and General Requirements	1
CC-1110	Scope	1
CC-1120	General Requirements	1
CC-1130	Rules for Concrete Containments	1
CC-1140	Boundaries of Jurisdiction	1
Article CC-2000	Material	2
CC-2100	General Requirements for Material	2
CC-2110	Scope	2
CC-2120	Pressure Retaining and Load Bearing Material	2
CC-2130	Certification of Material	3
CC-2140	Deterioration of Material and Coatings During Service	4
CC-2150	Heat Treatment to Enhance Mechanical Properties of Metallic Material ..	4
CC-2160	Dimensional Standards	4
CC-2200	Concrete and Concrete Constituents	4
CC-2210	Introduction	4
CC-2220	Concrete Constituents	5
CC-2230	Concrete Mix Design	6
CC-2240	Cementitious Grout	11
CC-2250	Marking and Identification of Concrete Constituents	13
CC-2300	Material for Reinforcing Systems	13
CC-2310	Introduction	13
CC-2320	Material Identification	13
CC-2330	Special Material Testing	13
CC-2400	Material for Prestressing Systems	13
CC-2410	Introduction	13
CC-2420	Prestressing Steel	13
CC-2430	Anchorage Components	14
CC-2440	Nonload-Carrying and Accessory Materials	15
CC-2450	Performance Requirements	16
CC-2460	Performance Tests	17
CC-2470	Marking and Identification of Prestressing Material	18
CC-2500	Material for Liners	19
CC-2510	Permitted Material Specifications	19
CC-2520	Fracture Toughness Requirements for Materials	19

CC-2530	Examination and Repair of Liner Material	25
CC-2540	Material Identification	31
CC-2600	Welding Material	32
CC-2610	Welding Material Requirements	32
CC-2620	Stud Welding Material	35
CC-2630	Identification of Welding Material	40
CC-2700	Material for Embedment Anchors	40
CC-2710	Introduction	40
CC-2720	Fracture Toughness Requirements for Embedment Anchor Materials ..	40
CC-2730	Examination and Repair of Embedment Anchor Material	40
CC-2740	Marking of Embedment Anchor Material	41
CC-2800	Material Manufacturer's Quality System Programs	41
CC-2810	Documentation and Maintenance of Quality System Programs	41
Article CC-3000	Design	42
CC-3100	General Design	42
CC-3110	Concrete Containment	42
CC-3120	Metallic Liner	42
CC-3130	Definition of Terms	42
CC-3140	Tolerances	43
CC-3200	Load Criteria	43
CC-3210	General	43
CC-3220	Load Categories	43
CC-3230	Load Combinations	45
CC-3240	Load Definitions	45
CC-3300	Containment Design Analysis Procedures	45
CC-3310	General	45
CC-3320	Shells	46
CC-3330	Base Mat, Frames, Box-Type Structures, and Assemblies of Slabs	46
CC-3340	Penetrations and Openings	46
CC-3400	Concrete Containment Structure Design Allowables	46
CC-3410	General	46
CC-3420	Allowable Stress for Factored Loads	47
CC-3430	Allowable Stresses for Service Loads	53
CC-3440	Concrete Temperatures	55
CC-3500	Containment Design Details	55
CC-3510	Design for Flexure and Axial Loads	55
CC-3520	Design of Shear Reinforcement	56
CC-3530	Reinforcing Steel Requirements	58
CC-3540	Prestressed Concrete	62
CC-3550	Separation of Structures	63
CC-3560	Foundation Requirements	63
CC-3570	Containment External Anchors	63
CC-3600	Liner Design Analysis Procedures	64
CC-3610	General	64
CC-3620	Liner	64
CC-3630	Liner Anchors	64
CC-3640	Penetration Assemblies	64
CC-3650	Brackets and Attachments	64
CC-3700	Liner Design	64
CC-3710	General	64
CC-3720	Liner	64
CC-3730	Liner Anchors	65
CC-3740	Penetration Assemblies	65
CC-3750	Brackets and Attachments	65
CC-3760	Fatigue	65

CC-3800	Liner Design Details	65
CC-3810	Liner Anchors	65
CC-3820	Penetration Liners	66
CC-3830	Transitions from Concrete to Steel	66
CC-3840	Welded Construction	66
CC-3900	Design Criteria for Impulse Loadings and Missile Impact	68
CC-3910	General	68
CC-3920	Design Allowables	68
CC-3930	Design Assumptions	68
Article CC-4000	Fabrication and Construction	70
CC-4100	General Requirements	70
CC-4110	Introduction	70
CC-4120	Certification of Material and Fabrication or Construction by Component Fabricator or Constructor	70
CC-4200	Concrete	71
CC-4210	General	71
CC-4220	Storing, Batching, Mixing, and Placing	71
CC-4230	Preplaced Aggregate Concrete	72
CC-4240	Curing	72
CC-4250	Formwork and Construction Joints	72
CC-4260	Cold and Hot Weather Conditions	73
CC-4270	Repairs to Concrete	73
CC-4280	Cement Grout for Grouted Tendon Systems	73
CC-4300	Fabrication of Reinforcing Systems	73
CC-4310	General	73
CC-4320	Bending of Reinforcing Bar	73
CC-4330	Splicing of Reinforcing Bars	74
CC-4340	Placing Reinforcement	78
CC-4350	Spacing of Reinforcement	78
CC-4360	Surface Condition	78
CC-4400	Fabrication and Installation of Prestressing Systems	78
CC-4410	General	78
CC-4420	Receiving, Storing, and Handling of Material	78
CC-4430	Tendon Fabrication	79
CC-4440	Tendon Identification	79
CC-4450	Tendon Installation	79
CC-4460	Post-Tensioning	79
CC-4470	Permanent Corrosion Protection	80
CC-4500	Fabrication of Liners	80
CC-4510	General Requirements	80
CC-4520	Forming, Fitting, and Aligning	80
CC-4530	Welding Qualifications	82
CC-4540	Rules Governing Making, Examining, and Repairing Welds	86
CC-4550	Heat Treatment	99
CC-4560	Protection of Attachments	102
CC-4600	Fabrication of Embedment Anchors	102
CC-4610	General Requirements	102
CC-4620	Forming, Fitting, and Aligning	102
CC-4630	Welding Qualifications	103
CC-4640	Rules Governing Making, Examining, and Repairing Welds	104
CC-4650	Heat Treatment	104
CC-4660	Bolted Construction	104

Article CC-5000	Construction Testing and Examination	105
CC-5100	General Requirements for Examination	105
CC-5110	Procedures, Qualification, and Evaluations	105
CC-5120	Qualification and Certification of Nondestructive Examination Personnel	105
CC-5130	Qualification of Concrete Inspection and Testing Personnel	106
CC-5140	Records	106
CC-5200	Concrete Examination	106
CC-5210	General	106
CC-5220	Concrete Constituents	107
CC-5230	Concrete	110
CC-5240	Cement Grout for Grouted Tendon Systems	111
CC-5300	Examination of Reinforcing Systems	112
CC-5310	General	112
CC-5320	Examination of Mechanical Splices	112
CC-5340	Examination of Bends	112
CC-5400	Examination of Prestressing Systems	113
CC-5410	General	113
CC-5420	Required Examination	113
CC-5500	Examination of Welds	113
CC-5510	General	113
CC-5520	Required Examination of Welds	114
CC-5530	Examination Procedures	114
CC-5540	Acceptance Standards	115
Article CC-6000	Structural Integrity Test of Concrete Containments	118
CC-6100	General Requirements	118
CC-6110	Introduction	118
CC-6120	Test and Instrument Plan	118
CC-6130	Testing of Division 1 Parts, Appurtenances, and Components	118
CC-6140	Pretest Conditions	118
CC-6150	Classification of Structure	118
CC-6160	Structural Response Predictions	118
CC-6200	Test Procedure	119
CC-6210	Pretest Examination	119
CC-6220	Instrumentation	119
CC-6230	Pretest of Instrumentation	119
CC-6300	Structural Test Requirements	119
CC-6310	Introduction	119
CC-6320	Pressurization	120
CC-6330	Temperature	120
CC-6340	Data Required	120
CC-6350	Surface Cracking	120
CC-6360	Displacement Measurements	120
CC-6370	Strain Measurements	121
CC-6380	Temperature Measurements	122
CC-6390	Post-Test Examination	122
CC-6400	Evaluation of Test Results	122
CC-6410	Acceptance Criteria	122
CC-6420	Surface Cracks	122
CC-6430	Retest	122
CC-6440	Strains	122
CC-6500	Analysis of Data and Preparation of Report	122
CC-6510	Resolution of Test Data	122
CC-6520	Presentation of Data	123
CC-6530	Minimum Report Requirements	123

Article CC-7000	Overpressure Protection	124
Article CC-8000	Nameplates, Stamping with Certification Mark, and Reports	125
CC-8100	General Requirements	125
Mandatory Appendix D2-I	Tables of Prestressing and Liner Material	126
Mandatory Appendix D2-II	Glossary of Terms and Nomenclature	131
Mandatory Appendix D2-III	Approval of New Material	135
Mandatory Appendix D2-IV	Rounded Indications	137
Mandatory Appendix D2-V	Qualifications of Concrete Inspection Personnel	138
Mandatory Appendix D2-VI	Leak Testing by Vacuum Box Technique	146
Mandatory Appendix D2-VIII	Qualifications for Arc Welding Reinforcing Bars	150
Nonmandatory Appendix D2-A	Typical CRV Load Combinations (Optional)	157
Nonmandatory Appendix D2-B	Nonmandatory Preheat Procedures	158
Nonmandatory Appendix D2-C	Certification of Levels I and II Concrete Inspection Personnel	159
Nonmandatory Appendix D2-D	Liner Dimensional Tolerances	168
Nonmandatory Appendix D2-E	Certified Material Test Reports for Liner Materials	172
Nonmandatory Appendix D2-F	Reinforcement Fabrication and Placing Tolerances	174

FIGURES

CC-2462-1	Manufacturer's Record of Tendon Performance Qualification Tests	17
CC-2465-1	Record of Mechanical Test Results Obtained From Tendon Performance Qualification Tests	18
CC-2521.1-1	Determination of Permissible Lowest Service Metal Temperature	21
CC-2521.1-1M	Determination of Permissible Lowest Service Metal Temperature	22
CC-2613.3.1-1	Delta Ferrite Content	36
CC-2620-1	Dimensions and Tolerances of Standard Studs	37
CC-2620-2	Typical Tensile Test Fixture	38
CC-2620-3	Bend Testing Device	38
CC-2620-4	Typical Device for Bend Testing of Small Studs	39
CC-3421-1	Allowable Compression Stresses for Factored Loads	47
CC-3431-1	Allowable Compression Stresses for Service Loads	54
CC-3831-1	Illustration of Welded Joint Locations Typical of All Categories	67
CC-3840-1	Tapered Transition Sections	69
CC-4323-1	Allowable Bend Configuration	74
CC-4534-1	Typical Torque Testing Device	87
CC-4542.2-1	Typical Category D Joints for Nozzle Diameters Over NPS 3 (DN 80)	88
CC-4542.2-2	Typical Category D Joints for Nozzle Diameters NPS 3 (DN 80) and Less	90
CC-4542.2-3	Typical Category E Joints	92
CC-4542.2-4	Typical Category F Joints	93
CC-4542.2-5	Typical Category G Joints	93
CC-4542.2-6	Typical Category H Joints	94
CC-4542.2-7	Typical Category J Joints	95
CC-4542.9-1	Fillet and Socket Weld Dimensions	96
CC-4543.6-1	Weld Joint Producing Through-Thickness Loading	98
CC-4543.6-2	Special Deposition Technique for Weld Joint Producing Through-Thickness Loading (Typical)	99
D2-VIII-1420-1	Typical Direct Butt Splices	152
D2-D-1230-1	Measurements of Local Dimensions Per D2-F-1230	169
D2-D-1320-1	Measurement Points Per D2-F-1320	170
D2-D-1330-1	Measurement Points Per D2-F-1330	171
D2-F-1220-1	Standard Fabricating Tolerances for Bar Sizes #3 (10 mm) Through #11 (35 mm)	175

D2-F-1230-1	Standard Fabricating Tolerances for Bar Sizes #14 (43 mm) and #18 (57 mm)	178
D2-F-1320-1	Location of Reinforcement	180

TABLES

CC-2231-1	Concrete Properties	6
CC-2231.7.1-1	Exposure Categories and Classes	7
CC-2231.7.2-1	Requirements for Concrete by Exposure Class	8
CC-2231.7.3-1	Requirements for Concrete Subject to Exposure Class F3	9
CC-2231.7.4-1	Requirements for Establishing Suitability of Cementitious Materials Combinations Exposed to Water-Soluble Sulfate	9
CC-2231.7.5-1	Concrete Air Content for Various Sizes of Coarse Aggregates	9
CC-2233.1.2-1	Modification Factor for Standard Deviation When Less Than 30 Tests Are Available	9
CC-2233.2.1-1	Required Average Compressive Strength When Data are Available to Establish a Sample Standard Deviation	10
CC-2233.2.2-1	Required Average Compressive Strength When Data Are Not Available to Establish a Standard Deviation	10
CC-2442-1	Analysis Limits of Permanent Coating Material for CRV Prestressing	16
CC-2521.1-1	Exemptions From Impact Testing Under CC-2521.1(h)	20
CC-2524.2-1	Required C_v Lateral Expansion Values for Liner Material Other Than Bolting	23
CC-2524.2-2	Required C_v Energy Values for Liner Material Other Than Bolting	23
CC-2524.3(a)-1	Required C_v Values for Bolting Material Tested in Accordance With CC-2524.3(a)	24
CC-2524.3(b)-1	Required C_v Values for Bolting Material Tested in Accordance With CC-2524.3(b) and CC-2524.4	24
CC-2524.4-1	Required C_v Energy Values for Liner Material for the Overpressure Test	24
CC-2613.1-1	Sampling of Welding Materials for Chemical Analysis	34
CC-2613.2-1	Welding Material Chemical Analysis	34
CC-2623.2-1	Strength Requirements for Studs	40
CC-3136.6-1	Classification of Forces in Concrete Containments for Steel Reinforcing and Concrete Allowable Stresses	44
CC-3230-1	Load Combinations and Load Factors	46
CC-3720-1	Liner Plate Allowables	64
CC-3730-1	Liner Anchor Allowables	65
CC-4322-1	Minimum Diameter of Bend	74
CC-4333-1	Tensile Requirements for Mechanical Reinforcing Bar Splices and Welded Joints	77
CC-4523-1	Maximum Allowable Offset in Final Welded Joints	82
CC-4534-1	Required Torque for Testing Studs	87
CC-4542.8.1-1	Maximum Thicknesses Permitted	95
CC-4552-1	Mandatory Requirements for Postweld Heat Treatment (PWHT) of Welds	100
CC-4552-2	Exemptions to Mandatory PWHT	100
CC-4552-3	Alternative PWHT Temperatures	101
CC-5200-1	Minimum Testing Frequencies for Concrete Constituents and Concrete	108
D2-I-1.2	Material for Containment Prestressing Systems	126
D2-I-2.2	Material for Containment Liners	126
D2-I-2.3	Material for Embedment Anchors	130
D2-V-4100-1	Minimum Levels of Capability for Functions	143
D2-VIII-1410-1	Filler Metal Requirements	151
D2-VIII-1430-1	Minimum Preheat and Interpass Requirements	153
D2-VIII-1620-1	Radiograph Acceptance Criteria	155
ENDNOTES		181

(13)

LIST OF SECTIONS

SECTIONS

- I Rules for Construction of Power Boilers

- II Materials
 - Part A — Ferrous Material Specifications
 - Part B — Nonferrous Material Specifications
 - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
 - Part D — Properties (Customary)
 - Part D — Properties (Metric)

- III Rules for Construction of Nuclear Facility Components
 - Subsection NCA — General Requirements for Division 1 and Division 2
 - Appendices
 - Division 1
 - Subsection NB — Class 1 Components
 - Subsection NC — Class 2 Components
 - Subsection ND — Class 3 Components
 - Subsection NE — Class MC Components
 - Subsection NF — Supports
 - Subsection NG — Core Support Structures
 - Subsection NH — Class 1 Components in Elevated Temperature Service
 - Division 2 — Code for Concrete Containments
 - Division 3 — Containments for Transportation and Storage of Spent Nuclear Fuel and High Level Radioactive Material and Waste
 - Division 5 — High Temperature Reactors

- IV Rules for Construction of Heating Boilers

- V Nondestructive Examination

- VI Recommended Rules for the Care and Operation of Heating Boilers

- VII Recommended Guidelines for the Care of Power Boilers

- VIII Rules for Construction of Pressure Vessels
 - Division 1
 - Division 2 — Alternative Rules
 - Division 3 — Alternative Rules for Construction of High Pressure Vessels

- IX Welding and Brazing Qualifications

- X Fiber-Reinforced Plastic Pressure Vessels

- XI Rules for Inservice Inspection of Nuclear Power Plant Components

- XII Rules for Construction and Continued Service of Transport Tanks

INTERPRETATIONS

ASME issues written replies to inquiries concerning interpretation of technical aspects of the Code.

Interpretations of the Code are posted in January and July at <http://cstools.asme.org/interpretations.cfm>. Any Interpretations issued during the previous two calendar years are included with the publication of the applicable Section of the Code. Interpretations of Section III, Divisions 1 and 2 and Section III Appendices are included with Subsection NCA.

CODE CASES

The Boiler and Pressure Vessel Code committees meet regularly to consider proposed additions and revisions to the Code and to formulate Cases to clarify the intent of existing requirements or provide, when the need is urgent, rules for materials or constructions not covered by existing Code rules. Those Cases that have been adopted will appear in the appropriate 2013 Code Cases book: "Boilers and Pressure Vessels" or "Nuclear Components." Supplements will be sent automatically to the purchasers of the Code Cases books up to the publication of the 2015 Code.

FOREWORD

(This Foreword is provided as an aid to the user and is not part of the rules of this Code.)

In 1911, The American Society of Mechanical Engineers established the Boiler and Pressure Vessel Committee to formulate standard rules for the construction of steam boilers and other pressure vessels. In 2009, the Boiler and Pressure Vessel Committee was superseded by the following committees:

- (a) Committee on Power Boilers (I)
- (b) Committee on Materials (II)
- (c) Committee on Construction of Nuclear Facility Components (III)
- (d) Committee on Heating Boilers (IV)
- (e) Committee on Nondestructive Examination (V)
- (f) Committee on Pressure Vessels (VIII)
- (g) Committee on Welding and Brazing (IX)
- (h) Committee on Fiber-Reinforced Plastic Pressure Vessels (X)
- (i) Committee on Nuclear Inservice Inspection (XI)
- (j) Committee on Transport Tanks (XII)

Where reference is made to “the Committee” in this Foreword, each of these committees is included individually and collectively.

The Committee's function is to establish rules of safety relating only to pressure integrity, which govern the construction* of boilers, pressure vessels, transport tanks, and nuclear components, and the inservice inspection of nuclear components and transport tanks. The Committee also interprets these rules when questions arise regarding their intent. This Code does not address other safety issues relating to the construction of boilers, pressure vessels, transport tanks, or nuclear components, or the inservice inspection of nuclear components or transport tanks. Users of the Code should refer to the pertinent codes, standards, laws, regulations, or other relevant documents for safety issues other than those relating to pressure integrity. Except for Sections XI and XII, and with a few other exceptions, the rules do not, of practical necessity, reflect the likelihood and consequences of deterioration in service related to specific service fluids or external operating environments. In formulating the rules, the Committee considers the needs of users, manufacturers, and inspectors of pressure vessels. The objective of the rules is to afford reasonably certain protection of life and property, and to provide a margin for deterioration in service to give a reasonably long, safe period of usefulness. Advancements in design and materials and evidence of experience have been recognized.

This Code contains mandatory requirements, specific prohibitions, and nonmandatory guidance for construction activities and inservice inspection and testing activities. The Code does not address all aspects of these activities and those aspects that are not specifically addressed should not be considered prohibited. The Code is not a handbook and cannot replace education, experience, and the use of engineering judgment. The phrase *engineering judgement* refers to technical judgments made by knowledgeable engineers experienced in the application of the Code. Engineering judgments must be consistent with Code philosophy, and such judgments must never be used to overrule mandatory requirements or specific prohibitions of the Code.

The Committee recognizes that tools and techniques used for design and analysis change as technology progresses and expects engineers to use good judgment in the application of these tools. The designer is responsible for complying with Code rules and demonstrating compliance with Code equations when such equations are mandatory. The Code neither requires nor prohibits the use of computers for the design or analysis of components constructed to the requirements of the Code. However, designers and engineers using computer programs for design or analysis are cautioned that they are responsible for all technical assumptions inherent in the programs they use and the application of these programs to their design.

* *Construction*, as used in this Foreword, is an all-inclusive term comprising materials, design, fabrication, examination, inspection, testing, certification, and pressure relief.

The rules established by the Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way the manufacturer's freedom to choose any method of design or any form of construction that conforms to the Code rules.

The Committee meets regularly to consider revisions of the rules, new rules as dictated by technological development, Code Cases, and requests for interpretations. Only the Committee has the authority to provide official interpretations of this Code. Requests for revisions, new rules, Code Cases, or interpretations shall be addressed to the Secretary in writing and shall give full particulars in order to receive consideration and action (see Submittal of Technical Inquiries to the Boiler and Pressure Vessel Standards Committees). Proposed revisions to the Code resulting from inquiries will be presented to the Committee for appropriate action. The action of the Committee becomes effective only after confirmation by ballot of the Committee and approval by ASME. Proposed revisions to the Code approved by the Committee are submitted to the American National Standards Institute (ANSI) and published at <http://cstools.asme.org/csconnect/public/index.cfm?PublicReview=Revisions> to invite comments from all interested persons. After public review and final approval by ASME, revisions are published at regular intervals in Editions of the Code.

The Committee does not rule on whether a component shall or shall not be constructed to the provisions of the Code. The scope of each Section has been established to identify the components and parameters considered by the Committee in formulating the Code rules.

Questions or issues regarding compliance of a specific component with the Code rules are to be directed to the ASME Certificate Holder (Manufacturer). Inquiries concerning the interpretation of the Code are to be directed to the Committee. ASME is to be notified should questions arise concerning improper use of an ASME Certification Mark.

When required by context in this Section, the singular shall be interpreted as the plural, and vice versa, and the feminine, masculine, or neuter gender shall be treated as such other gender as appropriate.

STATEMENT OF POLICY ON THE USE OF THE CERTIFICATION MARK AND CODE AUTHORIZATION IN ADVERTISING

ASME has established procedures to authorize qualified organizations to perform various activities in accordance with the requirements of the ASME Boiler and Pressure Vessel Code. It is the aim of the Society to provide recognition of organizations so authorized. An organization holding authorization to perform various activities in accordance with the requirements of the Code may state this capability in its advertising literature.

Organizations that are authorized to use the Certification Mark for marking items or constructions that have been constructed and inspected in compliance with the ASME Boiler and Pressure Vessel Code are issued Certificates of Authorization. It is the aim of the Society to maintain the standing of the Certification Mark for the benefit of the users, the enforcement jurisdictions, and the holders of the Certification Mark who comply with all requirements.

Based on these objectives, the following policy has been established on the usage in advertising of facsimiles of the Certification Mark, Certificates of Authorization, and reference to Code construction. The American Society of Mechanical Engineers does not “approve,” “certify,” “rate,” or “endorse” any item, construction, or activity and there shall be no statements or implications that might so indicate. An organization holding the Certification Mark and/or a Certificate of Authorization may state in advertising literature that items, constructions, or activities “are built (produced or performed) or activities conducted in accordance with the requirements of the ASME Boiler and Pressure Vessel Code,” or “meet the requirements of the ASME Boiler and Pressure Vessel Code.” An ASME corporate logo shall not be used by any organization other than ASME.

The Certification Mark shall be used only for stamping and nameplates as specifically provided in the Code. However, facsimiles may be used for the purpose of fostering the use of such construction. Such usage may be by an association or a society, or by a holder of the Certification Mark who may also use the facsimile in advertising to show that clearly specified items will carry the Certification Mark. General usage is permitted only when all of a manufacturer’s items are constructed under the rules.

STATEMENT OF POLICY ON THE USE OF ASME MARKING TO IDENTIFY MANUFACTURED ITEMS

The ASME Boiler and Pressure Vessel Code provides rules for the construction of boilers, pressure vessels, and nuclear components. This includes requirements for materials, design, fabrication, examination, inspection, and stamping. Items constructed in accordance with all of the applicable rules of the Code are identified with the official Certification Mark described in the governing Section of the Code.

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME” or the Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code.

Items shall not be described on ASME Data Report Forms nor on similar forms referring to ASME that tend to imply that all Code requirements have been met when, in fact, they have not been. Data Report Forms covering items not fully complying with ASME requirements should not refer to ASME or they should clearly identify all exceptions to the ASME requirements.

(13) SUBMITTAL OF TECHNICAL INQUIRIES TO THE BOILER AND PRESSURE VESSEL STANDARDS COMMITTEES

1 INTRODUCTION

(a) The following information provides guidance to Code users for submitting technical inquiries to the committees. See Guideline on the Approval of New Materials Under the ASME Boiler and Pressure Vessel Code in Section II, Parts C and D for additional requirements for requests involving adding new materials to the Code. Technical inquiries include requests for revisions or additions to the Code rules, requests for Code Cases, and requests for Code Interpretations, as described below.

(1) *Code Revisions.* Code revisions are considered to accommodate technological developments, address administrative requirements, incorporate Code Cases, or to clarify Code intent.

(2) *Code Cases.* Code Cases represent alternatives or additions to existing Code rules. Code Cases are written as a question and reply, and are usually intended to be incorporated into the Code at a later date. When used, Code Cases prescribe mandatory requirements in the same sense as the text of the Code. However, users are cautioned that not all jurisdictions or owners automatically accept Code Cases. The most common applications for Code Cases are:

(-a) to permit early implementation of an approved Code revision based on an urgent need

(-b) to permit the use of a new material for Code construction

(-c) to gain experience with new materials or alternative rules prior to incorporation directly into the Code

(3) *Code Interpretations.* Code Interpretations provide clarification of the meaning of existing rules in the Code, and are also presented in question and reply format. Interpretations do not introduce new requirements. In cases where existing Code text does not fully convey the meaning that was intended, and revision of the rules is required to support an interpretation, an Intent Interpretation will be issued and the Code will be revised.

(b) The Code rules, Code Cases, and Code Interpretations established by the committees are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code rules.

(c) Inquiries that do not comply with these provisions or that do not provide sufficient information for a committee's full understanding may result in the request being returned to the inquirer with no action.

2 INQUIRY FORMAT

Submittals to a committee shall include:

(a) *Purpose.* Specify one of the following:

(1) revision of present Code rules

(2) new or additional Code rules

(3) Code Case

(4) Code Interpretation

(b) *Background.* Provide the information needed for the committee's understanding of the inquiry, being sure to include reference to the applicable Code Section, Division, Edition, Addenda (if applicable), paragraphs, figures, and tables. Preferably, provide a copy of the specific referenced portions of the Code.

(c) *Presentations.* The inquirer may desire or be asked to attend a meeting of the committee to make a formal presentation or to answer questions from the committee members with regard to the inquiry. Attendance at a committee meeting shall be at the expense of the inquirer. The inquirer's attendance or lack of attendance at a meeting shall not be a basis for acceptance or rejection of the inquiry by the committee.