

PD ISO/TR 16732-3:2013



BSI Standards Publication

# Fire safety engineering — Fire risk assessment

Part 3: Example of an industrial property

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

*raising standards worldwide™*



**National foreword**

This Published Document is the UK implementation of ISO/TR 16732-3:2013.

The UK participation in its preparation was entrusted to Technical Committee FSH/24, Fire safety engineering.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013.

Published by BSI Standards Limited 2013

ISBN 978 0 580 80188 4

ICS 13.220.01

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 May 2013.

**Amendments issued since publication**

Date	Text affected
------	---------------

---

# TECHNICAL REPORT

# ISO/TR 16732-3

First edition  
2013-02-15

---

---

## Fire safety engineering — Fire risk assessment —

### Part 3: Example of an industrial property

*Ingénierie de la sécurité incendie — Évaluation du risque d'incendie —  
Partie 3: Exemple d'un complexe industriel*



Reference number  
ISO/TR 16732-3:2013(E)

© ISO 2013



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Applicability of fire risk assessment</b> .....	<b>2</b>
<b>5 Overview of fire risk management</b> .....	<b>2</b>
5.1 General.....	2
5.2 Overall description of the industrial facility.....	2
5.3 Phenomenology of a BLEVE.....	3
5.4 Risk reduction measures.....	5
5.5 Presentation of design options.....	5
<b>6 Steps in fire risk estimation</b> .....	<b>8</b>
6.1 Overview of fire risk estimation.....	8
6.2 Use of scenarios in fire risk assessment.....	8
6.3 Estimation of frequency and probability.....	11
6.4 Estimation of consequence.....	13
6.5 Calculation of scenario fire risk and combined fire risk.....	13
<b>7 Uncertainty, sensitivity, precision, and bias</b> .....	<b>18</b>
<b>8 Fire risk evaluation</b> .....	<b>19</b>
8.1 Individual and societal risk.....	19
8.2 Risk acceptance criteria.....	19
8.3 Safety factors and safety margins.....	20
<b>Bibliography</b> .....	<b>21</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

In exceptional circumstances, when a technical committee has collected data of a different kind from that which is normally published as an International Standard ("state of the art", for example), it may decide by a simple majority vote of its participating members to publish a Technical Report. A Technical Report is entirely informative in nature and does not have to be reviewed until the data it provides are considered to be no longer valid or useful.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO/TR 16732-3 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 4, *Fire safety engineering*.

ISO 16732 consists of the following parts, under the general title *Fire safety engineering — Fire risk assessment*:

- *Part 1: General*
- *Part 2: Example of an office building* [Technical Report]
- *Part 3: Example of an industrial property* [Technical Report]

## Introduction

This part of ISO/TR 16732 presents an example of the application of ISO 16732-1, prepared in the format of ISO 16732-1. It includes only those sections of ISO 16732-1 that describe steps in the fire risk assessment procedure. It preserves the numbering of sections in ISO 16732-1 and so omits numbered sections for which there is no text or information for this example.

This example is intended to illustrate the implementation of the steps of fire risk assessment, as defined in ISO 16732-1. Only steps that are considered as relevant in this example are well detailed in this annex.

Risk assessment is preceded by two steps – establishment of the context, including the fire safety objectives to be met, the subjects of the fire risk assessment to be performed and related facts or assumptions; and identification of the various hazards to be assessed. (A “hazard” is something with the potential to cause harm.)

Assumptions made in the present document have been chosen to illustrate, in a simple manner, how the fire risk assessment methodology proposed in ISO 16732-1 can be applied to an industrial facility. These assumptions must be regarded as examples only, and not be applied to other cases without verifying they are representative of the considered cases.





# Fire safety engineering — Fire risk assessment —

## Part 3: Example of an industrial property

### 1 Scope

This part of ISO/TR 16732 deals with a fictitious propane storage facility dedicated to the reception of propane transported by tank wagons, the storage of propane in a pressurized vessel and the bulk shipment of propane by tank trucks. The fire risk assessment developed in this part of ISO/TR 16732 is not intended to be exhaustive, but is given as an example to illustrate the application of ISO 16732-1 to an industrial facility.

The scope of this part of ISO/TR 16732 is further limited to design-phase strategies, including changes to the layout of the facility and selection of relevant fire safety strategies (implementation of risk reduction measures). Not included are strategies that operate during the operation phase, including process modifications.

This part of ISO/TR 16732 illustrates the value of fire risk assessment because multiple scenarios are analysed, and several design options are available, which may perform well or not depending on the considered scenario. Risk estimation is needed to determine the result of these different combinations, and overall measures of performance that can be compared between design options. If there were only one scenario of interest, or if the options all tended to perform the same way on all the scenarios, then a simpler type of engineering analysis would suffice.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 16732-1:2012, *Fire safety engineering — Fire risk assessment — Part 1: General*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16732-1 and the following apply.

#### 3.1

##### **BLEVE**

##### **Boiling Liquid Expanding Vapour Explosion**

phenomenon which occurs when a vessel containing a pressurized liquid substantially above its (atmospheric) boiling point is ruptured, releasing the contents explosively

Note 1 to entry: Taken from Reference [1].

Note 2 to entry: A more detailed description of phenomena involved during a BLEVE is given in 5.3.

#### 3.2

##### **flashing vaporization**

rapid transformation into vapor that is released when a saturated liquid stream undergoes a reduction in pressure