

**ASME B16.21-2021**  
(Revision of ASME B16.21-2016)

# **Nonmetallic Flat Gaskets for Pipe Flanges**

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

**ASME B16.21-2021**  
(Revision of ASME B16.21-2016)

# **Nonmetallic Flat Gaskets for Pipe Flanges**

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: January 21, 2022

The next edition of this Standard is scheduled for publication in 2026.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME B16 Committee may be published as Cases. Cases and interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2022 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved  
Printed in U.S.A.

# CONTENTS

Foreword .....		iv
Committee Roster .....		v
Correspondence With the B16 Committee .....		vi
Summary of Changes .....		viii
List of Changes in Record Number Order .....		ix
<b>1</b>	<b>Scope .....</b>	<b>1</b>
<b>2</b>	<b>General .....</b>	<b>1</b>
<b>3</b>	<b>Materials .....</b>	<b>1</b>
<b>4</b>	<b>Dimensions and Tolerances .....</b>	<b>2</b>
<b>5</b>	<b>Markings .....</b>	<b>2</b>
 <b>Mandatory Appendix</b>		
I	References .....	10
 <b>Nonmandatory Appendices</b>		
A	Quality System Program .....	11
B	Additional Reference .....	12
 <b>Tables</b>		
4.1-1	Gasket Dimensions for ASME B16.1 Class 25, Cast Iron Pipe Flanges and Flanged Fittings . . .	3
4.1-2	Gasket Dimensions for ASME B16.1 Class 125, Cast Iron Pipe Flanges and Flanged Fittings . .	4
4.1-3	Flat Ring Gasket Dimensions for ASME B16.1 Class 250, Cast Iron Pipe Flanges and Flanged Fittings	5
4.1-4	Gasket Dimensions for ASME B16.5 Class 150, Pipe Flanges and Flanged Fittings . . . . .	6
4.1-5	Flat Ring Gasket Dimensions for ASME B16.5, Pipe Flanges and Flanged Fittings, Classes 300, 400, 600, and 900 .....	7
4.1-6	Full Face Gasket Dimensions for ASME B16.24, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Classes 150 and 300 .....	7
4.1-7	Flat Ring Gasket Dimensions for ASME B16.47 Series A, Large Diameter Steel Flanges, Classes 150, 300, 400, and 600 .....	8
4.1-8	Flat Ring Gasket Dimensions for ASME B16.47 Series B, Large Diameter Steel Flanges, Classes 75, 150, 300, 400, and 600 .....	8
4.1-9	Full Face Gasket Dimensions for MSS SP-51 Class 150LW, Corrosion-Resistant Cast Flanges and Flanged Fittings .....	9

# FOREWORD

Before this Standard was issued, the individual sizes of gaskets were made to many different sets of dimensions, based on different concepts of adaptation and functional use on the part of consumers as well as manufacturers. In some cases, dimensions were shown in American Standards. To standardize gasket sizes, the Standards and Specifications Committee of the Mechanical Packing Association (MPA) started work on a standard for nonmetallic or cut gaskets for bronze, iron, and steel pipe flanges.

Dimensions of gaskets being used were collected, and a basic design philosophy for sizing was formulated by the Committee. This was the result of extensive field research experience and accepted standard user requirements. The procedure that followed was to dimension the gasket for each type and size of flange so as to prevent the gasket from projecting into the line of flow. Dimensional tolerances of standard pipe flanges and fittings as to I.D., O.D., and bolting were all considered.

Suggested dimensional standards were tabulated and distributed for industry comment. After several revisions, a final draft, dated September 15, 1948, was approved by the MPA for submission as an American Standard.

Sectional Committee (B16) on the Standardization of Pipe Flanges and Fittings was organized in 1921 under the procedure of the American Standards Association (ASA), with the Heating, Piping, and Air Conditioning Contractors' National Association [now Mechanical Contractors Association of America (MCAA)], Manufacturers' Standardization Society of the Valve and Fittings Industry (MSS), and The American Society of Mechanical Engineers (ASME) as joint sponsors.

Sectional Committee B16 received the proposal on May 9, 1949, and assigned it to a joint group of Subcommittees 1 and 3. The MSS was also consulted as the proposal included gaskets for bronze flanges made to their Standard Practice SP-2. This joint group offered a revision of the original design concept for sizing, which was acceptable to the MPA's Committee [now the Fluid Sealing Association (FSA)]. The Standard was approved as an American Standard on December 5, 1951, with the designation ASA B16.21-1951.

In 1961, the Standard was reviewed by the members of Subcommittee No. 7 on Gaskets and proposals for revision and updating the Standard were agreed upon. The ASA granted approval of the revision on March 20, 1962.

In the mid-1960s, work had begun on a revision. The revision became a complete rewrite and included gaskets for API Std 605, MSS SP-44 and SP-51, as well as complete metric equivalents for all dimensions. The American National Standards Institute (ANSI) approved the revised standard as an American National Standard on May 2, 1978.

In 1982, American National Standards Committee B16 was reorganized as an ASME Committee operating under procedures accredited by ANSI.

In 1989, general revisions had begun to reflect the current size ranges covered by the corresponding flange standard. Gasket dimensions for tongue and groove, male and female rating classes above 900 were deleted because a survey indicated these nonmetallic gaskets were almost never used for these joints. Tolerances to the dimensions were added. ANSI approved the edition as an American National Standard, with the new designation ASME B16.21-1992, on March 16, 1992.

In 2005, the Standard adopted metric (SI) dimensions. ANSI approved this American National Standard on March 16, 2005.

The 2011 edition included revisions to paragraph numbering and adjustments of appendices. ANSI approved it as an American National Standard on January 13, 2011.

In the 2016 edition, Table 9 was expanded to include values greater than NPS 12. Following approval by the ASME B16 Standards Committee, ANSI approved the 2016 edition as an American National Standard, with the designation ASME B16.21-2016, on October 11, 2016.

In this 2021 edition, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. Also in this edition, NPS 22 has been added to [Tables 4.1-4](#) (formerly Tables 4 and I-4) and [4.1-5](#) (formerly Tables 5 and I-5) and deleted from [Table 4.1-7](#) (formerly Tables 7 and I-7). Following approval by the ASME B16 Standards Committee, ASME B16.21-2021 was approved by ANSI on December 7, 2021.

# ASME B16 COMMITTEE

## Standardization of Valves, Flanges, Fittings, and Gaskets

(The following is the roster of the Committee at the time of approval of this Standard.)

### STANDARDS COMMITTEE OFFICERS

**C. E. Davila**, *Chair*  
**R. M. Bojarczuk**, *Vice Chair*  
**S. J. Rossi**, *Secretary*

### STANDARDS COMMITTEE PERSONNEL

<b>A. Appleton</b> , Alloy Stainless Products Co., Inc.	<b>E. J. Lain</b> , Exelon Nuclear
<b>J. E. Barker</b> , DeZURIK, Inc.	<b>T. A. McMahon</b> , Emerson Automation Solutions
<b>R. W. Barnes</b> , ANRIC Enterprises, Inc.	<b>R. C. Merrick</b> , Consultant
<b>D. C. Bayreuther</b> , Neles Corp.	<b>W. H. Patrick</b> , Dow Chemical Co.
<b>W. B. Bedesem</b> , Consultant	<b>D. W. Raho</b> , CCM 2000
<b>R. M. Bojarczuk</b> , Retired	<b>D. F. Reid</b> , VSP Technologies
<b>A. M. Cheta</b> , Shell Global Solutions (U.S.)	<b>S. J. Rossi</b> , The American Society of Mechanical Engineers
<b>M. A. Clark</b> , NIBCO, Inc.	<b>R. A. Schmidt</b> , Canadoil
<b>G. A. Cuccio</b> , Capitol Manufacturing Co.	<b>J. Sekerak</b> , CSA Group
<b>C. E. Davila</b> , Crane Chempharma and Energy	<b>F. R. Volgstadt</b> , Volgstadt and Associates, Inc.
<b>K. S. Felder</b> , Valero Energy	<b>F. Feng</b> , <i>Delegate</i> , China Productivity Center for Machinery
<b>D. R. Frikken</b> , Becht Engineering Co., Inc.	<b>P. V. Craig</b> , <i>Contributing Member</i> , Jomar Group
<b>J. Holstrom</b> , Val-Matic Valve and Manufacturing Corp.	<b>B. G. Fabian</b> , <i>Contributing Member</i> , Pennsylvania Machine Works
<b>D. Hunt, Jr.</b> , Fastenal	<b>A. G. Kireta, Jr.</b> , <i>Contributing Member</i> , Copper Development Association, Inc.
<b>G. A. Jolly</b> , Samshin Ltd.	

### SUBCOMMITTEE G — GASKETS FOR FLANGED JOINTS

<b>E. J. Lain</b> , <i>Chair</i> , Exelon Nuclear	<b>K. E. Guenther</b> , Shell
<b>J. Baulch</b> , <i>Vice Chair</i> , Teadit North America	<b>E. Jamalyaria</b> , Flexitallic Engineering
<b>A. Carrion</b> , <i>Secretary</i> , The American Society of Mechanical Engineers	<b>Y. Li</b> , Flexitallic, L.P.
<b>C. A. Arnett</b> , Amtec North America, Inc.	<b>L. Melvin</b> , Gasket Resources, Inc.
<b>R. M. Bojarczuk</b> , Retired	<b>R. T. Mueller</b> , Consultant
<b>G. Briggs</b> , James Walker Mooreflex	<b>B. Pourchot</b> , SGL Group
<b>M. Bush</b> , Marathon Petroleum Corp.	<b>D. F. Reid</b> , VSP Technologies
<b>D. E. Clover</b> , ERIKS North America	<b>M. Ruffin</b> , Chevron
<b>K. S. Felder</b> , Valero Energy	<b>S. Szemanek</b> , Marathon Petroleum Corp.
<b>L. Fernandes</b> , Garlock Sealing Technologies	<b>R. Taylor</b> , 3S Superior Sealing Service
<b>P. R. Francis</b> , Miami Valley Gasket	<b>C. Yoder</b> , <i>Alternate</i> , Garlock Sealing Technologies
<b>D. R. Frikken</b> , Becht Engineering Co., Inc.	

# CORRESPONDENCE WITH THE B16 COMMITTEE

**General.** ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B16 Standards Committee  
The American Society of Mechanical Engineers  
Two Park Avenue  
New York, NY 10016-5990  
<http://go.asme.org/Inquiry>

**Proposing Revisions.** Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

**Proposing a Case.** Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

**Interpretations.** Upon request, the B16 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the B16 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/InterpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may e-mail the request to the Secretary of the B16 Standards Committee at [SecretaryB16@asme.org](mailto:SecretaryB16@asme.org), or mail it to the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

- Subject: Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
- Edition: Cite the applicable edition of the Standard for which the interpretation is being requested.
- Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a “yes” or “no” reply is acceptable.
- Proposed Reply(ies): Provide a proposed reply(ies) in the form of “Yes” or “No,” with explanation as needed. If entering replies to more than one question, please number the questions and replies.
- Background Information: Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the Inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

**Attending Committee Meetings.** The B16 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B16 Standards Committee.



# ASME B16.21-2021

## SUMMARY OF CHANGES

Following approval by the ASME B16 Standards Committee and ASME, and after public review, ASME B16.21-2021 was approved by the American National Standards Institute on December 7, 2021.

In ASME B16.21-2021, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. In addition, this edition includes the following changes identified by a margin note, **(21)**. The Record Number listed below is explained in more detail in the “List of Changes in Record Number Order” following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
6	Table 4.1-4	NPS 22 added (21-1954)
7	Table 4.1-5	NPS 22 added (21-1954)
8	Table 4.1-7	NPS 22 and Note (1) deleted (21-1954)
12	Nonmandatory Appendix B	Title editorially revised

# LIST OF CHANGES IN RECORD NUMBER ORDER

<u>Record Number</u>	<u>Changes</u>
21-1954	Inserted NPS 22 in Tables 4.1-4 (former Tables 4 and I-4) and 4.1-5 (former Tables 5 and I-5). Deleted NPS 22 and Note (1) from Table 4.1-7 (former Tables 7 and I-7).

INTENTIONALLY LEFT BLANK

# NONMETALLIC FLAT GASKETS FOR PIPE FLANGES

## 1 SCOPE

This Standard covers types, sizes, materials, dimensions, tolerances, and markings for nonmetallic flat gaskets. These gaskets are dimensionally suitable for use with flanges described in the referenced flange standards.

## 2 GENERAL

### 2.1 Relevant Units

This Standard states values both in SI (metric) and U.S. Customary units. As an exception, diameter of bolts and flange bolt holes are expressed in inch units only. These systems of units are to be regarded separately as standard. In this Standard, the U.S. Customary units are shown in parentheses. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Except for diameter of bolts and flange bolt holes, combining values from the two systems constitutes nonconformance with the Standard.

### 2.2 Quality Systems

Requirements relating to the product manufacturers' quality system programs are described in [Nonmandatory Appendix A](#).

### 2.3 References

Standards and specifications adopted by reference in this Standard are shown in [Mandatory Appendix I](#).

### 2.4 Flanged Joints

A flanged joint is composed of separate and independent, although interrelated, components: the flanges, gasket, and bolting, which are assembled by another influence, the assembler. Proper controls must be exercised in the selection and application for all these elements to attain a joint that has acceptable leak tightness. Additional guidelines for flange assembly can be found in ASME PCC-1 (see [Nonmandatory Appendix B](#)).

### 2.5 Types

Dimensions are provided for the following types of gaskets, which are suitable for use with the flange faces indicated:

Gasket Type	Flange Facing
Full face	Flat face
Flat ring	Raised face

### 2.6 Size

NPS, followed by a dimensionless number, is the designation for nominal pipe size, as described in ASME B36.10M and is related to the reference nominal diameter, DN, used in international standards. The relationship is as follows:

NPS	DN
$\frac{1}{2}$	15
$\frac{3}{4}$	20
1	25
$1\frac{1}{4}$	32
$1\frac{1}{2}$	40
2	50
$2\frac{1}{2}$	65
3	80
$3\frac{1}{2}$	90
4	100

GENERAL NOTE: For NPS  $\geq 4$ , the related DN = 25 × NPS.

### 2.7 Pressure Class Designation

Class, followed by a dimensionless number, is the designation for common flange pressure-temperature ratings as given by the referenced flange standards.

## 3 MATERIALS

### 3.1 Composition

Gaskets shall be made of resilient or pliable materials. Metal or nonmetal composites may be incorporated as reinforcement or filler material.

### 3.2 Service Requirements

Selection of a material suitable for a given service application is the responsibility of the user subject to the requirements of any applicable code or government regulation. The material selected shall be compatible