


*NSF International Standard /
American National Standard /
National Standard of Canada*

NSF/ANSI/CAN 61 - 2022

Drinking Water System Components - Health Effects



NSF International, an independent, not-for-profit, nongovernmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

This standard is subject to revision.
Contact NSF to confirm this revision is current.

Users of this standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Additives – System Components
c/o NSF International
789 North Dixboro Road, P.O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Fax: (734) 769-0109
Email: info@nsf.org
Web: www.nsf.org

NSF International Standard /
American National Standard /
National Standard of Canada
for Drinking Water Additives –

**Drinking Water System Components –
Health Effects**

Standard Developer
NSF International

ICS 13.060.20

Designated as an ANSI Standard
March 15, 2022
American National Standards Institute

Designated as a National Standard of Canada
March 15, 2022
Standards Council of Canada

Prepared by
The NSF Joint Committee on Drinking Water Additives

Recommended for adoption by
The NSF Council of Public Health Consultants

Adopted by
NSF International
June 1988

Revised October 1988
Revised May 1992
Revised July 1996
Revised January 1997
Revised November 1998
Revised September 2000
Revised July 2002
Revised November 2004
Revised March 2007
Revised December 2008
Revised October 2010
Revised July 2012
Revised September 2014
Revised July 2016
Revised February 2019
Revised November 2021

Revised May 1990
Revised September 1994
Revised September 1996
Revised March 1997
Revised January 1999
Revised February 2001
Addendum August 2002
Addendum March 2005
Revised July 2007
Revised August 2009
Revised June 2001
Addendum March 2013
Revised February 2015
Addendum January 2017
Revised October 2019
Revised August 2022

Revised May 1991
Revised January 1995
Revised November 1996
Revised July 1997
Revised November 1999
Addendum September 2001
Editorial revision October 2003
Revised October 2005
Addendum October 2007
Revised February 2010
Addendum March 2012
Revised January 2014
Revised October 2015
Revised October 2017
Revised July 2020

Published by
NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this standard, please reference the designation
"NSF/ANSI/CAN 61 – 2022."

Cette Norme Nationale du Canada est disponible en versions Française et Anglaise.

Copyright 2022 NSF International

Previous editions © 2021, 2020, 2019, 2017, 2016, 2015, 2014, 2013, 2012, 2011, 2010, 2009, 2008, 2007,
2005, 2004, 2003, 2002, 2001, 2000, 1999, 1998, 1997, 1996, 1995, 1994, 1992, 1991, 1990, 1988

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any
means, electronic or mechanical, including photocopying and microfilm, without permission in writing from
NSF International.

Printed in the United States of America.

Disclaimers¹

NSF International (NSF), in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this standard. It is the responsibility of the user of this standard to judge the suitability of the ANS for the user's purpose.

Participation in NSF standards development activities by regulatory agency representatives (federal, state, or local) shall not constitute their agency's endorsement of NSF or any of its standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include all requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

At the time of this publication, examples of programs and processes were provided for general guidance. This information is given for the convenience of users of this standard and does not constitute an endorsement by NSF International. Equivalent programs and processes may be used.

Unless otherwise referenced, the annexes are not considered an integral part of NSF standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.

Abbreviations

The following table is provided as a reference for unit abbreviations for common forms of measurement used within NSF documents.

time	second	s
	minute	min
	hour	h
	day	d
	week	wk
	month	mo
	year	yr
length	inch	in
	foot	ft
	yard	yd
	rod	rd
	mile	mi
	micrometer	μm
	nanometer	nm
	millimeter	mm
	centimeter	cm
	meter	m
kilometer	km	
liquid measure	milliliter	mL
	liter	L
	liters per day	LPD
	liters per minute	LPM
	ounce	oz
	pint	pt
	quart	qt
	gallon	gal
	gallons per minute	GPM
gallons per day	GPD	
weight	microgram	μg
	picogram	pg
	nanogram	ng
	milligram	mg
	centigram	cg
	gram	g
	kilogram	kg
	pounds	lb
	tons	t
	metric tons	mt

Contents

- 1 General 1
 - 1.1 Purpose..... 1
 - 1.2 Scope 1
 - 1.3 Normative references 1
 - 1.4 Limitations 3
 - 1.5 Alternate products or materials 4
 - 1.6 Significant figures and rounding 4
- 2 Definitions 4
- 3 General requirements 6
 - 3.1 General 6
 - 3.2 Information and formulation requirements 6
 - 3.3 Identification of analytes 9
 - 3.4 Products manufactured from Annex N-2 acceptable materials 10
 - 3.5 Restriction on use of lead containing materials 17
 - 3.6 Lead content of products 17
- 4 Pipes and related products 17
 - 4.1 Scope 17
 - 4.2 Definitions 18
 - 4.3 General requirements 18
 - 4.4 Sample requirements..... 18
 - 4.5 Extraction procedures 19
 - 4.6 Analysis..... 24
 - 4.7 Normalization of contaminant concentrations..... 24
 - 4.8 Evaluation of contaminant concentrations 26
- 5 Barrier materials 32
 - 5.1 Scope 32
 - 5.2 Definitions 32
 - 5.3 General requirements 33
 - 5.4 Sample requirements..... 33
 - 5.5 Extraction procedures 34
 - 5.6 Analysis of extraction water 38
 - 5.7 Normalization 38
 - 5.8 Evaluation of contaminant concentrations 41
- 6 Joining and sealing materials 46
 - 6.1 Coverage 46
 - 6.2 Definitions 46
 - 6.3 Material and extraction testing requirements..... 46
 - 6.4 Items of special significance 47
- 7 Process media 47
 - 7.1 Scope 47
 - 7.2 Definitions 47
 - 7.3 General requirements 48
 - 7.4 Sample requirements..... 50
 - 7.5 Extraction procedures 50
 - 7.6 Analysis..... 53
 - 7.7 Normalization 53
 - 7.8 Evaluation of contaminant concentrations 55

8 Mechanical devices 59

8.1 Coverage 59

8.2 Definitions 59

8.3 Device, component, or material requirements 59

8.4 In-line devices, components, and materials 60

8.5 POE systems, components, and media 61

8.6 Chemical feeders and generators 61

8.7 Other mechanical devices, components, and materials 62

9 Mechanical plumbing devices 64

9.1 Coverage 64

9.2 Definitions 65

9.3 Device, component, or material requirements 66

9.4 Exposure and normalization 66

9.5 Evaluation of normalized contaminant concentrations 67

10 Instructions and information 68

Normative Annex 1 Product / material evaluation 69

N-1.1 Background 69

N-1.2 General evaluation requirements 69

N-1.3 Joining and sealing materials 72

N-1.4 Mechanical devices 74

N-1.5 Mechanical plumbing devices 79

N-1.6 Collection and preservation of extraction media after exposure 81

N-1.7 Analysis methods 82

N-1.8 Normalization 89

N-1.9 Extraction water preparation 95

Normative Annex 2 Acceptable materials 113

N-2.1 Purpose 113

N-2.2 Evaluation of acceptable materials 113

N-2.3 Extraction testing 113

N-2.4 Documentation 113

Informative Annex 1 Toxicology review and evaluation procedures 119

Informative Annex 2 Normative drinking water criteria 121

Informative Annex 3 Informational drinking water criteria 123

Informative Annex 4 Revisions to the evaluation of lead 125

Informative Annex 5 Weighted average lead content evaluation procedure to a 0.25%
lead requirement 127

Informative Annex 6 Water quality criteria considerations for piping materials in contact with
drinking water 129

I-6.1 Background 129

I-6.2 Criteria (by material type) 129

I-6.3 Determining HCO_3^- concentration from alkalinity using Standard Methods 4500- CO_2
Carbon Dioxide (Editorial revisions, 2011) 132

Informative Annex 7 Revisions to the evaluation of lead 135

I-7.1 Background 135

I-7.2 Incorporation of revisions into Standard 135

I-7.3 Revisions 136

Interpretation Annex..... 139

This page is intentionally left blank.

Foreword²

In response to a competitive request for proposals from the U.S. Environmental Protection Agency (U.S. EPA), a consortium led by NSF International (NSF) agreed to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the consortium include the American Water Works Association Research Foundation (WRF), the Association of State Drinking Water Administrators (ASDWA), the Conference of State Health and Environmental Managers (COSHEM), and the American Water Works Association (AWWA). (COSHEM has since become inactive as an organization.) Each organization was represented on a steering committee with oversight responsibility for the administration of the cooperative agreement. The Steering Committee provides guidance on overall administration and management of the cooperative agreement. Currently, the member organizations remain active in an oversight role.

Two standards for additives products have been adopted. NSF/ANSI/CAN 60: *Drinking Water Treatment Chemicals — Health Effects* covers many of the water treatment chemicals, also known as direct additives. This standard, NSF/ANSI/CAN 61, covers all indirect additives products and materials. Testing to determine the potential of a product to impart taste and/or odor to drinking water is not included in this standard.

NSF/ANSI/CAN 61, and subsequent product certification against it, has replaced the U.S. EPA Additives Advisory Program for drinking water system components. U.S. EPA terminated its advisory role in April 1990. For more information with regard to U.S. EPA's actions, refer to the July 7, 1988 *Federal Register* (53FR25586).

NSF/ANSI/CAN 61 was developed to establish minimum requirements for the control of potential adverse human health effects from products that contact drinking water. It does not attempt to include product performance requirements that are currently addressed in other voluntary consensus standards established by such organizations as the AWWA, ASTM International, and the American National Standards Institute (ANSI). Because this standard complements the performance standards of these organizations, it is recommended that products also meet the appropriate performance requirements specified in the standards of such organizations.

Water age can be a major factor in the deterioration of water quality within plumbing systems affecting issues of both public health and aesthetic concerns. With increased water age is an increased potential for the formation of disinfection by-products, increased corrosion, and an increased potential for microbial regrowth. It can also lead to a loss in the effectiveness of corrosion control measures and an increased potential for nitrification of the water.

Within NSF/ANSI/CAN 61, most extraction protocols result in exposure periods between 12 to 24 hours. While these are appropriate for typical drinking water system use, they can be significantly less than in others. Examples of where high water age can occur include:

- water storage tanks in rain water catchment systems where the duration may be weeks or months;
- plumbing system designs in green buildings which result of overall reduction in water usage without a change in piping design to minimize stagnation;
- buildings where stagnant periods occur due to nonuse such as schools between semesters, vacation homes, or seasonal buildings; and
- products on isolated lines with either long or oversized piping resulting low water turnover.

² The information contained in this foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.

NSF/ANSI/CAN 61 compliant products are often specified in these applications yet the potential accumulation of leachates over extended periods of exposure may or may not be addressed though this standard. It is important that the design of drinking water plumbing systems take into account potentials for extended aging of water. This may include the flushing of the water piping system after extended periods of nonuse. It is also important for managers of the drinking systems in buildings be aware of the potential for high water age and proactively manage the system to minimize it.

This standard and the accompanying text are intended for voluntary use by certifying organizations, utilities, regulatory agencies, and/or manufacturers as a basis of providing assurances that adequate health protection exists for covered products. Product certification issues, including frequency of testing and requirements for follow-up testing, evaluation, enforcement, and other policy issues, are not addressed by this standard.

In 2020, the Joint Committee developed proposed changes designed to increase the public health protection of this standard relative to the evaluation of lead leaching from endpoint devices. Due to the significant impact of these changes, the Joint Committee has established an extended effective date for the requirement to become mandatory on January 1, 2024. This effective date was selected to provide manufacturers a reasonable time to reengineer products to meet the new requirements, to have them tested, and to make them available in the marketplace. This date is based on the date of product manufacture. Manufacturers and certifiers are encouraged to actively pursue conformance to the new requirement prior to January 1, 2024. For clarity, the Joint Committee has placed the pending requirements in an informative annex.

All references to gallons (gal) are in U.S. gallons.

This standard is designated as a National Standard of Canada (NSC) in compliance with requirements and guidance set out by the Standards Council of Canada (SCC).

This edition of the standard contains the following revisions:

Issue 160

The revision includes clarification on Q statistic testing for non-lead materials to reflect current practice.

Issue 161

The revision adds six brass rod alloys to the list of acceptable materials for lead leaching under Annex N-2 of NSF/ANSI/CAN 61.

Issue 162

The revision clarifies language in both Sections 9.1 and 9.1.2.

Issue 163

The revision adds language to reflect the requirements for well packing media in Section 7.

The interpretations annex contains responses to interpretation requests. The responses will be published in each version of the standard until such time that the interpretation response is no longer applicable.

This standard was developed by the NSF Joint Committee on Drinking Water Additives – System Components using the consensus process described by the American National Standards Institute and the Standards Council of Canada’s *Requirements and Guidance*. At the time of approval, the Joint Committee consisted of 9 public health / regulatory, 11 industry, 7 product certifier / testing lab, and 8 user representatives.

Suggestions for improvement of this standard are welcome. This standard is maintained on a continuous maintenance schedule and can be opened for comment at any time. Comments should be sent to: Chair, Joint Committee on Drinking Water Additives – System Components at standards@nsf.org, or c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

This page is intentionally left blank.

SCC Foreword

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited standards development organization, in compliance with requirements and guidance set out by the SCC. More information on National Standards of Canada can be found at <www.scc.ca>.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at <www.scc.ca>.

Consortium organizations

NSF International

Popularly referred to as NSF, NSF International is a noncommercial agency. It is incorporated under the laws of Michigan as a not-for-profit organization devoted to research, education, and service. It seeks to solve problems involving man and his environment. It wishes to promote health and enrich the quality of life through conserving and improving that environment. Its fundamental principle of operation is to serve as a neutral medium in which business and industry, official regulatory agencies, and the public come together to deal with problems involving products, equipment, procedures, and services related to health and the environment. It is conceived and administered as a public service organization.

NSF is perhaps best known for its role in developing standards and criteria for equipment, products, and services that bear upon health. NSF was the lead organization in the consortium responsible for developing this standard. NSF conducts research; tests and evaluates equipment, products, and services for compliance with standards and criteria; and grants and controls the use of NSF registered marks.

NSF offers product certification (listing services) for all products covered by its standards. Each program has established policies governing the associated product evaluation, listing services, follow-up, and enforcement activities. The NSF listing mark is widely recognized as a sign that the product or service to which it relates complies with the applicable NSF standard(s).

Water Research Foundation

The mission of the American Water Works Association Research Foundation (now the Water Research Foundation), is to sponsor practical, applied research on behalf of the drinking water industry of North America. The scope of the research program embraces all aspects of water supply operation, from development and maintenance of water resources to treatment technologies and water quality issues, from storage and distribution system operations to health effects studies and utility planning and management activities. Water Research Foundation (WRF) serves as the centralized industry institution for planning, managing, and funding cooperative research and development in drinking water, including the subsequent transfer of technology and results for practical application by the water utility community.

WRF's purpose in this cooperative program is to provide a communication link with the water utilities throughout North America and serve as the focal point for identification of research needs of the water supply industry with respect to the additives program.

The Association of State Drinking Water Administrators

The Association of State Drinking Water Administrators (ASDWA) is a nonprofit organization whose eligible membership is comprised of drinking water program administrators in each of the 50 states and seven U.S. territories. Through the organization, representatives speak with a collective voice to Congressional committees, the United States Environmental Protection Agency (U.S. EPA), professional and trade associations, water utilities, and the general public on issues related to state drinking water programs. With its mission of protecting the public health through assurance of high-quality drinking water, and promoting responsible, reasonable, and feasible drinking water programs at the state and federal levels, the Association is a valued contributor to the consortium, and to the program. It provides the link between the additives program and the state drinking water programs.

The Conference of State Health and Environmental Managers

The Conference of State Health and Environmental Managers (COSHEM), known formerly as the Conference of State Sanitary Engineers (CSSE), is currently inactive as an organization. It brought to the consortium expertise and involvement of state health and environmental program managers. The Conference was the focal point for health concerns of all state environmental programs, including drinking water, wastewater, air, solid and hazardous wastes, radiology, occupational health, and food. A standing committee on water supply focused on drinking water issues and kept the membership informed. The Conference played an important role early in the program through two-way communication with state health and environmental program decision makers.

American Water Works Association

The purpose of the American Water Works Association (AWWA) is to promote public health, safety, and welfare by improving the quality and increasing the quantity of water delivered to the public, and to developing and furthering an understanding of the problems relating thereto by:

- advancing the knowledge of the design, construction, operation, water treatment, and management of water utilities;
- developing standards for procedures, equipment, and materials used by public water supply systems;
- advancing the knowledge of problems involved in the development of resources, production, and distribution of safe and adequate water supplies;
- educating the public on the problems of water supply and promoting a spirit of cooperation between consumers and suppliers in solving these problems; and
- conducting research to determine the causes of problems with providing a safe and adequate water supply, and proposing solutions thereto in an effort to improve the quality and quantity of the water supply provided to the public.

AWWA brings to the consortium its established position as the largest public drinking water association in North America, with a broad membership that includes utilities, consultants, manufacturers / distributors / agents, contractors, and other organizations with a direct interest in drinking water.

This page is intentionally left blank.

NSF/ANSI/CAN Standard for Drinking Water Additives –

Drinking Water System Components – Health Effects

1 General

1.1 Purpose

This standard establishes minimum health effects requirements for the chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems. This standard does not establish performance, taste and odor, or microbial growth support requirements for drinking water system products, components, or materials.

1.2 Scope

1.2.1 This standard is intended to cover specific materials or products that come into contact with: drinking water, drinking water treatment chemicals, or both. The focus of the standard is evaluation of contaminants or impurities imparted indirectly to drinking water. The products and materials covered include, but are not limited to, process media (e.g., carbon, sand), protective materials (e.g., coatings, linings, liners), joining and sealing materials (e.g., solvent cements, welding materials, gaskets), pipes and related products (e.g., pipes, tanks, fittings), mechanical devices used in treatment / transmission / distribution systems (e.g., valves, chlorinators, separation membranes, point-of-entry (POE) drinking water treatment systems), and mechanical plumbing devices (e.g., faucets, endpoint control valves).

1.2.2 Point-of-use (POU) drinking water treatment devices are not covered by the scope of this standard.

1.3 Normative references

The following documents contain requirements that, by reference in this text, constitute requirements of this standard. At the time this standard was balloted, the editions listed below were valid. All documents are subject to revision, and parties are encouraged to investigate the possibility of applying the recent editions of the documents indicated below. The most recent published edition of the document shall be used for undated references.

21 C.F.R. Part 58, *Good Laboratory Practice for Nonclinical Laboratory Studies*³

40 C.F.R. Part 136, *Guidelines Establishing Test Procedures for the Analysis of Pollutants*³

40 C.F.R. Part 141, *National Primary Drinking Water Regulations*³

40 C.F.R. Part 160, *Good Laboratory Practice Standards*³

³ National Archives and Records Administration, Office of the Federal Register. 7 G Street NW, Suite A-734, Washington, DC 20401. <www.ecfr.gov>