

# IEEE Standard Profile for Use of IEEE 1588™ Precision Time Protocol in Power System Applications

IEEE Power & Energy Society

Sponsored by the  
Power System Relaying Committee  
and  
Substations Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA

**IEEE Std C37.238™-2011**

14 July 2011



# **IEEE Standard Profile for Use of IEEE 1588™ Precision Time Protocol in Power System Applications**

Sponsor

**Power System Relaying Committee**

and

**Substations Committee**

of the

**IEEE Power & Energy Society**

Approved 16 June 2011

**IEEE-SA Standards Board**

**Abstract:** A common profile for the use of Precision Time Protocol (PTP) of IEEE Std 1588-2008 in power system protection, control, automation, and data communication applications utilizing an Ethernet communications architecture is specified.

**Keywords:** grandmaster clock, IEEE 1588, power substation, precise time synchronization, Precision Time Protocol (PTP), sample synchronization, slave-only clock, synchrophasors, transparent clock

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 14 July 2011. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

Modbus is a registered trademark in the U.S. Patent & Trademark Office, owned by the Modbus Organization, Inc.

PDF: ISBN 978-0-7381-6721-3 STD97145  
Print: ISBN 978-0-7381-6722-0 STDPD97145

*IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854-4141  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std C37.238-2011, IEEE Standard Profile for Use of IEEE 1588™ Precision Time Protocol in Power System Applications.

This standard specifies a common profile for use of IEEE 1588 Precision Time Protocol (PTP) in power system protection, control, automation, and data communication applications utilizing an Ethernet communications architecture.

Typical Ethernet-based time distribution architecture consists of a reference clock, bridges, and end devices. Bridges with boundary clock functionality may also be used at interconnection points between different PTP domains or PTP profiles.

In addition to distributing global time that is traceable to a recognized standard time source, the profile has a provision for distributing local time for the cases when connectivity to recognized standard time sources is lost.

The profile can be used for precise time synchronization of the devices in a substation, and between substations in a larger geographical area, if performance requirements of this standard are met.

The use of different physical layer communication technologies to carry Ethernet frames, including SONET/SDH and wireless technologies, is not precluded if they can meet performance requirements of this standard.

Time distribution specified in this standard is based on the following basic assumptions:

- All devices that participate in time distribution support this standard.
- All devices are in the same time distribution domain.
- All devices have point-to-point connections to their neighbors.
- Transmit and receive cable delay for each point-to-point connection is assumed to be symmetrical. Known asymmetry in cable delay can be configured and corrected.

The use of security techniques is an important consideration and, based on the application, may be desirable or mandated. Security extensions and network engineering methods for hardening the PTP-based time distribution system against malicious attacks are not covered, and are outside of scope of this standard. If security techniques are used, they should not impair the ability of devices to achieve performance, specified in this standard. Future improvements in IEEE 1588 security mechanism will be considered in a revision of this standard.

Redundancy is an important consideration; some applications recommend or mandate support for different time distribution technologies, e.g., Global Positioning System (GPS) and Inter-Range Instrumentation Group B (IRIG-B). Support for multiple time distribution technologies at the same time is out of scope of this standard.

## Notice to users

### Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

### Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

### Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

### Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.



## Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the IEEE 1588 Profile for Power System Applications Working Group had the following membership:

**Galina S. Antonova**, *Chair*  
**William Dickerson**, *Vice Chair*

Alex Apostolov  
Christopher Brunner  
Dac-Phuoc Bui  
Michael Dood  
Heiko Gerstung  
Didier Giarratano  
Richard Harada  
Clemens Hoga  
Christopher R. Huntley  
Hubert Kirmann

Stanley Klein  
Tom Ko  
Steven A. Kunsman  
Kenneth Martin  
Gary Michel  
René Midence  
Bruce Muschlitz  
Roger Moore  
R. Jay Murphy  
Bogdan Popescu  
Craig Preuss

Farmoosh Rahmatian  
Markus Renz  
Veselin Skendzic  
Fred Steinhauer  
Tim Tibbals  
Jean-Charles Tournier  
Benton A. Vandiver  
Jon Waters  
Justin Wu  
Baihua Xue

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman  
Mark Adamiak  
Satish K. Aggarwal  
Galina S. Antonova  
James Ariza  
Ali Al Awazi  
Chris Bagge  
Philip Beaumont  
P. Stephan Bedrosian  
Kenneth Behrendt  
William Bloethe  
Chris Brooks  
Gustavo Brunello  
Christoph Brunner  
Arvind K. Chaudhary  
Prashanth Chittapuram  
Stephen Conrad  
James Cornelison  
Patrick Diamond  
Gary Donner  
Michael Dood  
Randall Dotson  
Neal Dowling  
Lee Eccles  
Gary Engmann  
Ronald Farquharson  
Kenneth Fodero  
Heiko Gerstung  
Jeffrey Gilbert  
Roman Graf  
Ron Greenthaler  
Stephen Grier  
Randall Groves

Roger Hedding  
Gary Heuston  
Werner Hoelzl  
Gary Hoffman  
David Horvath  
Christopher R. Huntley  
Innocent Kamwa  
Piotr Karocki  
Bogdan Kasztenny  
Yuri Khersonsky  
Stanley Klein  
Joseph L. Koepfinger  
Jim Kulchisky  
Chung-Yiu Lam  
Greg Luri  
Wayne W. Manges  
Kenneth Martin  
Pierre Martin  
William McBride  
David Mcginn  
Gary Michel  
René Midence  
William Moncrief  
Georges Montillet  
Jerry Murphy  
R. Murphy  
Bruce Muschlitz  
Michael S. Newman  
Chris Osterloh  
Lorraine Padden  
Donald Parker  
Charles Petras  
Robert Pettigrew  
Ulrich Pohl

Craig Preuss  
Michael Roberts  
Robert Robinson  
Charles Rogers  
M. Sachdev  
Bartien Sayogo  
Thomas Schossig  
Sam Sciacca  
Gil Shultz  
Tarlochan Sidhu  
Mark Simon  
Veselin Skendzic  
James Smith  
Jerry Smith  
Aaron Snyder  
John Spare  
Gary Stoedter  
Walter Struppler  
John Tengdin  
Michael Thompson  
Joe Uchiyama  
Eric Udren  
Benton A. Vandiver  
John Vergis  
Jane Verner  
Ilia Voloh  
John Wang  
Jon Waters  
Stephen Webb  
Karl Weber  
Ludwig Winkel  
Phil Winston  
Oren Yuen

When the IEEE-SA Standards Board approved this standard on 16 June 2011, it had the following membership:

**Richard H. Hulett**, *Chair*  
**John Kulick**, *Vice Chair*  
**Robert M. Grow**, *Past Chair*  
**Judith Gorman**, *Secretary*

Masayuki Ariyoshi  
William Bartley  
Ted Burse  
Clint Chaplin  
Wael Diab  
Jean-Philippe Faure  
Alexander Gelman  
Paul Houzé

Jim Hughes  
Joseph L. Koepfinger\*  
David J. Law  
Thomas Lee  
Hung Ling  
Oleg Logvinov  
Ted Olsen

Gary Robinson  
Jon Walter Rosdahl  
Sam Sciacca  
Mike Seavey  
Curtis Siller  
Phil Winston  
Howard L. Wolfman  
Don Wright

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Michael Janezic, *NIST Representative*

Lisa Perry  
*IEEE Standards Program Manager, Document Development*

Matthew J. Ceglia  
*IEEE Standards Program Manager, Technical Program Development*

## Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	1
2. Normative references.....	2
3. Definitions, special terms, and word usage .....	2
3.1 Definitions .....	2
3.2 Special terms.....	5
3.3 Word usage .....	5
4. Abbreviations .....	5
5. Standard profile for power system applications .....	6
5.1 Identification.....	6
5.2 PTP attribute values.....	7
5.3 Path delay mechanism .....	7
5.4 Best master clock algorithm .....	8
5.5 Management mechanism .....	8
5.6 Transport mechanism.....	11
5.7 Clock types .....	12
5.8 Communication model.....	12
5.9 Timescale.....	12
5.10 Clauses 16 and 17, Annexes K and L of IEEE Std 1588-2008 .....	13
5.11 clockIdentity .....	13
5.12 TLVs.....	13
5.13 TimeInaccuracy .....	15
Annex A (informative) Operating modes .....	16
Annex B (normative) Steady-state performance requirements.....	18
Annex C (informative) Time performance parameters and their use for IEC 61850, IEEE Std C37.118, and IRIG-B applications.....	19
Annex D (informative) Use of IEEE C37.238 messages for slave-only clocks (IRIG-B replacement) .....	25
Annex E (normative) Management Information Base.....	29
Annex F (informative) Bibliography .....	54



# IEEE Standard Profile for Use of IEEE 1588™ Precision Time Protocol in Power System Applications

*IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

### 1.1 Scope

This standard specifies a common profile for the use of IEEE 1588 Precision Time Protocol (PTP) in power system protection, control, automation, and data communication applications utilizing an Ethernet communications architecture.

The profile specifies a well-defined subset of IEEE 1588 mechanisms and settings aimed at enabling device interoperability, robust response to network failures, and deterministic control of delivered time quality. It specifies the preferred physical layer (Ethernet) higher level protocol used for PTP message exchange and the PTP protocol configuration parameters. Special attention is given to ensuring consistent and reliable time distribution within substations, between substations, and across wide geographic areas.

### 1.2 Purpose

The purpose of this standard is to facilitate adoption of IEEE Std 1588-2008 for power system applications requiring high precision time synchronization.<sup>1</sup> It specifies a common subset of PTP parameters and options to provide global time availability, device interoperability, and failure management. This set of PTP

---

<sup>1</sup> Information on references can be found in Clause 2.