

IEEE Recommended Practice for Network Communication in Electric Power Substations

IEEE Power and Energy Society

Developed by the
Power System Communications and Cybersecurity Committee

IEEE Std 1615™-2019
(Revision of IEEE Std 1615-2007)

IEEE Recommended Practice for Network Communication in Electric Power Substations

Developed by the

Power System Communications and Cybersecurity Committee
of the
IEEE Power and Energy Society

Approved 5 September 2019

IEEE SA Standards Board

Abstract: Recommended practices for communication and interoperation of devices connected on an electric power substation Internet Protocol (IP) network are provided. An introduction to the concepts that need to be mastered as well as specific recommendations to follow when deploying the technologies are provided for the power engineer new to IP networking. Direction and requirements to facilitate interoperable electric utility information networks are provided for equipment manufacturers and system integrators.

Keywords: Distributed Network Protocol 3 (DNP3), Ethernet, fiber-optic, IEC 60870-5, IEC 61850, IEEE 1615™, intelligent electronic device (IED), Internet Protocol (IP), managed switch, network, network devices, noise sources, non-operational data, operational data, RS-232, RS-485, security awareness, Transmission Control Protocol (TCP), time synchronization, wireless network

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2019 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 8 November 2019. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-6137-5 STD23873
Print: ISBN 978-1-5044-6138-2 STDPD23873

IEEE prohibits discrimination, harassment, and bullying.
For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.
No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. A current IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit IEEE Xplore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE SA or IEEE's standards development process, visit the IEEE SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this draft recommended practice was completed, the Network Communications in Substations 1615 Working Group had the following membership:

Kevin Easley, Chair
Craig Preuss, Vice Chair
Ed Cenzon, Co-Secretary
Michael Dood, Co-Secretary

Farel Becker
James Bougie

Chris Huntley
Marc Laroix

Silvio Roesler
Eric Thibodeau

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
David Aho
Ali Al Awazi
Jay Anderson
Philip Beaumont
James Bougie
Derek Brown
Gustavo Brunello
William Byrd
James Cain
Paul Cardinal
Yesenia Cevallos
Christopher Chelmecki
Randall Crellin
Ratan Das
Matthew Davis
Michael Dood
Kevin Easley
Ronald Farquharson
Kenneth Fodero
Mietek Glinkowski
Jalal Gohari
Edwin Goodwin
Randall Groves
David Haynes
Roger Hedding
Marco Hernandez
Werner Hoelzl
Gary Hoffman
Chris Huntley
Richard Jackson
Innocent Kamwa

Efthymios Karabetos
George Karady
Stuart Kerry
Yuri Khersonsky
James Kinney
Boris Kogan
Bruce Kraemer
Jim Kulchisky
Chung-Yiu Lam
Lawrenc Long
Elvis Maculuba
Arturo Maldonado
Pierre Martin
John McDonald
C. Michael Miller
Jeff Mizener
Jerry Murphy
R. Murphy
Bruce Muschlitz
Arthur Neubauer
Michael Newman
Paul Nikolich
Joe Nims
James O'Brien
Lorraine Padden
Richard Paes
Bansi Patel
Charles Pestell
Percy Pool
Charles Rogers
Benjamin Rolfe
Thomas Rozek
Daniel Sabin

Miriam Sanders
Steven Sano
Bartien Sayogo
Robert Seitz
Devki Sharma
Mark Simon
Veselin Skendzic
Jeremy Smith
Jerry Smith
Michael Smith
Gary Smullin
Yuyin Song
Robert Stagg
Thomas Starai
Wayne Stec
Ryan Stone
David Tepen
Eric Thibodeau
Michael Thompson
Mark-Rene Uchida
Joe Uchiyama
James Van De Ligt
Roger Verdolin
John Vergis
James Volk
Khurram Waheed
Andrew West
Kenneth White
Aaron Wilson
Robert Wilson
Jian Yu
Oren Yuen

When the IEEE SA Standards Board approved this recommended practice on 5 September 2019, it had the following membership:

Gary Hoffman, *Chair*
Ted Burse, *Vice Chair*
Jean-Philippe Faure, *Past Chair*
Konstantinos Karachalios, *Secretary*

Masayuki Ariyoshi
Stephen D. Dukes
J. Travis Griffith
Guido Hiertz
Christel Hunter
Thomas Koshy
Joseph L. Koepfinger*
John D. Kulick

David J. Law
Joseph Levy
Howard Li
Xiaohui Liu
Kevin Lu
Daleep Mohla
Andrew Myles

Annette D. Reilly
Dorothy Stanley
Sha Wei
Phil Wennblom
Philip Winston
Howard Wolfman
Feng Wu
Jingyi Zhou

*Member Emeritus

Introduction

This introduction is not part of IEEE Std 1615-2019, IEEE Recommended Practice for Network Communication in Electric Power Substations.

IEEE Recommended Practice for Network Communication in Electric Power Substations was first published in 2007. Much of the guidance in the 2007 version of this document remains important and necessary in continuing to support legacy equipment.

There has been a dramatic change in the networking technologies since 2007. Security requirements and tools to address them have impacted design philosophies. Technical requirements unique to power industry applications previously precluded certain uses of Ethernet and TCP/IP (Transport Control Protocol/Internet Protocol), and these are being resolved through the creation of other standards.

Many new applications have created the need for higher bandwidth to support real-time operational awareness and to make this data available to many users beyond the traditional “system operators”. These include higher power system load factors, the introduction of distributed and variable generation, and the use of synchrophasors to support various power system applications.

Historically, serial connectivity (e.g., TIA-232-F) and protocols based on serial technology have dominated substation communications. Serial communication was taken to be inherently secure, both through limited physical accessibility and through obscurity of proprietary protocols. Substation inputs and control signals have been wired directly to protective relays, remote terminal units (RTUs), and recording/metering equipment.

The ability of Ethernet and TCP/IP to serve the large set of needs of the industry securely, reliably, and economically alters the landscape of electric utility communications. DNP3 IP is ubiquitous, and IEC 61850 (International Electrotechnical Commission) is designed as a network suite of functions. Historically, protective relays have been selected by power-system engineers without regard for network or protocol support, and communications have been accomplished using whatever adapters and converters were required. Now, although the protective functionality obviously remains paramount, lack of necessary network functionality may be used to disqualify equipment.

Contents

1. Overview	11
1.1 Scope	11
1.2 Purpose	11
1.3 Preface	11
1.4 Design philosophy	12
1.5 Factors in network design	12
2. Normative references	14
3. Acronyms and abbreviations	15
4. Electric utility information and communications technology (ICT)	17
4.1 Serial communication architecture	19
4.2 Ethernet network communication architecture	21
4.3 Other network technologies	24
4.4 Interfacing serial equipment to an Ethernet-based network	24
4.5 Moving from a serial system to an Ethernet-based architecture	26
4.6 Recommendations for utility networks	29
5. Data flows on Ethernet networks	29
5.1 Data flows	29
5.2 Characterization of data flows	32
6. Security issues and recommendations	34
6.1 Threats	35
6.2 Targets of attack	35
6.3 Cyber-attack techniques	35
6.4 Recommendations and techniques to address threats in a utility information system	36
7. Recommendations for Ethernet-based networks	39
7.1 Media	41
7.2 Reliability	43
8. Substation network design	44
8.1 Selection of communication architecture	44
8.2 Functional requirements	49
9. Interface and processing	51
9.1 Communication interfaces	51
10. Testing	53
10.1 Test planning	53
10.2 Testing plan framework	54
10.3 Testing	55
Annex A (informative) Security issues and awareness	60
A.1 Source of threats to the electric power system	60
A.2 Targets of attack in the electric utility network	61
A.3 Common cyber-attack techniques	63
A.4 Techniques to address threats to the electric utility network	66

Annex B (informative) Protocols used in and to substations.....	73
B.1 Services supported by the Internet Protocol Suite (IPS).....	73
B.2 Name-to-address mapping using DNS.....	73
B.3 Managed host configuration using Dynamic Host Configuration Protocol (DHCP).....	73
B.4 Bootstrapping an IP address using Bootstrap Protocol (BOOTP).....	73
B.5 Network management using Simple Network Management Protocol (SNMP).....	73
B.6 Time synchronization using Network Time Protocol (NTP)/IEEE Std 1588.....	74
B.7 Remote terminals using secure shell (SSH)/Telnet.....	74
B.8 IED access using Hypertext Transfer Protocol (HTTP)/HTTPS.....	75
B.9 File transfer using File Transfer Protocol (FTP)/Secure File Transfer Protocol (SFTP).....	76
B.10 Rapid Spanning Tree Protocol (RSTP).....	77
B.11 High-availability Seamless Redundancy/Parallel Redundancy Protocol (HSR/PRP).....	77
B.12 IEEE 1815 (DNP3).....	79
B.13 Protocol features.....	81
B.14 IEC 60870-5.....	83
B.15 IEC 61850.....	86
Annex C (informative) Internet Protocol Suite (IPS).....	91
C.1 Introduction.....	91
C.2 IP layers.....	92
C.3 IP Addressing.....	95
C.4 IPv6.....	104
Annex D (informative) Interconnection diagrams for communications to and within substations.....	106
D.1 Single master station.....	106
D.2 Multiple master stations.....	107
D.3 Multiple master stations, multiple RTUs.....	108
D.4 Combination systems.....	109
D.5 Substation gateway connections (legacy to standard protocols).....	110
D.6 Networked systems.....	111
D.7 Network physical topologies.....	112
Annex E (informative) Serial communication channel analysis.....	116
E.1 Introduction.....	116
E.2 Specify the performance of a master station to RTU communication channel.....	116
E.3 Channel performance analysis procedure.....	117
E.4 Illustrative example.....	117
Annex F (informative) Protocol models.....	119
F.1 Master slave.....	119
F.2 Client-server model.....	121
F.3 Peer-to-peer networks.....	122
Annex G (informative) Network management.....	123
G.1 Configuring network settings in IEDs.....	123
G.2 Network management in the electric utility information system.....	124
G.3 Tools.....	124
Annex H (informative) Features of devices and media supporting Ethernet-based networks.....	128
H.1 General device features.....	128
H.2 Media features.....	131
H.3 Network devices.....	133
Annex I (informative) Bibliography.....	136

IEEE Recommended Practice for Network Communication in Electric Power Substations

1. Overview

1.1 Scope

This document defines a recommended practice for the design, testing, and operation of communications networks within, to, and from electric power substations. Security considerations are included in the above. It does not establish a new underlying communications standard. Instead, this document presents guidelines and best practices for designing these communication networks.

1.2 Purpose

This recommended practice provides direction for implementers who wish to produce interoperable and secure communications for an electric power substation network. It also provides direction for users, system integrators, and equipment manufacturers who need to establish requirements and design of communications networks within, to, and from the electric power substation. This is meant to address both the physical and logical elements of the network.

1.3 Preface

Network communications is an important component of substation design because of the reliance of many utility applications on a variety of communication networks. This recommended practice recommends proven methods to specify network requirements, specify network schema, design network schema, and mitigate hazards and threats to networks in electric utility substations, while controlling the cost of the network and maintenance of the network. It is impossible for this recommended practice to be inclusive of all types of communication networks and protocols that could exist inside of substations. For example, advanced metering infrastructure (AMI) equipment may be installed inside substations, provide no interaction with the substation local area network (LAN), and be independently connected to the wide area network (WAN). So while impossible to cover every possible technology and protocol, there are many common technologies typical to many substations.

Ethernet and the Transmission Control Protocol/Internet Protocol (TCP/IP) are by far the dominant technologies in office and home use. The cost-effectiveness of IP over Ethernet, including factors of