

IEEE Guide for the Detection, Location and Interpretation of Sources of Acoustic Emissions from Electrical Discharges in Power Transformers and Power Reactors

IEEE Power and Energy Society

Sponsored by the
Transformers Committee

IEEE Guide for the Detection, Location and Interpretation of Sources of Acoustic Emissions from Electrical Discharges in Power Transformers and Power Reactors

Sponsor

Transformers Committee
of the
IEEE Power and Energy Society

Approved 23 October 2018

IEEE-SA Standards Board

Abstract: The detection and location of acoustic emissions (AEs) from partial discharges (PDs) and other sources in liquid-insulated power transformers and reactors are covered in this guide. A means of associating the relative magnitude and position of PDs and other sources with the acoustic signals obtained by strategically located transducers is provided.

Keywords: acoustic emission (AE), attenuation, burst, gas-in-oil analysis, IEEE C57.127™, low-amplitude discharges, partial discharge (PD), power transformers, reactors

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2019 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 11 March 2019. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-5469-8 STD23500
Print: ISBN 978-1-5044-5468-1 STDPD23500

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Xplore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this guide was completed, the Detection on PD—Acoustic Emission Working Group had the following membership:

Detlev Gross, *Chair*
John Harley, *Vice Chair*

Omar Ahmed	Alexander Kraetge	Alaor Scardazzi
Jeffrey Benach	David Larochelle	Aron Sexton
Robert Brusetti	Gustavo Leal	Hemchandra Shertukde
Luc Dorpmanns	Gregorio Lobo	Andre Shor
Michael Franchek	Ali Naderian Jahromi	Charles Sweetser
Thang Hochanh	Arturo Nunez	Mark Tostrud
Stephen Jordan	Amitabh Sarkar	Marco Tozzi

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Tauhid Haque Ansari	Peter Kelly	John Roach
Stephen Antosz	Sheldon Kennedy	Zoltan Roman
Donald Ayers	James Kinney	Rodrigo Ronchi
Barry Beaster	Zan Kiparizoski	Ryandi Ryandi
Robert Beavers	Axel Kraemer	Dinesh Sankarakurup
Emil Bercea	Alexander Kraetge	Daniel Sauer
Enrique Betancourt	Jim Kulchisky	Roderick Sauls
Wallace Binder	Raja Kuppaswamy	Bartien Sayogo
Thomas Blackburn	John Lackey	Ewald Schweiger
William Bloethe	Chung-Yiu Lam	Hemchandra Shertukde
W. Boettger	Benjamin Lanz	Hyeong Sim
Alain Bolliger	David Larochelle	Jerry Smith
Demetrio Bucaneg Jr.	Michael Lauxman	Gary Smullin
William Byrd	Aleksandr Levin	Sanjib Som
Paul Cardinal	Mario Locarno	Brian Sparling
Suresh Channarasappa	Kumar Mani	Thomas Spitzer
Stephen Conrad	J.Dennis Marlow	Wayne Stec
Gary Donner	Lee Matthews	Craig Stiegemeier
Jorge Fernandez Daher	James McBride	Gary Stoedter
Namal Fernando	Mark McNally	Charles Sweetser
Bruce Forsyth	Susan McNelly	Juan Thierry
Anthony Franchitti	Andrew McNulty	Mark Tostrud
George Frimpong	Charles McShane	Marco Tozzi
Jalal Gohari	Joseph Melanson	James Van De Ligt
Edwin Goodwin	Daniel Mulkey	Ajith Varghese
William Griesacker	Ali Naderian Jahromi	Jason Varnell
Detlev Gross	K. R. M. Nair	John Vergis
Randall Groves	Lorraine Padden	Jane Verner
Bal Gupta	Bansi Patel	Dharam Vir
John Harley	Dhiru Patel	Loren Wagenaar
Roger Hayes	David Peelo	David Walker
Werner Hoelzl	Brian Penny	David Wallace
Philip Hopkinson	Christopher Petrola	David Wallach
Richard Jackson	Alvaro Portillo	Kenneth White
Nathan Jacob	Bertrand Poulin	Baitun Yang
John John	Iulian Profir	Peter Zhao
Stephen Jordan	Lakshman Raut	Leo Zibert
Laszlo Kadar	Johannes Rickmann	Waldemar Ziomek

When the IEEE-SA Standards Board approved this guide on 23 October 2018, it had the following membership:

Jean-Philippe Faure, *Chair*
Gary Hoffman, *Vice Chair*
John D. Kulick, *Past Chair*
Konstantinos Karachalios, *Secretary*

Ted Burse
Guido R. Hiertz
Christel Hunter
Joseph L. Koepfinger*
Thomas Koshy
Hung Ling
Dong Liu

Xiaohui Liu
Kevin Lu
Daleep Mohla
Andrew Myles
Paul Nikolich
Ronald C. Petersen
Annette D. Reilly

Robby Robson
Dorothy Stanley
Mehmet Ulema
Phil Wennblom
Philip Winston
Howard Wolfman
Jingyi Zhou

*Member Emeritus

Introduction

This introduction is not part of IEEE Std C57.127-2018, IEEE Guide for the Detection, Location and Interpretation of Sources of Acoustic Emissions from Electrical Discharges in Power Transformers and Power Reactors.

This guide is an expansion of IEEE Std C57.127™-2007. It has been expanded to add a detailed background theory, to better describe the different techniques available, and to add new applications of acoustic location. Documented case studies have also been added to highlight specific situations. Active workers in the field are constantly trying to improve their methods. More effective methods may appear in the future.

Contents

1. Overview	14
1.1 Scope	14
1.2 Purpose	14
1.3 Safety warning	14
2. Definitions, acronyms, and abbreviations	15
2.1 Definitions	15
2.2 Acronyms and abbreviations	16
3. Detection and measurement of PD—background information	17
4. Acoustic signal and transmission characteristics	18
4.1 Acoustic signal	18
4.2 Acoustic signal propagation	21
4.3 Velocity of sound in materials	23
4.4 Competing signal paths	24
5. AE systems—technical concepts	26
5.1 Introduction	26
5.2 All-acoustic system	26
5.3 Acoustic system with an electrical PD trigger	27
5.4 On-line (continuous) acoustic monitoring system	28
5.5 Acoustic sensors	29
5.6 Multiple sensors system	30
5.7 Band-pass filter	30
6. AE testing	30
6.1 General considerations on the application of sensors	30
7. AE field test procedure	32
7.1 Introduction	32
7.2 Test setup	32
7.3 Sensor placement and initial scan	32
7.4 Testing methodologies	33
7.5 Reporting and follow up	34
8. Factory test procedure	34
8.1 Introduction	34
8.2 Initial sensor placement	34
8.3 Measurements and changing of sensor placement	37
9. Characterization of AE signals	38
9.1 Introduction	38
9.2 HVDC transformers and reactors	38
9.3 Characteristics of PD from static electrification	39
9.4 Acoustic activity from thermal faults, the core, mechanical noises, and other sources	39
9.5 Application of acoustics during factory impulse test	40
10. Integrating AE results with data from oil analysis	41
11. Acoustic activity interpretation	43
Annex A (informative) Bibliography	45

Annex B (informative) Signal processing	51
Annex C (informative) Tutorial and case studies for detection and location of AE from PD	54

List of Figures

Figure 1—Typical AE burst.....	19
Figure 2—Oscillations in an AE burst.....	19
Figure 3—Acoustic signal showing pressure wave (1) and the slower shear wave (2) reflections from stiffener on a transformer tank. Lower trace (3) shows tank wall sound path without stiffener	20
Figure 4—Ultrasonic detection of air-borne PD signal using parabolic reflectors.....	20
Figure 5—“Original Defekt Sucher,” mechanical Instrument to investigate structural sound (~1930).....	21
Figure 6—“Textbook” triangulation, tank homogeneously filled and wall as thin membrane.....	22
Figure 7—Compression wave at a tank wall—aperture angle, possible travel paths.....	24
Figure 8—Shear wave at a tank wall—aperture angle, possible travel paths.....	24
Figure 9—Arrival of different wave fronts—fast tank wall path and straight oil path.....	25
Figure 10—Bolted magnetic wall shunts seated in rubber will block acoustic signals almost entirely.....	25
Figure 11—Hidden PD source—signal paths and assumed location.....	26
Figure 12—Example of HV-side of three-phase transformer assembly	35
Figure 13—Example of sensor locations with PD source in center phase. Typically sensors are located on each side wall.	36
Figure 14—Example of sensor locations with PD source in outer phase. Typically sensors are located on each side wall and on the end wall.	36
Figure 15—Example of sensor locations when phase of PD source is not known. Sensors are located initially on one side wall.....	37
Figure 16—Transformer tank—plan view	37
Figure 17—Response of lightning impulse as el. trigger (CH1) and acoustic signals (CH3+CH4).....	41
Figure B.1—Determining the starting time using the energy criterion	52
Figure B.2—Comparison of conventional (FFT) and high-resolution subspace method (MUSIC) for spectral analysis of “clear” (left) and strongly noised (right) AE burst from PD	53
Figure C.1—A PD source emits stress waves that are detected by a sensor on the tank wall. This signal is processed to validate that it is PD and to determine the location.....	54
Figure C.2—Views of the workstation screen showing PD hits versus time and the location of the source of PD in the transformer tank	56
Figure C.3—Internal flashover.....	56
Figure C.4—Acoustic activity and three-dimensional PD source location in a 330 MVA, 400/115/35 kV transformer	57
Figure C.5—Plot showing the time (horizontal) when the acoustic activity produces locatable events (vertical) for a portion of the test	58

Figure C.6—Load current versus acoustic activity.....	58
Figure C.7—Voltage profile	59
Figure C.8—Three-dimensional plots versus construction photographs showing two clusters of acoustic activity.....	60
Figure C.9—Internal inspection findings after unit failed	61
Figure C.10—PD pattern of paper layer delamination (flat gas-filled pockets).....	61
Figure C.11—Using an HV cable as CC (left) and UHF drain valve sensor (right).....	62
Figure C.12—Signal of three acoustic sensors based on electrical trigger signal (red)	62
Figure C.13—Triangulation results of the measurements as shown with Figure C.12	63
Figure C.14—High voltage cable box and found location of the PD activity	63
Figure C.15—PD pattern on X2—spherical gas bubble.....	64
Figure C.16—Acoustic location results on X2 LV with sensors underneath (left) and above (right) the tank	64
Figure C.17—Identified locations on the reverse switch of tap changer X1 and X2.....	65
Figure C.18—Faint acoustic signals in front of X2—wall shunt attenuation	65
Figure C.19—Shell-type core styles (top view)—standard (a) and five-limb variant (b)	66
Figure C.20—PD of a floating potential on HV C phase	66
Figure C.21—Faint acoustic signal as captured on the lower part of C coil.....	67
Figure C.22—Assumed construction of the coil stack and location of the static shields	67
Figure C.23—Acoustic signals as found at the top of coil 1	68
Figure C.24—Path of the acoustic signal through the oil channels under the pressure disk.....	69
Figure C.25—Travel path of the acoustic signal through the oil channels deeply into the winding.....	69

List of Tables

Table 1—Acoustic properties of various materials (Lundgaard [B45]).....	23
Table 2—Time lag in electrical PD detectors	28
Table 3—AE testing: field versus factory differences	31
Table 4—Comparison of electrical and acoustic PD signals	42
Table C.1—DGA history of the transformer with PD activity	56
Table C.2—DGA values	57

IEEE Guide for the Detection, Location and Interpretation of Sources of Acoustic Emissions from Electrical Discharges in Power Transformers and Power Reactors

1. Overview

1.1 Scope

This guide is applicable to the detection and location of sources of acoustic emissions (AEs) from partial discharges (PDs) and other sources in power transformers and power reactors. There are descriptions of acoustic instrumentation, test procedures, and interpretation of results.

1.2 Purpose

This guide is intended to provide information that may be helpful in planning, installing, and operating acoustic measuring equipment and in meaningful interpretation of resulting data.

1.3 Safety warning

The safety warnings in this subclause apply only to work done on transformers installed in the field, not to factory testing. Refer to factory test codes for safety warnings for these situations. Partial discharge (PD)