

BS ISO 16405:2015



BSI Standards Publication

# Room corner and open calorimeter — Guidance on sampling and measurement of effluent gas production using FTIR technique

**bsi.**

...making excellence a habit.™

**National foreword**

This British Standard is the UK implementation of ISO 16405:2015.

The UK participation in its preparation was entrusted to Technical Committee FSH/21/-/7, Reaction to fire tests - Large and intermediate scale tests.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.  
Published by BSI Standards Limited 2015

ISBN 978 0 580 77283 2  
ICS 13.220.01

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 March 2015.

**Amendments/corrigenda issued since publication**

Date	Text affected
------	---------------

---

---

---

**Room corner and open calorimeter —  
Guidance on sampling and  
measurement of effluent gas  
production using FTIR technique**

*Mesurage de la production de gaz toxique à l'aide de la technique  
IRTF pour l'essai en coin de salle et calorimétrie ouverte*





**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Principle</b> .....	<b>1</b>
<b>5 Gas sampling system</b> .....	<b>2</b>
5.1 General.....	2
5.2 Gas sampling probe.....	2
5.2.1 Sampling position.....	2
5.2.2 Exhaust duct sampling application.....	3
5.2.3 Alternative sampling applications.....	4
5.3 Filter.....	5
5.4 Tubing.....	5
5.5 Pump.....	5
<b>6 FTIR instrument</b> .....	<b>6</b>
6.1 General.....	6
6.2 Gas cell.....	6
6.3 Spectrometer parameters.....	7
6.4 Detector.....	7
<b>7 Measurement</b> .....	<b>7</b>
7.1 Requirements.....	7
7.2 Calibration.....	7
7.3 Test procedure.....	7
<b>8 Analysis of spectra</b> .....	<b>8</b>
<b>9 Expression of results</b> .....	<b>8</b>
<b>Annex A (normative) Calculation</b> .....	<b>10</b>
<b>Bibliography</b> .....	<b>13</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT), see the following URL: [Foreword — Supplementary information](#).

The committee responsible for this document is ISO/TC 92, *Fire safety*, Subcommittee SC 1, *Fire initiation and growth*.

## Introduction

This International Standard is intended to obtain concentrations of effluent gases produced in large-scale or simulated real-scale fire tests, such as the room corner test and open calorimeters. These tests describe the fire behaviour of a product under controlled laboratory conditions.

The test standard can be used as part of a fire hazard assessment which takes into account all of the factors which are pertinent to an assessment of the fire hazard of a particular end use.





# Room corner and open calorimeter — Guidance on sampling and measurement of effluent gas production using FTIR technique

## 1 Scope

This International Standard gives guidance concerning suitable apparatus and procedures to be used when applying the FTIR method to measure concentrations of effluent gases produced in large-scale or simulated real-scale fire tests. Such tests include the room corner test (see ISO 9705) and open calorimeter tests as described in ISO 24473.

This guidance and measuring method only describes the way in which the sampling of the gases and collection of FTIR spectra are performed. Analysis of spectra and calibration is part of ISO 19702.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 9705, *Fire tests — Full-scale room test for surface products*

ISO 13943, *Fire safety — Vocabulary*

ISO 19702:—<sup>1)</sup>, *Guidance for sampling and analysis of toxic gases and vapours in fire effluents using Fourier Transform Infrared spectroscopy (FTIR)*

ISO 24473, *Fire tests — Open calorimetry — Measurement of the rate of production of heat and combustion products for fires of up to 40 MW*

ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM: 1995)*

## 3 Terms and definitions

For the purposes of this document, the definitions given in ISO 13943 apply.

## 4 Principle

By using the on-line FTIR technique, it is possible to simultaneously measure the time resolved concentration of several gases during a fire test.

The practical measurement procedure is to continuously extract a fraction of the effluents from the exhaust duct (the most common application) from the opening of the test room or, alternatively, from a position in the vicinity of a test object through a heated sampling system and into a heated optical cell. There, the specific absorption patterns of infrared-active species are recorded by a detector. This information is subsequently presented as an absorption spectrum that is used to determine the concentrations of effluent components. The frequency of collection of absorption spectra, the

---

1) To be published. (Revision of ISO 19702:2006)