



BSI Standards Publication

Free hanging heating and cooling surfaces for water with a temperature below 120°C

Part 1: Pre-fabricated ceiling mounted radiant panels for space heating —
Technical specifications and requirements

National foreword

This British Standard is the UK implementation of EN 14037-1:2016. It supersedes BS EN 14037-1:2003 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/6, Air or space heaters or coolers without combustion.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016.
Published by BSI Standards Limited 2016

ISBN 978 0 580 90457 8

ICS 91.140.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2016.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 14037-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2016

ICS 91.140.10; 91.140.30

Supersedes EN 14037-1:2003

English Version

Free hanging heating and cooling surfaces for water with a temperature below 120°C - Part 1: Pre-fabricated ceiling mounted radiant panels for space heating - Technical specifications and requirements

Panneaux rayonnants de chauffage et de rafraîchissement alimentés avec une eau à une température inférieure à 120 °C - Partie 1 : Panneaux rayonnants de plafond préfabriqués destinés au chauffage des locaux - Spécifications techniques et exigences

An der Decke frei abgehängte Heiz- und Kühlflächen für Wasser mit einer Temperatur unter 120 °C - Teil 1: Vorgefertigte Deckenstrahlplatten zur Raumheizung - Technische Spezifikationen und Anforderungen

This European Standard was approved by CEN on 19 March 2016.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

European foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Symbols and units	11
5 Requirements	13
5.1 General manufacturing requirements	13
5.2 Surface protection.....	13
5.3 Materials.....	14
5.4 Surface emissivity	14
5.5 Mechanical resistance	14
5.5.1 Horizontal curvature of radiant ceiling panels	14
5.5.2 Vertical deflection of radiant ceiling panels	15
5.6 Resistance to fixings.....	15
5.7 Pressure tightness	15
5.8 Resistance to pressure	15
5.9 Dimensional tolerances.....	15
5.10 Upper Insulation.....	16
5.11 Water flow resistance.....	16
5.12 Release of dangerous substances.....	16
5.13 Reaction to fire.....	16
5.13.1 General.....	16
5.13.2 Free hanging heating and cooling surfaces classified as Class A1 without the need for testing.....	16
5.13.3 Free hanging heating and cooling surfaces classified according to the test results	17
5.14 Rated thermal output and characteristic equation	17
5.15 Surface temperature	17
6 Assessment and verification of constancy of performance - AVCP	17
6.1 General.....	17
6.2 Type testing.....	17
6.2.1 General.....	17
6.2.2 Test samples, testing and compliance criteria	18
6.2.3 Test reports.....	19
6.2.4 Shared other party results.....	19
6.3 Factory production control (FPC)	20
6.3.1 General.....	20
6.3.2 Requirements.....	20
6.3.3 Product specific requirements.....	24
6.3.4 Initial inspection of factory and of FPC	24
6.3.5 Continuous surveillance of FPC.....	25
6.3.6 Procedure for modifications	25
6.3.7 One-off products, pre-production products (e.g. prototypes) and products produced in very low quantity	26
7 Technical documentation.....	27
7.1 General.....	27
7.2 Designation of the ceiling mounted radiant panels.....	27
7.3 Maximum operating pressure	27
7.4 Maximum operating temperature	27

7.5	Thermal output respectively cooling capacity.....	27
7.6	Dimensions and technical data.....	27
7.7	Reference data.....	28
7.8	Installation manual.....	28
Annex ZA (informative) Relationship of this European Standard with Regulation (EU) No. 305/2011.....		
		29
ZA.1	Scope and relevant characteristics	29
ZA.2	System of Assessment and Verification of Constancy of Performance (AVCP)	30
ZA.3	Assignment of AVCP tasks	30
	Bibliography	32

European foreword

This document (EN 14037-1:2016) has been prepared by Technical Committee CEN/TC 130 “Space heating appliances without integral heat sources”, the secretariat of which is held by UNI.

This document supersedes EN 14037-1:2003.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2017, and conflicting national standards shall be withdrawn at the latest by June 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports basic work requirements of Regulation (EU) No. 305/2011.

For relationship with Regulation (EU) No. 305/2011, see informative Annex ZA, which is an integral part of this document.

The main changes are:

- the title has been changed,
- the introduction has been changed,
- the scope has been changed,
- new definitions have been added,
- the Annex ZA has been adapted.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard results from the recognition, that heated and chilled ceiling radiant panels falling into the field of application hereinafter stated are traded on the basis of their thermal output. For evaluating and comparing different heated and chilled ceiling surfaces it is therefore necessary to refer to a heating stipulated value.

As installations with ceiling mounted radiant panels can also be used in practice for space cooling, it is necessary to have a test method for evaluating the cooling capacity. Installations with different free hanging heating and cooling surfaces need, for the use of space heating a test method for evaluating the heating output. The test method differs from the method for ceiling mounted radiant panels.

The European Standard EN 14037, *Free hanging heating and cooling surfaces for water with a temperature below 120°C*, consists of the following parts:

- *Part 1: Pre-fabricated ceiling mounted radiant panels for space heating - Technical specifications and requirements;*
- *Part 2: Pre-fabricated ceiling mounted radiant panels for space heating - Test method for thermal output;*
- *Part 3: Pre-fabricated ceiling mounted radiant panels for space heating - Rating method and evaluation of radiant thermal output;*
- *Part 4: Pre-fabricated ceiling mounted radiant panels for space heating - Test method for cooling capacity;*
- *Part 5: Open or closed heated ceiling surfaces - Test method for thermal output.*

1 Scope

This European Standard defines technical specifications and requirements of free hanging pre-fabricated ceiling mounted radiant panels with an air gap between construction and the emitter (not embedded) fed with water at temperatures below 120 °C connected with a centralized heating supply source intended to be installed in buildings.

The panels should be installed with an upper insulation.

The European Standard does not apply to independent heating devices.

The European Standard also defines the additional common data that the manufacturer has to provide to the trade in order to ensure the correct application of the products.

This European standard does not cover the performance of hanging accessories.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 14037-2:2016, *Free hanging heating and cooling surfaces for water with a temperature below 120°C - Part 2: Pre-fabricated ceiling mounted radiant panels for space heating - Test method for thermal output*

EN 14037-3:2016, *Free hanging heating and cooling surfaces for water with a temperature below 120°C - Part 3: Pre-fabricated ceiling mounted radiant panels for space heating - Rating method and evaluation of radiant thermal output*

EN ISO 2409, *Paints and varnishes - Cross-cut test (ISO 2409)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given below apply.

3.1 heating appliance

device having the purpose of transferring heat in order to provide specific temperature conditions inside buildings

3.2 independent heating appliance

self-contained heating appliance which does not need to be connected to a remote heat source (e. g. a boiler) as it contains its own heat source (e. g. gas fired appliances, electric appliances, heat pump appliances)

3.3 pre-fabricated ceiling mounted radiant panel

pre-fabricated heat-transmitting device in the form of a heating or cooling element with width of 0,3 m up to 1,5 m fitted with connection components or open pipes for in-side-assembling and designed to operate on water flow heating and/or cooling facilities