



BSI Standards Publication

Energy performance of buildings — Method for calculation of system energy requirements and system efficiencies

Part 1: General and Energy performance expression,
Module M3-1, M3-4, M3-9, M8-1, M8-4

National foreword

This British Standard is the UK implementation of EN 15316-1:2017. It supersedes BS EN 15316-1:2007, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/24, Heating systems and water based cooling systems in buildings.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017
Published by BSI Standards Limited 2017

ISBN 978 0 580 87776 6

ICS 91.140.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2017.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 15316-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2017

ICS 91.140.10

Supersedes EN 15316-1:2007

English Version

**Energy performance of buildings - Method for calculation
of system energy requirements and system efficiencies -
Part 1: General and Energy performance expression,
Module M3-1, M3-4, M3-9, M8-1, M8-4**

Performance énergétique des bâtiments - Méthode de calcul des besoins énergétiques et des rendements des systèmes - Partie 1 : Généralités et expression de la performance, Modules M3-1, M3-4, M3-9, M8-1, M8-4

Energetische Bewertung von Gebäuden - Verfahren zur Berechnung der Energieanforderungen und Nutzungsgrade der Anlagen - Teil 1: Allgemeines und Darstellung der Energieeffizienz, Module M3-1, M3-4, M3-9, M8-1, M8-4

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword	6
Introduction	7
1 Scope.....	11
2 Normative references.....	13
3 Terms and definitions	13
4 Symbols and abbreviations	13
4.1 Symbols.....	13
4.2 Subscripts	13
5 Description of the methods	14
5.1 General description of the calculation method.....	14
5.1.1 Calculation direction	14
5.1.2 Operating conditions	14
5.1.3 Maximum heat supply and power check.....	15
5.1.4 Two emission sub-systems installed in the same heating system zone.....	16
5.1.5 Multiservice and operating of multi generator systems (load dispatching)	16
5.1.6 Heating and domestic hot water system thermal losses	16
5.1.7 Auxiliary energy	17
5.1.8 Sub-system energy balance	18
5.1.9 Interaction with other technical building systems.....	20
5.2 Optional methods.....	20
5.3 Application data	20
6 Calculation procedure.....	20
6.1 Output data.....	20
6.2 Calculation interval and calculation period.....	22
6.2.1 Calculation interval.....	22
6.2.2 Calculation period	22
6.3 Input data.....	22
6.3.1 Product data.....	22
6.3.2 System design data.....	22
6.3.3 Operating data and boundary conditions	23
6.3.4 Other data	25
6.4 Domestic hot water energy use calculation	25
6.4.1 Domestic hot water needs per domestic hot water system zone	25
6.4.2 Domestic hot water distribution calculation	26
6.4.3 Domestic hot water storage calculation	27
6.5 Space heating energy use calculation.....	28
6.5.1 Generalities.....	28
6.5.2 Space heating emission useful output per space heating system zone	28
6.5.3 Heating system control	30
6.6 Nodes calculation	31
6.6.1 General.....	31
6.6.2 Node output energy flow (load circuits).....	32

6.6.3	Node supply (flow) temperature	32
6.6.4	Node return temperature	32
6.6.5	Node losses.....	33
6.6.6	Node gains	33
6.6.7	Node input (feeding circuit).....	33
6.6.8	Node input mass flow rate.....	33
6.7	Generation sub-system calculation.....	33
6.7.1	Heat generator dispatch sequence.....	33
6.7.2	Generation sub-system operating conditions calculation.....	35
6.7.3	Generation input calculation.....	35
6.8	Generation input per energy carrier and per service	35
6.8.1	General	35
6.8.2	Alternate control.....	36
6.8.3	Parallel control	36
6.9	Auxiliary energy.....	36
6.9.1	Calculating the auxiliary energy of all sub systems	36
6.9.2	Distribution rules auxiliary energy	36
6.10	Recoverable system thermal losses.....	37
6.10.1	Calculating the recoverable thermal losses of all sub systems.....	37
6.10.2	Distribution rules recoverable losses	37
7	Energy efficiency indicators of space heating and domestic hot water systems or sub-systems	38
	Annex A (normative) Template for the specification of application data	39
	Annex B (informative) Default application data	44
	Annex C (normative) Heating circuit calculation modules.....	50
C.1	General	50
C.2	Constant flow rate and variable temperature module.....	51
C.2.1	General	51
C.2.2	Output data	52
C.2.3	Input data	52
C.2.4	Calculation of minimum required temperature.....	53
C.2.5	Calculation of actual operating conditions.....	54
C.3	Varying mass flow rate and constant temperature module.....	54
C.3.1	General	54
C.3.2	Output data	55
C.3.3	Input data	56
C.3.4	Calculation of minimum required temperature.....	56
C.3.5	Calculation of actual operating conditions.....	57
C.4	Intermittent flow rate module.....	58
C.4.1	General	58
C.4.2	Output data	59
C.4.3	Input data	60

C.4.4	Calculation of minimum required temperature.....	60
C.4.5	Calculation of actual operating conditions.....	61
C.5	Constant flow rate and variable heat exchange.....	62
C.5.1	General.....	62
C.5.2	Output data.....	63
C.5.3	Input data.....	64
C.5.4	Calculation of minimum required temperature.....	64
C.5.5	Calculation of actual operating conditions.....	65
Annex D (normative)	Generation circuits calculation modules.....	67
D.1	Generation direct circuit.....	67
D.1.1	General.....	67
D.1.2	Output data.....	67
D.1.3	Input data.....	68
D.1.4	Calculation procedure.....	68
D.2	Generation independent flow rate circuit.....	69
D.2.1	General.....	69
D.2.2	Output data.....	69
D.2.3	Input data.....	70
D.2.4	Calculation procedure.....	70
Annex E (informative)	Bin method.....	72
E.1	General.....	72
E.1.1	General.....	72
E.1.2	Uniformly occurring heat gains.....	73
E.1.3	Non-uniformly occurring heat gains.....	73
E.2	Bin principles.....	74
E.3	Energy demand – heating loads.....	75
E.3.1	General.....	75
E.3.2	Space heating mode.....	76
E.3.3	Domestic hot water mode.....	76
E.4	Calculation interval.....	77
E.4.1	Bin calculation interval.....	77
E.4.2	Effective bin time.....	77
E.5	Generator operating mode (priorities).....	79
E.5.1	General.....	79
E.5.2	Alternate operating mode.....	80
E.5.3	Parallel operating mode.....	80

E.6	Operating conditions calculation.....	80
E.6.1	Running time of a heat generator	80
E.6.2	Generator running time depending on operating mode	81
E.6.3	Generator sequence due to lack of heat capacity	82
E.6.4	Calculation of needed back-up energy	83

European foreword

This document (EN 15316-1:2017) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems”, the secretariat of which is held by DIN.

This document supersedes EN 15316-1:2007.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2017, and conflicting national standards shall be withdrawn at the latest by October 2017.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

The main changes compared to EN 15316-1:2007 are:

- reference and coordination of all other modules (a module corresponds to a subsystem standard);
- inclusion of operating conditions calculation and load dispatching related to building automation control (BAC) and systems design (e.g. connection of distributions).
- inclusion of a monthly method based on BIN.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

EPB standards deal with energy performance calculation and other related aspects (like system sizing) to provide the building services considered in the EPB Directive.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this standard a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE So in this case:

- the regulators will **specify** the choices;
- the individual user will apply the standard to assess the energy performance of a building, and thereby **use** the choices made by the regulators.

Topics addressed in this standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B of this standard. Public regulation on the same topics can even, for certain applications, override the use of this standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

- national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case the national annex (e.g. NA) refers to this text;
- or, by default, the national standards body will consider the possibility to add or include a national annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 15316-6-1).

CEN/TC 228 deals with heating systems and water based cooling systems in buildings. Subjects covered by TC 228 are:

- energy performance calculation;
- inspection;
- design of systems;
- installation and commissioning.

The first version of this standard was developed during the first EPBD mandate and published in 2008. The revision for inclusion in the second EPBD mandate package was performed in 2014.

Default references to EPB standards other than EN ISO 52000-1 are identified by the EPB module code number and given an Annex A (normative template) and Annex B (informative default choice).

Table 1 associates the title of the EN EPB standards to the numbers and modules. It also remembers the replaced standards.

Table 1 — List of EN EPB standards related to the calculation of space heating and domestic hot water systems

No.	Module	<i>New EPBD numbering</i>	<i>Old standards replaced</i>	<i>Title of the new EPBD standard</i>
1	M1-14	EN 15459-1	EN 15459	Energy performance of buildings - Heating systems and water based cooling systems in buildings - Part 1: Economic evaluation procedure for energy systems in buildings, Module M1-14
		CEN/TR 15459-2	New	Energy performance of buildings - Economic evaluation procedure for energy systems in buildings - Part 2: Explanation and justification of EN 15459-1, Module M1-14)
2	M3-11 M8-11	EN 15378-1	EN 15378	Energy performance of buildings - Heating systems and DHW in buildings - Part 1: Inspection of boilers, heating systems and DHW, Module M3-11, M8-11
		CEN/TR 15378-2	New	Energy performance of buildings - Heating systems and DHW in buildings - Part 2: Explanation and justification of EN 15378-1, Module M3-11 and M8-11)
3	M3-10 M8-10	EN 15378-3	New	Energy performance of buildings - Heating and DHW systems in buildings - Part 3: Measured energy performance, Module M3-10, M8-10
		CEN/TR 15378-4	New	Heating systems and water based cooling systems in buildings - Heating systems and DHW in buildings - Part 4: Accompanying TR to EN 15378-3 (Measured energy performance))
4	M3-3	EN 12831-1	EN 12831	Energy performance of buildings - Method for calculation of the design heat load - Part 1: Space heating load, Module M3-3
		CEN/TR 12831-2	New	Energy performance of buildings - Method for calculation of the design heat load - Part 2: Explanation and justification of EN 12831-1, Module M3-3)

No.	Module	New EPBD numbering	Old standards replaced	Title of the new EPBD standard
5	M8-3	EN 12831-3	EN 15316-3-1	Energy performance of buildings - Method for calculation of the design heat load - Part 3: Domestic hot water systems heat load and characterisation of needs, Module M8-2, M8-3
		CEN/TR 12831-4	New	Energy performance of buildings - Method for the calculation of the design heat load - Part 4: Explanation and justification of EN 12831-3, Module M8-2, M8-3
6	M3-1 M8-1 M3-4	EN 15316-1	EN 15316-1	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 1: General and Energy performance expression, Module M3-1, M3-4, M3-9, M8-1, M8-4
	M8-4 M3-9 M8-9	CEN/TR 15316-6-1	New	Heating systems and water based cooling systems in buildings — Method for calculation of system energy requirements and system efficiencies — Part 1: Explanation and justification of EN 15316-1, Module M3-1, M3-4, M3-9, M8-1, M8-4
7	M3-5 M4-5	EN 15316-2	EN 15316-2-1	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 2: Space emission systems (heating and cooling), Module M3-5, M4-5
		CEN/TR 15316-6-2	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-2: Explanation and justification of EN 15316-2, Module M3-5, M4-5
8	M3-6 M4-6 M8-6	EN 15316-3	EN 15316-2-3 EN 15316-3-2	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 3: Space distribution systems (DHW, heating and cooling), Module M3-6, M4-6, M8-6
		CEN/TR 15316-6-3	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-3: Explanation and justification of 15316-3, Module M3-6, M4-6, M8-6
9	M3-8-1 M8-8-1	EN 15316-4-1	EN 15316-4-1 EN 15316-3-3 EN 15316-4-7	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-1: Space heating and DHW generation systems, combustion systems (boilers, biomass), Module M3-8-1, M8-8-1
		CEN/TR 15316-6-4	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-4: Explanation and justification of EN 15316-4-1, Module M3-8-1, M8-8-1
10	M3-8-2 M4-8-2 M8-8-2	EN 15316-4-2	EN 15316-4-2	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-2: Space heating generation systems, heat pump systems, Module M3-8-2, M8-8-2
		CEN/TR 15316-6-5	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-5: Explanation and justification of EN 15316-4-2, Module M3-8

No.	Module	New EPBD numbering	Old standards replaced	Title of the new EPBD standard
11	M3-8-3 M8-8-3 M11-8-3	EN 15316-4-3	EN 15316-4-3 EN 15316-4-6	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-3: Heat generation systems, thermal solar and photovoltaic systems, Module M3-8-3, M8-8-3, M11-8-3
		CEN/TR 15316-6-6	New	Energy performance of buildings - Method for calculation of system energy performance and system efficiencies - Part 6-6: Explanation and justification of EN 15316-4-3 Module M3-8-3 M8-8-3
12	M3-8-4 M8-8-4 M11-8-4 M3-7 / M8-7	EN 15316-4-4	EN 15316-4-4	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-4: Heat generation systems, building-integrated cogeneration systems, Module M8-3-4, M8-8-4, M8-11-4
		CEN/TR 15316-6-7	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-7: Explanation and justification of EN 15316-4-4, Module M8-3-4, M8-8-4, M8-11-4
13	M3-8-5 M4-8-5 M8-8-5 M11-8-5	EN 15316-4-5	EN 15316-4-5	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-5: District heating and cooling, Module M3-8-5, M4-8-5, M8-8-5, M11-8-5
		CEN/TR 15316-6-8	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-8: Explanation and justification of EN 15316-4-5 (District heating and cooling), Module M3-8-5, M4-8-5, M8-8-5, M11-8-5
14	M3-8-8	EN 15316-4-8	EN 15316-4-8	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-8: Space heating generation systems, air heating and overhead radiant heating systems, including stoves (local), Module M3-8-8
		CEN/TR 15316-6-9	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-9: Explanation and justification of EN 15316-4-8, Module M3-8-8
15	M3-7 M8-7	EN 15316-5	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 5: Space heating and DHW storage systems (not cooling), M3-7, M8-7
		CEN/TR 15316-6-10	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 6-10: Explanation and justification of EN 15316-5, Module M3-7, M8-7
16	M3-8-6 M8-8-6	EN 15316-4-9	New	Heating systems and water based cooling systems in buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-9: Direct electric generation systems
17	M11-8-7	EN 15316-4-10	New	Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-10: Wind power generation systems, Module M11-8-7

1 Scope

This European Standard is the general frame for the calculation of the energy use and the energy performance of heating and domestic hot water systems. This standard is only dealing with the heat, provided by water based systems, needed for heating, domestic hot water and cooling (e.g. absorption chiller).

It specifies how to perform the calculation of the entire installation using the calculation modules (see Table 2) corresponding to the methods defined in the respective standards.

It deals with common issues like operating conditions calculation and energy performance indicators.

It standardises the inputs and outputs in order to achieve a common European calculation method.

It allows the energy analysis of the heating and Domestic hot water systems and sub-systems including control (emission, distribution, storage, generation) by comparing the system losses and by defining energy performance indicators.

The performance analysis allows the comparison between systems and sub-systems and makes possible to evaluate the impact of each sub-system on the energy performance of a building.

The calculation of the system losses of each part of the heating sub-systems is defined in subsequent standards.

Ventilation systems are not included in this standard (e.g. balanced systems with heat recovery), but if the air is preheated or an air heating system is installed, the systems providing the heat to the AHU (Air Handling Unit) are covered by this standard.

Table 2 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.