BS 7288:2016+A1:2022



BSI Standards Publication

Specification for residual current devices with or without overcurrent protection for socket-outlets for household and similar uses



Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2022

Published by BSI Standards Limited 2022

ISBN 978 0 539 19709 9

ICS 29.120.30; 29.120.50

The following BSI references relate to the work on this document: Committee reference PEL/23/1 Drafts for comment 16/30337150; 21/30445445 DC

Amendments/corrigenda issued since publication

Date	Text affected
31 May 2022	A1: see Foreword

Forewordv0Introduction11Scope12Normative references23Terms, definitions and symbols34Classification according to behaviour resulting from failure of the line voltage104.1Classification according to behaviour in presence of d.c. components104.2Classification according to the heavion for earthing104.4Classification according to the environmental conditions114.5Classification according to the environmental conditions114.6Classification according to the environmental conditions114.7Classification according to the very of terminals114.8Classification according to the very of the cover plate114.9Classification according to the very of terminals114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.3Characteristics of SRCDs125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Tekered or standard values of maximum break time of SRCDs for a.c. residual current157Table 1 - Standard values of maximum break time of SRCDs for a.c. residual current157Table 4 - Position of marking156.1General19158.3Vold18188.4Operating characteristics21<	Conte	Contents	
0 Introduction 1 1 Scope 1 2 Normative references 2 3 Terms, definitions and symbols 3 4 Classification according to behaviour resulting from failure of the line voltage 10 4.1 Classification according to behaviour in presence of d.c. components 10 4.2 Classification according to the design of the cover plate 10 4.5 Classification according to the environmental conditions 11 4.6 Classification according to the environmental conditions 11 4.7 Classification according to the environmental conditions 11 4.8 Classification according to vercurrent protection 11 4.9 Classification according to vercurrent protection 11 4.10 Type of SRCD 11 4.11 Number of poles 12 12 5 Characteristics of SRCDs 12 12 5.1 Summary of characteristics 12 12 5.2 Characteristic sonomon to all socket-outlet residual current devices 12 12 5.3 Characteristic sonomon to all s		Foreword	v
1 Scope 1 2 Normative references 2 3 Terms, definitions and symbols 3 4 Classification 9 4.1 Classification according to behaviour resulting from failure of the line voltage 10 4.2 Classification according to behaviour in presence of d.c. components 10 4.3 Classification according to the design of the cover plate 10 4.4 Classification according to the enethod of mounting 10 4.5 Classification according to the enethod of mounting 10 4.6 Classification according to the environmental conditions 11 4.7 Classification according to the environmental conditions 11 4.8 Classification according to the environmental conditions 11 4.10 Type of SRCD 12 5 Characteristics specific to SRCDs 12 5 Summary of characteristics specific to SRCDs with overcurrent protection (see 4.9) 13 5.4 Preferred or standard values of maximum break time of SRCDs for a.c. residual current 15 7 Table 4 — Standard values of maximum break time of SRCDs for a.c. residual current 15	0	Introduction	1
2 Normative references 2 3 Terms, definitions and symbols 3 4 Classification 9 4.1 Classification according to behaviour resulting from failure of the line voltage 10 4.2 Classification according to behaviour in presence of d.c. components 10 4.4 Classification according to the design of the cover plate 10 4.5 Classification according to the environmental conditions 11 4.6 Classification according to the method of mounting 10 4.7 Classification according to the provison for earthing 10 4.7 Classification according to overcurrent protection 11 4.8 Classification according to overcurrent protection 11 4.10 Type of SRCD 11 4.11 Number of poles 12 5 Characteristics common to all socket-outlet residual current devices 12 5.2 Characteristics common to all socket-outlet residual current devices 12 5.3 Characteristics common to all socket-outlet residual current devices 12 5.4 Preferred or standard values of maximum break time of SRCDs for a.c. residual current	1	Scope	1
3 Terms, definitions and symbols 3 4 Classification 9 4.1 Classification according to behaviour resulting from failure of the line voltage 10 4.2 Classification according to the design 10 4.3 Classification according to the design of the cover plate 10 4.4 Classification according to the environmental conditions 11 4.5 Classification according to the environmental conditions 11 4.6 Classification according to the environmental conditions 11 4.8 Classification according to the environmental conditions 11 4.9 Classification according to the environmental conditions 11 4.10 Type of SRCD 11 4.11 Number of poles 11 4.12 Type of switching 12 5 Characteristics of SRCDs 12 5.1 Summary of characteristics 12 5.2 Characteristics specific to SRCDs with overcurrent protection (see 4.9) 13 5.4 Preferred or standard values of maximum break time of SRCDs for pulsating d.c. residual current to table 1 - Standard values of maximum break time of SRCDs for a.c. residual current tot	2	Normative references	2
4 Classification 9 4.1 Classification according to behaviour resulting from failure of the line voltage 10 4.2 Classification according to the design 10 4.3 Classification according to the provision for earthing 10 4.4 Classification according to the design of the cover plate 10 4.6 Classification according to the environmental conditions 11 4.7 Classification according to the type of terminals 11 4.8 Classification according to the type of terminals 11 4.9 Classification according to the type of terminals 11 4.10 Type of SKCD 11 4.11 Number of poles 12 5 Characteristics of SKCDs 12 5.1 Summary of characteristics 12 5.2 Characteristics of SKCDs 12 5.3 Characteristics specific to SRCDs with overcurrent protection (see 4.9) 13 5.4 Preferred or standard values of maximum break time of SRCDs for a.c. residual current 15 5.5 Text deleted 15 6 Marking and other product information 15 6.1 General 15 7 Table 4 - Position of marking 15 7	3	Terms, definitions and symbols	3
4.1Classification according to behaviour resulting from failure of the line voltage104.2Classification according to behaviour in presence of d.c. components104.3Classification according to the provision for earthing104.4Classification according to the method of mounting104.5Classification according to the method of mounting104.6Classification according to the environmental conditions114.8Classification according to the type of terminals114.9Classification according to the type of terminals114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics of SRCDs125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current155.5Text deleted156.1General156.2Additional marking156.3Void187Table 4 - Position of marking198Requirements for construction and operation19918General19918General257Table 4 - Tripping current limits258.4Operating characteristics247Table 5 - Volues of influe	4	Classification	9
4.2Classification according to be design104.3Classification according to be haviour in presence of d.c. components104.4Classification according to the provision for earthing104.5Classification according to the design of the cover plate104.6Classification according to the environmental conditions114.8Classification according to the environmental conditions114.9Classification according to the type of terminals114.10Type of SRCD114.11Number of poles114.12Type of SRCD125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics common to all socket-outlet residual current devices125.1Summary of characteristics125.2Characteristics socific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 2 - Standard values of maximum break time of SRCDs for pulsating d.c. residual current156.1General157Table 4 - Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Table 5 - Volues of influencing quantities18<	4.1	Classification according to behaviour resulting from failure of the line voltage	10
4.3Classification according to behaviour in presence of d.c. components104.4Classification according to the design of the cover plate104.5Classification according to the design of the cover plate104.6Classification according to the environmental conditions114.8Classification according to the environmental conditions114.8Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics common to all socket-outlet residual current devices147Table 1 - Standard values147Table 1 - Standard values of maximum break time of SRCDs for a.c. residual current155.5Text deleted156.1General157Table 4 - Position of maximum break time of SRCDs for pulsating d.c. residual current156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General20178.4Operating characteristics247Table 6 - Mini	4.2	Classification according to the design	10
4.4Classification according to the provision for earthing104.5Classification according to the method of mounting104.6Classification according to the environmental conditions114.8Classification according to the type of terminals114.9Classification according to the type of terminals114.10Type of SRD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values14Table 1 Standard values of maximum break time of SRCDs for a.c. residual current156Marking and other product information156.1General157Table 4 Position of marking186.3Void187Standard conditions for operation in service and for installation187Table 5 Values of influencing quantities198.1General20207Table 6 Minimum clearances and creepage distances218.4Operating characteristics247Table 6 Minimum clearances and creepage distances218.5Void25258.6Test device258.7Temperature-ris	4.3	Classification according to behaviour in presence of d.c. components	10
4.5Classification according to the design of the cover plate104.6Classification according to the method of mounting104.7Classification according to the environmental conditions114.8Classification according to the type of terminals114.9Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles125Characteristics of SRCDs125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics second on tall socket-outlet residual current devices125.3Characteristics second on tall socket-outlet residual current devices125.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 1 Standard values of maximum break time of SRCDs for pulsating d.c. residual current156Marking and other product information156.1General157Table 4 Position of marking186.3Void187Standard conditions for operation in service and for installation187.4General198.1General198.1General207Table 6 Minimum clearances and creepage distances217Table 7 - Tripping current limits258.6Test device258.7Temperature-rise values258.6Test	4.4	Classification according to the provision for earthing	10
4.6Classification according to the method of mounting104.7Classification according to the environmental conditions114.8Classification according to the type of terminals114.9Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 2 - Standard values of maximum break time of SRCDs for pulsating d.c. residual current156Marking and other product information156.1General157Table 4 - Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation198.1General208.2Information and marking198.3Mechanical and electrical design207Table 5 - Wolde of influencing quantities218.4Operating characteristics258.5Void258.6Test device258.7Temperature rise <td>4.5</td> <td>Classification according to the design of the cover plate</td> <td>10</td>	4.5	Classification according to the design of the cover plate	10
4.7Classification according to the environmental conditions114.8Classification according to the type of terminals114.9Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 1 - Standard values of maximum break time of SRCDs for a.c. residual current156Marking and other product information156.1General157Table 4 - Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Table 5 - Values of influencing quantities188Requirements for construction and operation198.1General207Table 7 - Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties26 <td>4.6</td> <td>Classification according to the method of mounting</td> <td>10</td>	4.6	Classification according to the method of mounting	10
4.8Classification according to the type of terminals114.9Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125Summary of characteristics125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics common to all socket-outlet residual current devices125.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 1 Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157Table 4 Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Table 5 Values of influencing quantities188Requirements for construction and operation198.1General207Table 7 Tripping current limits258.5Void258.6Test device258.7Temperature rise268.8Resistance to humidity268.9Dielectric prope	4.7	Classification according to the environmental conditions	11
4.9Classification according to overcurrent protection114.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157.4Table 1 — Standard values of maximum break time of SRCDs for a.c. residual current157.5Text deleted156Marking and other product information156.1General157.4Void187.5Standard conditions for operation in service and for installation187.6Marking for screwless terminals188.1Requirements for construction and operation198.2Information and marking198.3Mechanical and electrical design207.7Table 6 — Minimu clearances and creepage distances218.4Operating characteristics247.5Table 6 — Temperature-rise values268.6Test device258.7Temperature rise257.7Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC co	4.8	Classification according to the type of terminals	11
4.10Type of SRCD114.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics ormom to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157Table 1 Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157Table 4 Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation198.1General198.2Information and operation198.3Mechanical and electrical design207Table 6 Minimum clearances and creepage distances218.4Operating characteristics247Table 7 Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping26<	4.9	Classification according to overcurrent protection	11
4.11Number of poles114.12Type of switching125Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values14Table 1 Standard values of maximum break time of SRCDs for a.c. residual current155.5Text deleted156Marking and other product information156.1General157able 4 Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation198.1General198.1General198.2Information and marking198.3Mechanical and electrical design207Table 7 Tripping current limits258.4Operating characteristics247Table 7 Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	4.10	Type of SRCD	11
4.12Type of switching125Characteristics OSRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values of maximum break time of SRCDs for a.c. residual current157able 1 Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157able 4 Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General198.2Information and marking198.3Mechanical and electrical design207able 6 Minimum clearances and creepage distances217able 7 Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	4.11	Number of poles	11
5Characteristics of SRCDs125.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values14Table 1 Standard values of maximum break time of SRCDs for a.c. residual current155.4Text deleted155.5Text deleted156Marking and other product information156.1General157able 4 Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation188Requirements for construction and operation198.1General198.2Information and marking207able 7 Tripping current limits258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	4.12	Type of switching	12
5.1Summary of characteristics125.2Characteristics common to all socket-outlet residual current devices125.3Characteristics specific to SRCDs with overcurrent protection (see 4.9)135.4Preferred or standard values14Table 1 - Standard values of maximum break time of SRCDs for a.c. residual current155.4Text deleted155.5Text deleted156Marking and other product information156.1General157 Table 4 - Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187 Standard conditions for operation in service and for installation198.1General198.2Information and marking198.3Mechanical and electrical design207 Table 6 - Minimum clearances and creepage distances218.4Operating characteristics247 Table 7 - Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs to ace of overcurrent conditions26	5	Characteristics of SRCDs	12
5.2 Characteristics common to all socket-outlet residual current devices 12 5.3 Characteristics specific to SRCDs with overcurrent protection (see 4.9) 13 5.4 Preferred or standard values of maximum break time of SRCDs for a.c. residual current 15 Table 1 — Standard values of maximum break time of SRCDs for pulsating d.c. residual current 15 7 Text deleted 15 6 Marking and other product information 15 6.1 General 15 7 Table 4 — Position of marking 15 6.2 Additional marking for screwless terminals 18 6.3 Void 18 7 Standard conditions for operation in service and for installation 18 7 Standard construction and operation 19 8.1 General 19 8.2 Information and marking 19 8.3 Mechanical and electrical design 20 7 Table 7 — Tripping current limits 25 8.5 Void 25 8.6 Test device 25 8.7 Temperature rise 25 8.8 </td <td>5.1</td> <td>Summary of characteristics</td> <td>12</td>	5.1	Summary of characteristics	12
5.3 Characteristics specific to SRCDs with overcurrent protection (see 4.9) 13 5.4 Preferred or standard values 14 Table 1 Standard values of maximum break time of SRCDs for a.c. residual current 15 Table 2 Standard values of maximum break time of SRCDs for pulsating d.c. residual current 15 6.1 General 15 7 Table 4 Position of marking 15 6.2 Additional marking for screwless terminals 18 6.3 Void 18 7 Standard conditions for operation in service and for installation 18 7 Standard conditions for construction and operation 19 8.1 General 19 8.2 Information and marking 19 8.3 Mechanical and electrical design 20 7 Table 6 Minimum clearances and creepage distances 21 8.4 Operating characteristics 24 7 Temperature-rise values 25 8.7 Temperature-rise values 26 8.8 Resistance to humidity 26 8.9 Dielectric properties 26	5.2	Characteristics common to all socket-outlet residual current devices	12
5.4Preferred or standard values14Table 1 — Standard values of maximum break time of SRCDs for a.c. residual current15Table 2 — Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157able 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General198.2Information and marking198.3Mechanical and electrical design207able 6 — Minimum clearances and creepage distances218.4Operating characteristics247able 7 — Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	5.3	Characteristics specific to SRCDs with overcurrent protection (see 4.9)	13
Table 1 — Standard values of maximum break time of SRCDs for a.c. residual current15Table 2 — Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157able 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General198.2Information and marking198.3Mechanical and electrical design207able 6 — Minimum clearances and creepage distances218.4Operating characteristics247able 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise258.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	5.4	Preferred or standard values	14
Table 2 — Standard values of maximum break time of SRCDs for pulsating d.c. residual current155.5Text deleted156Marking and other product information156.1General157able 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation198.1General198.2Information and marking198.3Mechanical and electrical design Table 6 — Minimum clearances and creepage distances218.4Operating characteristics Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26		Table 1 — Standard values of maximum break time of SRCDs for a.c. residual current	15
5.5Text deleted156Marking and other product information156.1General15 $Table 4 - Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 Minimum clearances and creepage distances218.4Operating characteristics24Table 7 Tripping current limits258.5Void258.6Test device258.7Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26$		Table 2 — Standard values of maximum break time of SRCDs for pulsating d.c. residual current	15
6Marking and other product information156.1General15Table 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation198.1General198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	5.5	Text deleted	15
6.1General15Table 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation188Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	6	Marking and other product information	15
Table 4 — Position of marking156.2Additional marking for screwless terminals186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation and operation188Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design Table 6 — Minimum clearances and creepage distances218.4Operating characteristics Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping 8.11268.11Behaviour of SRCDs in case of overcurrent conditions26	6.1	General	15
6.2Additional marking for screwless terminals186.3Void186.3Void187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation187Standard conditions for operation in service and for installation187Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise258.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26		Table 4 — Position of marking	15
6.3Void187Standard conditions for operation in service and for installation18Table 5 Values of influencing quantities188Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 Minimum clearances and creepage distances218.4Operating characteristics24Table 7 Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	6.2	Additional marking for screwless terminals	18
7Standard conditions for operation in service and for installation18Table 5 — Values of influencing quantities188Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	6.3	Void	18
Table 5 — Values of influencing quantities188Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	7	Standard conditions for operation in service and for installation	18
8Requirements for construction and operation198.1General198.2Information and marking198.3Mechanical and electrical design Table 6 — Minimum clearances and creepage distances207Table 6 — Minimum clearances and creepage distances218.4Operating characteristics Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping 8.1126	0	Table 5 — Values of influencing quantities	18
8.1General198.2Information and marking198.3Mechanical and electrical design Table 6 — Minimum clearances and creepage distances208.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping 8.1126	8	Requirements for construction and operation	19
8.2Information and marking198.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.1	General	19
8.3Mechanical and electrical design20Table 6 — Minimum clearances and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.2	Information and marking	19
10010 6 — Minimum Clear dices and creepage distances218.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.3	Table 6 Minimum degranges and groups distances	20
8.4Operating characteristics24Table 7 — Tripping current limits258.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	0.4	Tuble 6 — Minimum clearances and creepage distances	21
8.5Void258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	0.4	Table 7 Trinning current limits	24
8.5Volu258.6Test device258.7Temperature rise257Temperature rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	85	Void	25
8.7Temperature rise258.7Temperature rise25Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.6	Test device	25
Tomperature rise25Table 8 — Temperature-rise values268.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.7	Temperature rice	25
8.8Resistance to humidity268.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	0.7	Table 8 — Temperature-rise values	25
8.9Dielectric properties268.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.8	Resistance to humidity	20
8.10EMC compliance and unwanted tripping268.11Behaviour of SRCDs in case of overcurrent conditions26	8.9	Dielectric properties	26
8.11Behaviour of SRCDs in case of overcurrent conditions26	8 10	EMC compliance and unwanted tripping	26
	8.11	Behaviour of SRCDs in case of overcurrent conditions	26

8.12	Resistance of the insulation against impulse voltages	27
8.13	Mechanical and electrical endurance	27
8.14	Resistance to mechanical shock	27
8.15	Reliability	27
8.16	Protection against electric shock and degree of protection IP of the SRCD	27
8.17	Resistance to heat	28
8.18	Resistance to abnormal heat and to fire	28
8.19	Behaviour of SRCDs within ambient temperature range	28
8.20	Resistance to temporary overvoltages	29
	Table 11 — Withstand values and duration of temporary overvoltages	29
9	Tests	29
9.1	General	29
	Table 12 — Test copper conductors corresponding to the rated currents	29
	Table 13 — Type testing schedule	30
9.2	Marking and test of indelibility of marking	30
9.3	Verification of the trip-free mechanism	30
9.4	Test for the verification of electronic circuits	31
	Table 14 — Maximum permissible temperatures under abnormal conditions	32
9.5	Requirements for capacitors and specific resistors and inductors	33
9.6	Test of reliability of screws, current-carrying parts and connections	34
	Table 15 — Screw thread diameters and applied torques	34
9.7	Screwed and screwless terminals	34
	Table 16 — Relationship between rated current and connectable nominal cross-sectional areas of	
	copper conductors	35
	Table 17 — Values for flexing under mechanical load test for copper conductors	36
	Table 18 — Values for pull test for screw-type terminals	37
	Table 19 — Composition of conductors	37
	Table 20 — Tightening torques for the verification of the mechanical strength of screw-type	
	terminals	38
	Table 21 — Relationship between rated current and connectable cross-sectional areas of copper	
	conductors for screwless terminals	40
	Table 22 — Value for pull test for screwless-type terminals	41
	Table 23 — Values for flexing under mechanical load test for copper conductors	42
	Table 24 — Test current for the verification of electrical and thermal stresses in normal use for	
	screwless terminals	42
	Table 25 — Nominal cross-sectional areas of rigid copper conductors for deflection test of	
	screwless terminals	44
	Table 26 — Deflection test forces	44
9.8	Verification of the operating characteristics of type AC and type A SRCDs	45
	Table 27 — Tripping current ranges for SRCDs in case of pulsating d.c. current	48
9.9	Void	49
9.10	Verification of the test device	49
9.11	Verification of the limit of temperature rise	49
	Table 27A — Loading of SRCDs for temperature rise test	51
9.12	Resistance to humidity	52
9.13	Test of dielectric properties	53
9.14	EMC compliance and unwanted tripping	54
	Table 28 — Tests to be applied for EMC	54
9.15	Verification of the behaviour of the SRCD under overcurrent conditions	55
	Table 29 — Tests to verify the behaviour of SRCDs under overcurrent conditions	55

	Table 30 — Power factor ranges of the test circuit	58
9.16	Verification of clearances of the SRCD with the impulse withstand voltage test	62
	Table 31 — Test voltage for verification of impulse withstand voltage between poles	63
	Table 32 — Test voltage for verification of impulse withstand voltage with the metal support	63
9.17	Mechanical and electrical endurance	63
	Table 33 — Cross-sectional area for test conductors	64
9.18	Resistance to mechanical shock	65
	Table 34 — Height of fall for impact tests	66
	Table 35 — Torque test values for glands	68
9.19	Reliability	69
9.20	Protection against electric shock and degree of protection IP of the SRCD	71
9.21	Resistance to heat	72
9.22	Resistance to abnormal heat and to fire – Glow-wire test	73
9.23	Text deleted	74
9.24	Verification of ageing of electronic components	74
9.25	Verification of the behaviour of the SRCD under temporary overvoltage conditions	74
9.26	Tests for reverse polarity (see 8.3.1)	75
9.27	Resistance to excessive residual stress test	75
	Figure 1 — Standard test finger	76
	Figure 2 — General test circuit	77
	Figure 3 — Minimum creepage distances and clearances as a function of peak value of voltage	78
	Figure 4 — Minimum creepage distances and clearances as a function of peak value of	_
	operatina voltaae	79
	Figure 5 — Pillar terminals	80
	Figure 6 — Screw terminals and stud terminals	81
	Figure 7 — Saddle terminals	82
	Figure 8 — Saddle terminals	83
	Figure 9 — Arrangement for checking damage to conductors	84
	Figure 10 — Information for deflection test	85
	Figure 11 — Example of a test circuit with current and voltage derived from separate sources	86
	Figure 12 — Test cycle for low temperature test	86
	Figure 13 — Void	87
	Figure 14 — Test circuit for the verification of the correct operation of SRCDs, in the case of	
	residual pulsatina direct currents	87
	Figure 15 — Test circuit for the verification of the correct operation of SRCDs, in the case of	
	residual pulsating direct currents superimposed by a smooth direct current	88
	Figure 16 — Damned oscillator current wave 0.5 µs/100 kHz	89
	Figure 17 — Example of test circuit for the verification of resistance against unwanted tripping	0,
	due to surge currents to earth resulting from impulse voltages for SRCDs	89
	Figure 18 — Test circuit for the verification of the rated making and breaking canacity and of the	0,7
	coordination	90
	Figure 19 — Test apparatus for the verification of the minimum l^2t and L values to be withstood	20
	hy the SRCD [9.15.2.1a]	91
	Figure 20 — Gauge for checking non-accessibility of live parts	92
	Figure 21 — Impact-test apparatus	93
	Figure 22 — Details of the striking element	94
	Figure 2.2 — Mounting support for specimens	95
	Figure 24 — Mounting block for flush-type SRCDs	95
	Figure 25 — Reliability test cycle	96
	Figure 26 — Ball-pressure test apparatus	97
	. galo = o Sall probaro voor apparavao	

	Figure 27 — Sketches and table showing the application of the blows	98
	Figure 28 — Diagrammatic representation of 9.22	99
	Figure 29 — Test circuit for the verification of TOV withstand (9.25) $^{\text{A}}$	99
Annex A	(normative) Test sequence and number of samples to be submitted for verification of	
	conformity	100
	Table A.1 — Type testing schedule	100
	Table A.2 — Number of samples for full test procedure	102
	Table A.3 — Number of samples for simplified test procedure	103
Annex B	(normative) Determination of clearances and creepage distances	104
	Figures B.1 to B.10 — Illustrations of the application of creepage distances	105
Annex C	(informative) Text deleted	106
Annex D	(normative) Routine tests	106
Annex E	(informative) Methods of determination of short-circuit power factor	107
Annex F	(informative) Differences between BS 7822:2016 and IEC 62640:2011 (with the	
	common modifications)	108
	Table F.1 — Differences between BS 7288:2016 and IEC 62640:2011/HD 62640:2015	108
	Bibliography	111

Summary of pages

This document comprises a front cover, an inside front cover, pages I to VI, pages 1 to 112, an inside back cover and a back cover.

Foreword

Publishing information

This British Standard is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 30 November 2016. It was prepared by Subcommittee PEL/23/1, *Circuit breakers and similar equipment for household use*, under the authority of Technical Committee PEL/23, *Electrical accessories*. A list of organizations represented on these committees can be obtained on request to their secretary.

Supersession

BS 7288:2016+A1:2022 supersedes BS 7288:2016, which is withdrawn.

Relationship with other publications

This revision implements IEC 62640 with the common modification applied by HD 62640 (A) and its Amendment No.12:2021. (A)

Information about this document

Text introduced or altered by Amendment(s) No. 1 is indicated in the text by tags (A) (A1). Minor editorial changes are not tagged.

This standard reproduces the text of IEC 62640 with the common modifications set out in HD 62640 applied (this is why parts are labelled "void") and certain necessary requirements retained from <u>BS 7288:1990</u>. The key differences between this edition of BS 7288 and IEC 62640 (with the common modifications) are set out in <u>Annex F</u>.

Where IEC 62640 text has been deleted as part of this revision, the words "*Text deleted*" have been inserted to indicate this.

This standard specifies requirements for socket-outlets incorporating residual current devices (SRCDs).

This edition covers the use of the following types of SRCDs:

- a) single pole with switched neutral;
- b) double pole;
- c) single pole with solid neutral.

This publication can be withdrawn, revised, partially suspended or suspended. Information regarding the status of this publication can be found in the Standards Catalogue on the BSI website at <u>bsigroup</u>. <u>com/standards</u>, or by contacting the Customer Services team.

Where websites and webpages have been cited, they are provided for ease of reference and are correct at the time of publication. The location of a webpage or website, or its contents, cannot be guaranteed.

Use of this document

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Presentational conventions

The provisions of this standard are presented in roman (i.e. upright) type. Its requirements are expressed in sentences in which the principal auxiliary verb is "shall".

Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.

Where words have alternative spellings, the preferred spelling of the Shorter Oxford English Dictionary is used (e.g. "organization" rather than "organisation").

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

This recipient is advised to consider seeking professional guidance with respect to its use of this publicaton.

This recipient is not intended to consitute a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

0 Introduction

The <u>BS EN 61008</u> and BS EN 61009 series are applicable to residual current devices having one to four poles used in any part of an electrical installation. These devices may be installed either at the origin of a whole installation or upstream of one or several circuits of a fixed installation or upstream of a circuit powering one or more socket-outlets, or be integrated in the same enclosure as a socket-outlet.

Such residual current devices are able to provide fault protection (protection against indirect contact), additional protection (protection against direct contact) if the rated residual current is equal to or less than 30 mA and protection against fire hazard due to a persistent earth leakage current without the operation of the overcurrent protection. Equipment meeting the requirements of the <u>BS EN 61008</u> or BS EN 61009 series ensures isolation, withstands high levels of electromagnetic disturbances for household and similar applications, and allows safe use of an electrical installation.

Although the <u>BS EN 61008</u> and BS EN 61009 series may be applicable to "residual current devices integrated in socket-outlets" it is acknowledged that due to the specific use and location of a socket-outlet, at the boundary of the fixed installation and immediately upstream of electrical equipment powered through a plug inserted into the socket-outlet, these devices require different features.

The residual current device at socket-outlet level is normally intended to be installed by skilled or instructed persons. It can be operated several times per day. The isolation function is not necessary since pulling out the plug from the socket-outlet is recognized as providing effective isolation. The absence of permanently connected long conductors downstream of the RCD, together with a limited number of powered appliances, justifies reduced EMC levels. Residual current devices covered by this standard are intended for additional protection in case of direct contact only. These particular features having been considered, it was recognized that a dedicated standard for socket-outlet residual current devices (SRCDs) was necessary.

1 Scope

This British Standard applies to residual current-operated devices (RCD) incorporated in, or specifically intended for use with, single pole and neutral and single pole and switched neutral and double pole socket-outlets, with provision of earthing of the socket-outlet for household and similar uses (SRCD: socket-outlet residual current devices). SRCDs, according to this standard, are intended to be used in single phase systems such as phase to neutral. SRCDs are only intended to provide supplementary protection downstream of the SRCD. SRCDs are intended for use in circuits where the fault protection and additional protection are already assured upstream of the SRCD.

NOTE 1 Void.

NOTE 2 Void.

NOTE 3 Void.

At SRCDs are only intended to provide additional protection downstream of the SRCD. SRCDs are intended for use in circuits where the fault protection (indirect contact protection) is already assured upstream of the SRCD. (At

NOTE 4 For SRCDs intended to provide isolation or fault protection, or to be used in IT systems, BS EN 61008-1 or BS EN 61009-1 should be used, as applicable, in conjunction with the requirements of <u>BS 1363-2</u> for socket-outlets.

NOTE 5 Requirements and testing for SRCDs intended to be used in IT systems are under consideration.