

Australian Standard[®]

**Insulator and conductor fittings for
overhead power lines**

**Part 1: Performance, material, general
requirements and dimensions**



This Australian Standard® was prepared by Committee EL-010, Overhead Lines. It was approved on behalf of the Council of Standards Australia on 4 November 2008. This Standard was published on 12 February 2009.

The following are represented on Committee EL-010:

- Australasian Railway Association
 - Australian Chamber of Commerce and Industry
 - Australian Electrical and Electronic Manufacturers Association
 - Australian Porcelain Insulators Association
 - Electricity Engineers Association, New Zealand
 - Energy Networks Association
-

This Standard was issued in draft form for comment as DR 07133.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Insulator and conductor fittings for
overhead power lines**

**Part 1: Performance, material, general
requirements and dimensions**

Originated as AS C345.1—1962 and AS C345.2—1967.
Previous edition 2004.
Fifth edition 2009.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia
ISBN 0 7337 9004 6

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-010, Overhead Lines, to supersede AS 1154.1—2004, *Insulator and conductor fittings for overhead power, Part 1: Performance, material, general requirements and dimensions*. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide users and manufacturers of fittings with definitions of terms, performance requirements, dimensions, test methods and acceptance criteria.

This Standard is one of a two-part series covering insulator and conductor fittings for overhead power lines, as follows:

Part 1: Performance, material, general requirements and dimensions (this Standard, which combines the former Part 1 and Part 2).

Part 3: Performance and general requirements for helical fittings.

In this revision reference is made to 120 kN rated fittings. These fittings employ M16 fasteners with 16 mm ball/socket couplings and, whilst maintaining the same dimensions, are essentially higher strength versions of the 70 kN fittings. These are NOT intended to be replacements for the previous rating of 125 kN that employed M18 fasteners with 20 mm couplings—these are mechanically similar but dimensionally quite different. If, for the purpose of maintenance, purchasers have need for 20 mm/125 kN fittings in their existing network, this is to be made clear to suppliers to avoid any confusion or incompatibility. Provision has been made by many to supply 106 kN fittings with high strength M18 bolts for these situations.

In the preparation of this Standard, consideration was given to IEC 61284:1997, *Overhead lines—Requirements and tests for fittings*, and IEC 61897:1998, *Overhead lines—Requirements and tests for Stockbridge type aeolian vibration dampers*, relevant parts of which have been incorporated in this Standard.

The following part of this Standard is technically identical to IEC 61284:1997:

Section 5, *Suspension and support fittings* is technically identical to Clauses 11.2—11.4 of IEC 61284:1997.

The following parts of this Standard are technically identical to IEC 61897:1998:

- (a) Clause 7.2.2.3, *Field test*, is technically identical to Clause 7.11.3.3 of IEC 61897:1998.
- (b) Clause 7.2.2.4, *Analytical method*, is technically identical to Clause 7.11.3.4 of IEC 61897:1998.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

The term ‘normative’ has been used in this Standard to define the application of the appendix to which it applies. A ‘normative’ appendix is an integral part of a Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 REFERENCED DOCUMENTS	5
1.3 DEFINITIONS	7
1.4 GENERAL REQUIREMENTS	8
1.5 GENERAL REQUIREMENTS FOR TESTS.....	11
1.6 VERIFICATION OF DIMENSIONS	12
SECTION 2 INSULATOR FITTINGS	
2.1 ITEMS TO BE SPECIFIED BY THE PURCHASER.....	13
2.2 MECHANICAL STRENGTH TYPE TEST.....	13
2.3 HARDNESS TEST.....	14
2.4 ROUTINE TESTS	14
2.5 BATCH TESTS.....	14
2.6 DOCUMENTATION.....	14
SECTION 3 TENSION FITTINGS	
3.1 ITEMS TO BE SPECIFIED BY THE PURCHASER.....	15
3.2 GENERAL	15
3.3 MECHANICAL STRENGTH TYPE TESTS	15
3.4 ELECTRICAL HEATING CYCLE TYPE TEST	16
3.5 ROUTINE TESTS	18
3.6 BATCH TESTS	18
3.7 DOCUMENTATION.....	18
SECTION 4 NON-TENSION FITTINGS	
4.1 ITEMS TO BE SPECIFIED BY THE PURCHASER.....	19
4.2 GENERAL REQUIREMENTS FOR TESTING.....	19
4.3 MECHANICAL TYPE TESTS FOR FITTINGS OTHER THAN TEE FITTINGS... 21	
4.4 MECHANICAL TYPE TESTS FOR TEE FITTINGS WHERE THE MAIN CONDUCTOR IS CONTINUOUS.....	21
4.5 ELECTRICAL HEATING CYCLE TYPE TEST	22
4.6 SHORT-TIME CURRENT TEST.....	23
4.7 BATCH TESTS.....	24
4.8 DOCUMENTATION.....	24
SECTION 5 SUSPENSION AND SUPPORT FITTINGS	
5.1 ITEMS TO BE SPECIFIED BY THE PURCHASER.....	25
5.2 GENERAL REQUIREMENTS FOR TESTS ON SUPPORT FITTINGS.....	25
5.3 MECHANICAL STRENGTH TYPE TESTS	25
5.4 CLAMP BOLT TIGHTENING TEST	26
5.5 ROUTINE TESTS	27
5.6 BATCH TESTS	27
5.7 DOCUMENTATION.....	27
SECTION 6 ELECTRICAL CONTROL FITTINGS	
6.1 ITEMS TO BE SPECIFIED BY THE PURCHASER.....	28
6.2 GENERAL REQUIREMENTS	28
6.3 TYPE TESTS	28
6.4 BATCH TESTS	29

SECTION 7 PROTECTIVE FITTINGS

7.1	ITEMS TO BE SPECIFIED BY THE PURCHASER.....	30
7.2	VIBRATION DAMPERS (STOCKBRIDGE TYPE)	30
7.3	SUBCONDUCTOR SPACERS	34
7.4	GENERAL MECHANICAL TYPE TESTS.....	34
7.5	GENERAL ELECTRICAL TYPE TESTS.....	34
7.6	BATCH TESTS	35
7.7	DOCUMENTATION.....	35
7.8	OTHER PROTECTIVE DEVICES.....	35

SECTION 8 DIMENSIONS AND MARKING

8.1	DIMENSIONS.....	36
8.2	MARKING	40

APPENDICES

A	FORGED STEEL FOR LOW TEMPERATURE APPLICATIONS	52
B	METHODS OF CALCULATING VIBRATION DAMPER EFFICIENCY	53
C	MECHANICAL IMPEDANCE TESTING.....	56
D	CORONA AND RADIO INTERFERENCE VOLTAGE TESTS	57

STANDARDS AUSTRALIA

Australian Standard

Insulator and conductor fittings for overhead power lines

Part 1: Performance, material, general requirements and dimensions

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out performance and general requirements for insulator and conductor fittings (other than helical fittings, OPGW and ADSS fittings, which are covered in AS 1154.3) together with the critical dimensions for cast, forged or fabricated insulator fittings for use on overhead electric power lines using insulators with minimum failing loads of 70 kN, 120 kN and 160 kN.

Pulling eyes provided to assist installation and fittings for insulated service lines, aerial bundled cables and high-voltage covered conductors are not covered by this Standard.

Fittings for high-temperature conductors are not covered by this Standard.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

1110	ISO metric hexagon bolts and screws—Product grades A and B
1110.1	Part 1: Bolts
1111	ISO metric hexagon bolts and screws—Product grade C
1111.1	Part 1: Bolts
1112	ISO metric hexagon nuts
1112.1	Part 1: Style 1—Product grades A and B
1112.2	Part 2: Style 2—Product grades A and B
1112.3	Part 3: Product grade C
1112.4	Part 4: Chamfered thin nuts—Product grades A and B
1154	Insulator and conductor fittings for overhead power lines
1214	Hot-dip galvanized coatings on threaded fasteners (ISO metric coarse thread series)
1237	Plain washers for metric bolts, screws and nuts for general purposes
1237.1	Part 1: General plan
1237.2	Part 2: Tolerances
1442	Carbon steels and carbon-manganese steels—Hot-rolled bars and semi-finished products
1444	Wrought alloy steels—Standard, hardenability (H) series and hardened and tempered to designated mechanical properties
1448	Carbon steel and carbon-manganese steels—Forgings (ruling section 300 mm maximum)