

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical accessories – Residual current monitors (RCMs) –
Part 1: RCMs for household and similar uses**

**Petit appareillage électrique – Contrôleurs d'isolement à courant différentiel
résiduel (RCM) –
Partie 1: RCM pour usages domestiques et analogues**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



IEC 62020-1

Edition 1.0 2020-04

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical accessories – Residual current monitors (RCMs) –
Part 1: RCMs for household and similar uses**

**Petit appareillage électrique – Contrôleurs d'isolement à courant différentiel
résiduel (RCM) –
Partie 1: RCM pour usages domestiques et analogues**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-8322-8145-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references	12
3 Terms and definitions	13
4 Classification.....	15
4.1 According to the method of operation.....	15
4.1.1 RCM functionally dependent on line voltage	15
4.1.2 RCM functionally dependent on an energy source other than line voltage	15
4.2 According to the type of installation	15
4.3 According to the number of current paths.....	15
4.4 According to the ability to adjust the residual operating current.....	15
4.5 According to the possibility of adjusting the time-delay	15
4.6 According to the protection against external influences.....	15
4.7 According to the method of mounting	15
4.8 According to the method of connection	15
4.9 According to the type of connection of the load conductors	15
4.9.1 RCM to which the monitored line is not directly connected.....	15
4.9.2 RCM to which the monitored line is directly connected.....	16
4.10 According to fault indicating means.....	16
4.11 According to ability to directionally discriminate between supply-side and load-side residual currents.....	16
4.12 According to the supply system.....	16
4.12.1 RCM for use in AC supply systems	16
4.12.2 RCM for use in DC supply systems.....	16
4.13 According to the type of residual current monitored.....	16
4.14 According to the method of residual current detection	16
5 Characteristics of RCMs	16
5.1 Summary of characteristics.....	16
5.2 Rated quantities and other characteristics.....	17
5.2.1 Rated voltage	17
5.2.2 Rated current (I_n).....	17
5.2.3 Rated residual operating current ($I_{\Delta n}$).....	17
5.2.4 Rated residual non-operating current ($I_{\Delta no}$)	18
5.2.5 Rated frequency	18
5.2.6 Operating characteristics	18
5.3 Standard and preferred values.....	18
5.3.1 Preferred values of rated voltage (U_e).....	18
5.3.2 Preferred values of rated current (I_n).....	19
5.3.3 Preferred values of rated residual operating current ($I_{\Delta n}$).....	19
5.3.4 Standard value of residual non-operating current ($I_{\Delta no}$).....	19
5.3.5 Standard minimum value of the non-operating overcurrent in the case of single-phase load through an RCM.....	19
5.3.6 Preferred values of rated frequency	19
5.3.7 Standard and preferred values of the rated conditional short-circuit current (I_{nc}) (only applicable to RCMs classified according to 4.9.2)	19

5.3.8	Maximum actuating time (T_{\max})	20
5.3.9	Minimum non-actuating time (T_{\min})	20
5.4	Coordination with short-circuit protective devices (SCPDs) (only valid for RCMs classified according to 4.9.2)	20
5.4.1	General	20
5.4.2	Rated conditional short-circuit current (I_{nc})	20
5.4.3	Rated conditional residual short-circuit current ($I_{\Delta C}$)	20
6	Marking and other product information	20
7	Standard conditions for operation in service and for installation	23
7.1	Standard conditions	23
7.2	Conditions of installation	24
8	Requirements for construction and operation	24
8.1	Mechanical design	24
8.1.1	General	24
8.1.2	Features	24
8.1.3	Clearances and creepage distances	25
8.1.4	Screws, current-carrying parts and connections	26
8.1.5	Terminals for external conductors	27
8.2	Protection against electric shock	29
8.3	Dielectric properties	30
8.4	Temperature rise	30
8.4.1	General	30
8.4.2	Temperature rise limits	30
8.4.3	Ambient air temperature	31
8.5	Operating characteristic	31
8.6	Directional discrimination	31
8.7	Operational endurance	31
8.8	Performance at short-circuit currents	31
8.9	Resistance to mechanical impact	31
8.10	Resistance to heat	32
8.11	Resistance to abnormal heat and to fire	32
8.12	Test device	32
8.13	Correct operation of RCMs within the supply voltage range	32
8.14	Behaviour of RCMs in case of overcurrents in the main circuit	32
8.15	Resistance of RCMs to unwanted initiating of an alarm due to current surges caused by impulse voltages	33
8.16	Behaviour of RCMs in case of earth fault currents comprising DC components	33
8.17	Reliability	33
8.18	Electromagnetic compatibility (EMC)	33
8.18.1	General	33
8.18.2	Immunity requirements	33
8.18.3	Emission requirements	33
8.19	Connection of an external current transformer (CT)	33
8.20	Response to temporary overvoltages on the LV side due to fault conditions on the HV side	33
9	Tests	34
9.1	General	34
9.2	Test conditions	35

9.3	Test of indelibility of marking	35
9.4	Test of reliability of screws, current-carrying parts and connections	36
9.5	Test of reliability of terminals for external conductors	37
9.6	Verification of protection against electric shock	38
9.7	Test of dielectric properties	39
9.7.1	Resistance to humidity	39
9.7.2	Insulation resistance of the main circuits of RCMs classified according to 4.9.2	39
9.7.3	Dielectric strength of the main circuit of RCMs classified according to 4.9.2	40
9.7.4	Insulation resistance and dielectric strength of control and auxiliary circuits	41
9.7.5	Secondary circuit of detection transformers	42
9.7.6	Capability of the RCM to withstand high DC voltages due to insulation measurements	42
9.7.7	Verification of impulse withstand voltages	42
9.8	Test of temperature rise	44
9.8.1	Ambient air temperature	44
9.8.2	Test procedure	44
9.8.3	Measurement of the temperature rise of parts	45
9.8.4	Temperature rise of a part	45
9.9	Verification of the operating characteristics	45
9.9.1	Test circuit	45
9.9.2	Off-load tests with residual sinusoidal alternating currents at the reference temperature of 20 °C ± 2 °C	45
9.9.3	Verification of the correct operation with load at the reference temperature	46
9.9.4	Verification of the connection and the function of an external current transformer (CT)	46
9.9.5	Verification of directional discrimination for RCMs classified according to 4.11	47
9.10	Verification of operational endurance	48
9.10.1	General	48
9.10.2	Test procedure	48
9.11	Verification of short-circuit withstand capability	48
9.11.1	List of the short-circuit tests	48
9.11.2	Short-circuit tests	48
9.12	Verification of resistance to mechanical impact	53
9.12.1	General	53
9.12.2	Test for all RCM types	53
9.12.3	Rail-mounted RCMs	55
9.12.4	Plug-in type RCMs	55
9.13	Test of resistance to heat	55
9.14	Test of resistance to abnormal heat and to fire	56
9.15	Verification of the operation of the test device at the limits of rated voltage	57
9.16	Verification of limiting values of the non-operating current under overcurrent conditions	57
9.16.1	General	57
9.16.2	Verification of the limiting value of overcurrent in the case of a load through an RCM with two current paths	57

9.16.3	Verification of the limiting value of overcurrent in the case of a single-phase load through a three-pole or four-pole RCM.....	58
9.16.4	Verification of the limiting value of overcurrent in the case of a single-phase load through an RCM with an external detecting device (transformer)	58
9.17	Verification of resistance against unwanted operation due to current surges caused by impulse voltages	59
9.18	Void	59
9.19	Additional verification of the correct operation at residual currents with DC components	59
9.19.1	General	59
9.19.2	Verification of the correct operation for RCM Type A, Type F and Type B.....	61
9.19.3	Verification of correct operation for RCM Type F and Type B.....	62
9.19.4	Verification of correct operation for RCM Type B	63
9.20	Verification of reliability.....	66
9.20.1	General	66
9.20.2	Climatic test	66
9.20.3	Test with temperature of 40 °C	68
9.21	Verification of ageing of electronic components	68
9.22	Verification of EMC requirements.....	68
9.22.1	General	68
9.22.2	Description of quiescent mode and operate mode.....	70
9.22.3	Criterion A1	70
9.22.4	Criterion A2	70
9.22.5	Criterion B	70
9.23	Response of the RCM to temporary overvoltages on the LV side, due to fault conditions on the HV side	71
9.24	Test of resistance to rusting.....	71
Annex A (normative) Test sequence and number of samples to be submitted for verification of conformity to this document		102
A.1	General.....	102
A.2	Test sequences	102
A.3	Number of samples to be submitted for full test procedure	103
A.4	Number of samples to be submitted for simplified test procedures in case of submitting simultaneously a range of RCMs of the same fundamental design	103
Annex B (normative) Determination of clearances and creepage distances		106
Bibliography.....		109
Figure 1 – Standing current in FE conductor		72
Figure 2 – Standard test finger (9.6)		73
Figure 3 – Test circuit for verification of the operating characteristics for RCMs.....		74
Figure 4 – Test circuit for verification of directional discrimination in IT systems for RCMs classified according to 4.12		75
Figure 5 – Test circuit for verification of the correct operation of RCMs in the case of residual pulsating direct currents		76
Figure 6 – Test circuit for verification of the correct operation of RCMs in the case of residual pulsating direct currents superimposed by smooth direct current of 0,006 A		78
Figure 7 – Test circuit for verification of the coordination with an SCPD of an RCM with two current paths (9.11).....		79

Figure 8 – Test circuit for verification of the coordination with an SCPD of an RCM with three current paths in a three-phase circuit (9.11)..... 80

Figure 9 – Test circuit for verification of the coordination with an SCPD of an RCM with four current paths on a three-phase circuit with neutral (9.11)..... 81

Figure 10 – Test apparatus for verification of the minimum I^2t and I_p values to be withstood by the RCM (9.11.2.1 a))..... 82

Figure 11 – Mechanical impact test apparatus (9.12.2) 83

Figure 12 – Striking element for pendulum impact test apparatus (9.12.2) 84

Figure 13 – Mounting support for sample for mechanical impact test (9.12.2) 85

Figure 14 – Example of mounting an unenclosed RCM for mechanical impact test (9.12.2)..... 86

Figure 15 – Example of mounting of panel mounting type RCM for the mechanical impact test (9.12.2)..... 87

Figure 16 – Application of force for mechanical test of rail-mounted RCM (9.12.3)..... 88

Figure 17 – Ball-pressure test apparatus (9.13.3) 88

Figure 18 – Test circuit for verification of the limiting value of overcurrent in the case of single-phase load 89

Figure 19 – Current ring wave 0,5 μ s/100 kHz 90

Figure 20 – Test circuit for the ring-wave test of RCMs 90

Figure 21 – Stabilizing period for reliability test (9.20.2.4)..... 91

Figure 22 – Reliability test cycle (9.20.2.4) 92

Figure 23 – Example test circuit for verification of ageing of electronic components (9.21)..... 93

Figure 24 – RCMs without monitored lines connected 94

Figure 25 – RCMs with monitored lines connected 94

Figure 26 – Example of a test circuit for verification of correct operation in case of residual sinusoidal alternating currents composed of multi-frequency components resulting from single-phase supplied speed motor control equipment..... 95

Figure 27 – Test circuit for verification of correct operation in case of residual sinusoidal alternating current up to 1 000 Hz 96

Figure 28 – Test circuit for 2-,3- and 4-pole RCM Type B to verify the correct operation in case of residual pulsating direct currents which may result from rectifying circuits supplied from two phases 97

Figure 29 – Test circuit for 3- and 4-pole RCM Type B to verify the correct operation in case of residual pulsating direct currents which may result from rectifying circuits supplied from three phases..... 98

Figure 30 – Test circuit for 2-, 3- and 4-pole RCM Type B to verify the correct operation in case of a residual smooth direct current 99

Figure 31 – Diagrammatic representation for glow-wire test 100

Figure 32 – Test circuit for 2-, 3- and 4-pole RCM Type B to verify the correct operation in case of a residual alternating current superimposed on a smooth direct current..... 101

Figure B.1 – Illustrations of the application of creepage distances 107

Figure B.2 – Illustrations of the application of creepage distances 108

Table 1 – Marking 21

Table 2 – Standard conditions for operation in service 24

Table 3 – Clearances and creepage distances 26

Table 4 – Connectable cross-sections of copper conductors for screw-type terminals	28
Table 5 – Temperature rise values	31
Table 6 – List of type tests depending on RCM classification	34
Table 7 – Test copper conductors corresponding to the rated currents.....	35
Table 8 – Screw thread diameters and applied torques	36
Table 9 – Pulling forces	37
Table 10 – Conductor dimensions	38
Table 11 – Test voltage of control and auxiliary circuits	41
Table 12 – Rated impulse withstand voltage as a function of the nominal voltage of the installation	44
Table 13 – Test voltage for verification of impulse withstand voltage	44
Table 14 – Silver wire diameter as a function of rated current and short-circuit currents	49
Table 15 – Minimum values of I^2t and I_p	50
Table 16 – Power factors for short-circuit tests	51
Table 17 – Overview of test details for the RCM types	60
Table 18 – Actuating current ranges	61
Table 19 – Frequency component values of test currents and starting current values for verifying operating	62
Table 20 – Operating current ranges for composite residual current.....	62
Table 21 – Residual non-operating and operating current according to frequencies that differ from the rated frequency 50/60 Hz for RCM Type B	64
Table 22 – EMC tests	69
Table 23 – Explanation of letter symbols used in Figure 6 to Figure 9.....	77
Table A.1 – Test sequences.....	102
Table A.2 – Number of samples submitted to tests.....	103
Table A.3 – Tests with a reduced number of samples	105

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL ACCESSORIES – RESIDUAL CURRENT MONITORS (RCMs) –

Part 1: RCMs for household and similar uses

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62020-1 has been prepared by subcommittee 23E: Circuit-breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories.

This first edition cancels and replaces IEC 62020:1998 and IEC 62020:1998/AMD1:2003. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- definition of Type F and Type B RCM;
- marking of Type F and Type B RCM;
- introduction of a new subclause, 8.20;
- modification of 9.7;

- update of 9.9;
- modification of 9.14;
- modification of 9.19, for introduction of the relevant test for Type F and Type B RCM.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
23E/1180/FDIS	23E/1183/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62020 series, published under the general title *Electrical accessories – Residual current monitors (RCMs)*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

INTRODUCTION

The purpose of a residual current monitor (hereinafter referred to as RCM) is to monitor an electrical installation or circuit for the presence of an unbalanced earth fault current and to indicate, by means of an alarm, the presence of such a residual current when it exceeds a predetermined level.

Installation and application rules are given in IEC 60364 (all parts).

ELECTRICAL ACCESSORIES – RESIDUAL CURRENT MONITORS (RCMs) –

Part 1: RCMs for household and similar uses

1 Scope

This document applies to residual current monitors for household and similar purposes, having rated operational voltages and a rated voltage of the monitored circuit not exceeding 440 V AC and rated currents not exceeding 125 A.

NOTE 1 The standard for residual current monitors having rated operational voltages and a rated voltage of the monitored circuit exceeding 440 V AC is in preparation, as IEC 62020-2.

RCMs are intended to monitor the residual current of the installation and to give a warning if the residual current between a live part and an exposed conductive part or earth exceeds a predetermined level.

RCMs covered by this document are not intended to be used as protective devices.

RCMs detect residual currents circulating in an AC circuit (e.g. residual alternating current, residual pulsating direct current, residual smooth direct current), whether suddenly applied or slowly rising.

NOTE 2 RCMs for DC systems are under consideration.

This document applies to monitors performing simultaneously the functions of detection of the residual current, of comparison of the value of this current with the residual operating current of the device and providing the specified warning signal(s) when the residual current exceeds this value.

RCMs supplied by internal batteries are not covered by this document.

The requirements of this document apply for standard conditions (see 7.1). Additional requirements can be necessary for RCMs used in locations having severe environmental conditions.

RCMs are intended for use in an environment with pollution degree 2 and overvoltage category III. For an environment with a higher pollution degree, enclosures giving the appropriate degree of protection are used.

RCMs in compliance with this document are suitable for use in TN, TT, and IT systems.

This document does not cover Insulation Monitoring Devices (IMDs), which are covered by the scope of IEC 61557-8.

NOTE 3 An RCM is distinguished from an IMD in that it is passive in its monitoring function and only responds to an unbalanced fault current in the installation being monitored. An IMD is active in its monitoring and measuring functions in that it can measure the balanced and unbalanced insulation resistance or impedance in the installation (see IEC 61557-8).