



BSI Standards Publication

Copper and copper alloys — Plumbing fittings

Part 5: Capillary fittings with short ends for brazing to copper tubes

National foreword

This British Standard is the UK implementation of EN 1254-5:2021. It supersedes BS EN 1254-5:1998, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee NFE/34/3, Copper and copper alloy fittings for tube and pipe.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 03348 9

ICS 23.040.40

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 1254-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2021

ICS 23.040.40

Supersedes EN 1254-5:1998

English Version

Copper and copper alloys - Plumbing fittings - Part 5: Capillary fittings with short ends for brazing to copper tubes

Cuivre et alliages de cuivre - Raccords - Partie
5 : Raccords à emboîture courte pour brasure
forte par capillarité pour tubes en cuivre

Kupfer und Kupferlegierungen - Fittings - Teil 5:
Kapillarlöt fittings mit geringer Einstecktiefe zum
Verbinden von Kupferrohren mittels Hartlötten

This European Standard was approved by CEN on 23 November 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	iv
Introduction	v
1 Scope	6
2 Normative references	7
3 Terms and definitions	7
4 Product characteristics	7
4.1 Internal pressure.....	7
4.2 Tightness.....	7
4.2.1 Leak tightness under internal hydrostatic pressure.....	7
4.2.2 Integrity of fabricated fitting bodies or having an 'as cast' microstructure.....	8
4.3 Release of dangerous substances.....	8
4.4 Durability.....	8
4.4.1 Durability of internal pressure: Resistance to stress corrosion.....	8
4.4.2 Durability of tightness: Residual carbon contamination in the bore.....	8
4.5 Dimensional tolerances of diameters.....	8
4.6 Wall thickness for short ends for capillary brazing to copper tubes.....	9
4.7 Wall thickness at threaded portions of adaptor fittings.....	11
4.8 Dimensions of tail pipe ends for swivel fittings.....	11
4.9 Dimensions of gas union connectors.....	11
4.10 Threaded end dimensions.....	11
4.11 Other adapter ends (not defined in EN 1254-20:2021).....	11
4.12 Length of engagement.....	11
4.13 Bore dimensions.....	13
4.14 Tube abutment.....	13
4.15 Alignment of the fitting ends.....	14
4.16 Shapes for tightening systems.....	14
4.17 Surface condition.....	14
4.18 Surface cleanliness for medical gases.....	14
5 Testing, assessment and sampling methods	15
5.1 General.....	15
5.1.1 Preparation of fittings for testing.....	15
5.1.2 Test temperature.....	15
5.1.3 Tolerances.....	15
5.2 Internal pressure.....	15
5.3 Tightness: Integrity of fabricated fitting bodies or having an 'as cast' microstructure.....	15
5.4 Durability.....	15
5.4.1 Durability of internal pressure: Resistance to stress corrosion.....	15
5.4.2 Durability of tightness.....	16
5.5 Dimensional tolerances of diameters.....	16
5.6 Wall thickness for short ends for capillary brazing to copper tubes.....	16
5.7 Wall thickness at threaded portions of adaptor fittings.....	16
5.7.1 Type testing.....	16
5.7.2 FPC testing.....	16
5.8 Dimensions of tail pipe ends for swivel fittings.....	16
5.9 Dimensions of gas union connectors.....	16
5.9.1 Type testing.....	16
5.9.2 FPC testing.....	16
5.10 Threaded end dimensions.....	17
5.11 Length of engagement.....	17
5.12 Bore dimensions.....	17
5.13 Alignment of the fitting ends.....	17
6 Evaluation of conformity	17

6.1	General.....	17
6.2	Type testing.....	17
6.2.1	General.....	17
6.2.2	Test samples, testing and compliance criteria.....	18
6.2.3	Test reports.....	19
6.3	Factory production control (FPC).....	19
6.3.1	General.....	19
6.3.2	Equipment.....	20
6.3.3	Raw materials and components.....	20
6.3.4	Product testing and evaluation.....	20
7	Designation.....	21
8	Marking, labelling and packaging.....	21
Annex A (normative) Operating temperatures and corresponding maximum operating pressures.....		22
Bibliography.....		23

European foreword

This document (EN 1254-5:2021) has been prepared by Technical Committee CEN/TC 133 “Copper and copper alloys”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2021, and conflicting national standards shall be withdrawn at the latest by November 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1254-5:1998.

The main changes to EN1254-5:1998 are:

- separation of test methods into part 20.

This part of the standard (EN 1254-5) should be read in conjunction with EN 1254-20:2021.

EN 1254 comprises the following parts under the general title “Copper and copper alloys — Plumbing fittings”:

- *Part 1: Capillary fittings for soldering or brazing to copper tubes*
- *Part 2: Compression fittings for use with copper tubes*
- *Part 3: Compression fittings for use with plastics and multilayer pipes*
- *Part 4: Threaded fittings*
- *Part 5: Capillary fittings with short ends for brazing to copper tubes*
- *Part 6: Push-fit fittings for use with metallic tubes, plastics and multilayer pipes*
- *Part 7: Press fittings for use with metallic tubes*
- *Part 8: Press fittings for use with plastics and multilayer pipes*
- *Part 20: Definitions, thread dimensions, test methods, reference data and supporting information*

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Products complying with this document may be used for several fluids including the transport of water intended for human consumption if they comply with the relevant national, regional or local regulatory provisions applicable in the place of use.

1 Scope

This document specifies product characteristics, assessment methods, compliance criteria of the test results and a designation system for capillary fittings with short ends for brazing to copper tubes e.g. EN 1057, EN 13348, EN 13349, EN 12735-1, EN 12735-2, etc. These fitting ends exist in two forms: end feed fittings and integral brazing ring fittings. For the purposes of joining copper tubes, the fitting ends have a nominal diameter from 14,7 mm to 159 mm. The fittings are designed for a service lifetime up to fifty years.

The fittings are used up to the operating temperatures and corresponding maximum operating pressures as indicated in [Annex A](#).

This document applies to copper alloy fittings. A non-exhaustive list of these copper alloys is given in CEN/TS 13388.

The capillary fittings with short ends for brazing to copper tubes are used with brazing alloys in accordance with alloys specified in EN ISO 17672.

Not all copper alloys that can be used to manufacture fittings can be brazed and those that can be brazed may require different brazing techniques (guidance is provided in in EN 1254-20:2021, Annex A).

Fittings with short ends for capillary brazing may also have threaded end connections. These threaded ends exist with metallic and with non-metallic sealing elements. For the purposes of joining with tubes, pipes, fittings or valves, the threaded ends have a size range from 1/8" to 4".

Adaptor fittings for use with copper tubes may combine short ends for capillary brazing with fitting ends defined in the other parts of EN 1254.

Capillary fittings with short ends for brazing may also have flanged end connections according to EN 1092-3.

Fittings can be produced by machining, metal forming, casting, or fabrication.

Products covered by this document are intended to be used in:

a) liquid applications:

- hot, cold or combined hot and cold water, including systems according to EN 806;
- closed heating systems according to EN 12828;
- cooling systems;
- drainage systems;
- fire protection systems including sprinkler systems according to EN 12845;
- refrigeration systems;
- supply systems for points of consumption with liquid fuels according to EN 12514.

b) gas applications:

- natural gas and liquefied petroleum gas systems with a maximum operating pressure less than or equal to 5 bar according to EN 1775;
- gas line systems with an operating pressure exceeding 0,5 bar for industrial installations and exceeding 5 bar for industrial and non-industrial installations according to EN 15001-1;
- compressed air systems;
- medical gas systems according to EN ISO 7396;
- refrigeration systems.