

NEMA Standards Publication ICS 7.2-2021

Application Guide for AC Adjustable Speed Drive Systems

Published by:

National Electrical Manufacturers Association 1300 North 17th Street, Suite 900 Rosslyn, VA 22209

www.nema.org

© 2022 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications. NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This guide was developed by the Motor and Generator Section and the Industrial Automation Control Products and Systems Section and approved for publication as an application guide of the National Electrical Manufacturers Association. This guide is intended to assist users in the proper selection and application of AC adjustable speed drive systems. The guide is revised periodically to provide for changes in user needs, advances in technology, and changing economic trends. All persons having experience in the selection, use, or manufacture of electric motors and adjustable speed drives are encouraged to submit recommendations that will improve the usefulness of this guide. Inquiries, comments, and proposed or recommended revisions should be submitted to the Motor and Generator Section and the Industrial Automation Control Products and Systems Section by contacting:

NEMA Technical Operations Department National Electrical Manufacturers Association 1300 North 17th Street, Suite 900 Rosslyn, VA 22209

The best judgment of the Motor and Generator Section and the Industrial Automation Control Products and Systems Section on the performance and construction of adjustable speed drive systems is represented in this guide. The guide is based upon sound engineering principles, research, and records of test and field experience. Also involved is an appreciation of the problems of manufacture, installation, and use derived from consultation with and information obtained from manufacturers, users, inspection authorities, and others having specialized experience. For systems intended for general applications, the individual companies through normal commercial contact determined information as to user requirements. Practical information concerning performance, safety, test, construction, and manufacture of adjustable speed drive systems is provided in this guide.

In the preparation and revision of these standards, consideration has been given to the work of other organizations whose standards are in any way related to adjustable speed drive systems. Credit is hereby given to all whose standards may have been helpful in the preparation of this volume.

This application guide was developed jointly by the Industrial Automation Control Products and Systems Section and the Motor and Generator Section. Section approval of the guide does not necessarily imply that all section members voted for its approval or participated in its development. At the time this guide was approved, the Industrial Automation Control Products and Systems Section was composed of the following members:

ABB Inc.—Cary, NC CARLO GAVAZZI, INC.—Buffalo Grove, IL Cummins, Inc.—Minneapolis, MN Danfoss VLT Drives—Loves Park, IL Delta Products Corporation—Research Triangle Park, NC Eaton—Menomonee Falls, WI Electro Switch Corporation—Weymouth, MA Elliott Control Company, Ltd.—Willis, TX Emerson Electric Co.—St. Louis, MO Fuji Electric Corporation—Edison, NJ Generac Power Systems, Inc. —Waukesha, WI Hubbell Incorporated—Shelton, CT Hypertherm Incorporated—Hanover, NH Legrand North America—New London, CT Master Control Systems, Inc.—Lake Bluff, IL Mitsubishi Electric Automation, Inc.—Vernon Hills, IL Nidec Motor Corporation—St. Louis, MO Phoenix Contact, Inc.—Middletown, PA

NEMA ICS 7.2-2021 Page ii

Post Glover Resistors, Inc.—Erlanger, KY
Reliance Controls Corporation—Racine, WI
Rockwell Automation—Milwaukee, WI
Schneider Electric—Andover, MA
SEW-Eurodrive, Inc.—Lyman, SC
Siemens Industry, Inc.—Norcross, GA
TE Connectivity—Harrisburg, MA
TECO-Westinghouse Motor Company—Round Rock TX
Toshiba International Corporation—Houston, TX
Turntide Technologies—Sunnyvale, CA
WAGO Corporation—Germantown, WI
Weidmuller Inc.—Richmond, VA
WorldWide Electric Corporation—Rochester, NY
Yaskawa America, Inc.—Waukegan, IL

Contents

	1	
	Scope	
Section 2	Referenced Standards	2
2.1	Referenced Standards	2
2.2	Other Referenced Standards	2
	Definitions	
Section 4	Description of System Components	
4.1	Load Types	
4.1.1	Variable Torque	
4.1.2	Constant Torque	
4.1.3	Constant Horsepower	
4.2	Motor Types	
4.2.1	General	
4.2.2	Design A	13
4.2.3	Design B	14
4.2.4	Design C	
4.2.5	Design D	
4.2.6	Definite-Purpose Inverter-Fed	
4.2.7	Permanent Magnet Synchronous Motors	
4.2.8	Synchronous Reluctance Motors	
4.3	Control Types	
4.3.1	Typical Power Ratings	
4.3.2	Control Methods	
4.3.3	PWM Techniques	17
	Description of Component Interactions	
5.1	Interaction Between Load and Motor	
5.1.1	Service Factor	
5.1.2	Maximum Safe Operating Speed	
5.1.3	Overspeed Capability	
5.1.4	Direction of Rotation	
5.2	Interaction Between Motor and Control	
5.2.1	Thermal Considerations	
5.2.3	Speed Range	
5.2.4	Acceleration Time	
5.2.5	Deceleration Time/Internal Motor Braking	
5.2.6	Reversal	
5.2.7	Stability	
5.2.8	Bypass	
5.2.9	Motor Terminal Voltage Transients	
5.2.10	Shaft Voltage and Bearing Currents	
5.2.11	Load Reactors and Filters	
5.2.12	Multiple Motors	
5.2.13	Pole Count	44
5.2.14	Connecting High Voltage to the Low Voltage Connection of a Dual Voltage	
	General-Purpose Motor	44
5.3	Interaction Between Control and AC Power Line	
5.3.1	Source Impedance/Short-Circuit Ampere Interrupting Capacity (AIC) Ratings	
5.3.2	Line Variations	
5.3.3	AC Line Power Factor	
5.3.4	Line Harmonic Currents—Adjustable Frequency Control Created	47

5.3.5	Control Protection	49
5.4	Drive System Interactions	50
5.4.1	Efficiency	50
5.4.2	Sound, Vibration, Resonance	
5.4.3	Grounding	
5.4.4	Power Cable Selection	
5.4.5	Electromagnetic Compatibility (EMC)	55
Section 6	Selection of Motor and Control by Application	
6.1	Application Information	
6.2	Motor Selection	57
6.2.1	Determine Motor Enclosure Requirements	57
6.2.2	Determine Motor Torque and Speed Requirements	58
6.2.3	Determine Accelerating and Decelerating Requirements (Time and Load)	59
6.2.4	Overload Capability	60
6.2.5	Determine Type of Duty	60
6.2.6	Other Considerations	
6.3	Control Selection	
6.3.1	Control Type Considerations	
6.3.2	Control and Motor Voltage Considerations	
6.3.3	Control HP/Current Rating Considerations	
6.3.4	Control Enclosure Considerations	
6.3.5	Speed Range and Regulation Considerations	
6.3.6	Bypass Operation Considerations	
6.3.7	Acceleration Time Considerations	
6.3.8	Deceleration and Braking	
6.3.9	Line Harmonic Voltage and Current Considerations	
6.4	Variable Torque Application	
6.4.1	Motor Selection	
6.4.2	Control Selection	
6.5	Constant Torque Application	
6.5.1	Motor Selection	
6.5.2	Control Selection	
6.6	Constant Horsepower Application	
6.6.1	Motor Selection	
6.6.2	Control Selection	
6.7	Loop Position and Tension Control Systems	
6.7.1 6.7.2	General	
6.7.2	· · · · · · · · · · · · · · · · · · ·	
6.7.3	Application Wind and Unwind Drive Systems	
6.8.1	General	
6.8.2	Application	
	Measurements/Instrumentation	
7.1	General	
7.2	Parameter Measurements	
	Sample ASD Application Data Form	
8.1	Application	
8.2	Motor	
8.3	Control	
8.4	Motor Environment	
8.5	Control Environment	
8.6	Connection	
8.7	Other	
-		
Annex R		90

Tables

Notors Above the 250 Frame) Squirrel-Cage Induction Motors	20
Table 5-2 Overspeed Capability of General-Purpose Motors	21
Table 5-3 Overspeed Capability of Definite-Purpose Inverter-Fed Motors	21
Table 5-4 Temperature Rise for General-Purpose Motors—Designs A, B, C, and D	24
Table 5-5 Temperature Rise for Continuous Duty Definite-Purpose Inverter-Fed Motors	25
Table 5-6 Temperature Rise for Definite-Purpose Inverter-Fed Motors	25
Table 5-7 Ambient Temperature at Altitudes for Rated Temperature Rise	28
Table 5-8 Characteristics of the Three Controls	37
Table 5-9 Minimum AIC Ratings	45
Table 5-10 60 Hz Sinewave Dielectric Test Voltage Specified in UL 1569 600 V Type MC Cable vs. Corona Inception Voltage Test Results at 25°C	53
Table 6-1 Constant and Variable Torque Speed Range Examples (Base Speed = 2,500 rpm)	58
Table 6-2 Constant Horsepower Speed Range Examples (Base Speed = 2,500 rpm)	59
Table 6-3 Control Performance Considerations	62
Table 6-4 Torque Control Operating Variables and Deviation Bands	74
Table 6-5 Constant-Force Loop Position Operating Variables and Deviation Band	75
Table 6-6 Loop Operation Operating Variables and Deviation Bands	75
Table 6-7 Tension Control Operating Variables and Deviation Bands	76
Table 6-8 Table Format for Line Speed and Tension Data	79
Table 7-1 Recommended Instrumentation for Parameter Measurement	81

Figures

Figure 3-1 Operating Loop Travel	7
Figure 3-2 Center Winder (Unwinder)	8
Figure 3-3 Surface Winder	8
Figure 4-1 Squared Torque Variation	9
Figure 4-2 Linear Torque Variation	10
Figure 4-3 Constant Torque Load	10
Figure 4-4 Duty Cycles	11
Figure 4-5 Impact Load	12
Figure 4-6 Constant Horsepower Load	13
Figure 4-7 Typical Motor Speed Torque Curves	14
Figure 4-8 Basis of Rating	15
Figure 5-1 Load Cycle Based on Temperature and Time of Operation	27
Figure 5-2 Constant Horsepower Load	30
Figure 5-3 Typical Voltage Response at Motor Terminals	33
Figure 5-4 Peak Voltage Categories When Using 65 ns Rise Time Pulse	35
Figure 5-5 Peak Voltage Categories When Using 160 ns Rise Time Pulse	36
Figure 5-6 Test Results of Peak Motor Voltage Based upon Lead Length for a 5 HP Motor	37
Figure 5-7 Test Results of Peak Motor Voltage Based upon Switching Frequency for a 5 HP Motor (Lead Length of 100 Feet)	38
Figure 5-8 Fluted Bearing Damage Caused by Electrical Current Flow	39
Figure 5-9 Electrical Arc Pit Located on the Inner Raceway of Bearing	39
Figure 5-10 Electric Machine Showing Parasitic Couplings	41
Figure 5-11 Common Mode Basic Circuit	42
Figure 5-12 Shaft Voltage Without Bearing Current 10V/DIV 25µS/DIV	42
Figure 5-13 Shaft Voltage Top 25V/DIV 5μS/DIV and Bearing Current Bottom 500mA/DIV 5μS/DIV	43
Figure 5-14 Types of Drive Power Cables	55
Figure 6-1 A Motor Design Where the Voltage and Torque Corner Points Are the Same	71
Figure 6-2 A Motor Design Where the Torque Corner Point Is at a Lower rpm than the Voltage Corne Point; Base Speed Is at the Torque Corner Point	
Figure 6-3 Torque Control Systems	74
Figure 6-4 Constant Force Loaded Loop—Position Control System	75
Figure 6-5 Hanging and Storage Loop Control System	76
Figure 6-6 Tension Feedback Control System	77

Section 1 Scope

This guide covers AC electrical drive systems, rated 600 volts or less, consisting of three-phase induction motors, voltage-source pulse-width modulated adjustable frequency controls, and associated components. The guide addresses common issues that should be considered in the selection of drive system components and the installation and application of the drive system.