

ASSE/ANSI 1024-2023



Performance Requirements for **Dual Check Backflow Preventers**

ASSE Board Approved: July 2023
ANSI Approved: August 2023
ICS Code: 23 060 50 | 91 140 60



General Information

Neither this standard, nor any portion thereof, may be reproduced without the written consent of ASSE International.

No product may be said to be listed by ASSE unless the manufacturer has applied to ASSE International, has had its product tested by an official ASSE recognized independent laboratory according to the applicable standards, and had its documentation reviewed and approved by the consensus ASSE Seal Control Board. Having completed the aforementioned, the manufacturer may display the ASSE seal on the product.

Instructions for receiving the authorization to display the Seal are available from the ASSE International office. Organizations wishing to adopt or list any ASSE standard should print the ASSE standard number on the cover page first in equal or larger type to that of the adopting or listing organization.

ASSE International
Mokena, Illinois
Copyright © 2023, 2021, 2018, 2004, 1994, 1988, 1979
All rights reserved.

Foreword

This foreword shall not be considered a part of the standard; however, it is offered to provide background information.

ASSE International is dedicated to the preservation of public health and safety through its guiding principle, “Prevention Rather Than Cure.” Preventing the contamination of potable water in plumbing systems is a major objective of ASSE’s Standards Program.

The recognition of probable sources or causes of contamination or pollution of a potable water system whereby it becomes unfit or undesirable for human consumption is vital to the maintenance of its continued potability.

There are two basic and practiced methods for the protection of potable water supplies: Protection by containment is the isolation, by a suitable means, of the system within the premises supplied, which could be a source of contamination or pollution, from the vendor’s or public water supply system.

Protection of each individual outlet within the premises, which could be a source of contamination or pollution, by a suitable device or means.

Protection by containment protects the vendor’s or public water supply only. It does not provide protection within the premises supplied.

In modern plumbing systems, there are many situations where backflow could occur due to backpressure conditions. In some cases, the backflow of pollutants into the potable water system could cause serious health hazards, while in other cases the backflow of pollutants into the potable water system would make it undesirable, yet not a health hazard, to the persons consuming it (low hazard).

This standard focuses on devices known as dual check valves, which will fulfill “low hazard” protective needs.

The devices described are suitable for either protection by containment at residential supply service lines, or protection of individual outlets where pollutants, which could be caused to enter the potable water, are of low hazard.

These devices are generally suitable for cold water service under continuous or intermittent pressure conditions. Usage with hot water is limited to the temperature specified by the manufacturer, and when certified under this standard. This standard was first adopted in 1979 and was the latest addition to ASSE’s backflow prevention standards. Each standard covers a different type of backflow protection device, each tailored to the protective requirements essential to the specific system conditions in which it is installed, and the degree of hazard involved.

This standard was promulgated in accordance with procedures developed by the American National Standards Institute (ANSI).

Compliance with this standard does not imply acceptance by any code group unless the standard has been adopted by the code.

2023 Product Standards Committee

Tsan-Liang Su, PhD – Chairman
Stevens Institute of Technology
Hoboken, NJ, USA

Karl Abrahamson
Saint Paul Department of Safety and Inspections
Cottage Grove, MN, USA

John Bertrand
Watts Water Technologies
Cleveland, OH, USA

Julia Briggs
NSF International
Ann Arbor, MI, USA

William Briggs Jr.
TSF Engineering
New York, NY, USA

Terry Burger (non-voting)
ASSE International
Cleveland, OH, USA

William Chapin
Professional Code Consulting, LLC
Cullman, AL, USA

Steve Ducharme
Piping Industry Technical College/UA 254
Winnipeg, MB, Canada

Mark E. Fish
Zurn Elkay Water Solutions
Cary, NC, USA

Fernando Fernandez
Toto USA Inc.
Ontario, CA, USA

Ron George
Plumb-Tech Design & Consulting Services LLC
Newport, MI, USA

Mark Gibeault
Kohler Company
Kohler, WI, USA

Daniel Gleiberman
Sloan Valve Company
Los Angeles, CA, USA

Brandon Gunnell
Precision Plumbing Products
Portland, OR, USA

Chris Haldiman
Watts Water Technologies
Springfield, MO, USA

Kevin Hardwick
Precision Plumbing Products
Portland, OR, USA

John F. Higdon, P.E.
Merit Brass Company
Matthews, NC, USA

Mike Johnson
Delta Faucet
Indianapolis, IN, USA

Jim Kendzel
American Supply Association
Itasca, IL, USA

Anthony Menafro
State of NJ Department of Community Affairs
Trenton, NJ, USA

Bob Neff
Delta Faucet
Pendleton, IN, USA

David Orton
NSF International
Ann Arbor, MI, USA

Thomas Pitcherello
Self
Bordentown, NJ, USA

Daniel Rademacher
Viega, LLC
Butte, MT, USA

Shabbir Rawalpindiwala
Self
Kohler, WI, USA

Billy Smith
ASPE
Montgomery, AL, USA

Chris White (non-voting)
ASSE International
Mokena, IL, USA

Chris Wright
Ontario Pipe Trades
Dundalk, ON, Canada

ASSE 1024 Working Group

Bert Bain

The Ford Meter Box Company
Wabash, IN, USA

Pete Bertagna

Watts Watter Technologies
Franklin, NH, USA

Kevin Bretzman

The Ford Meter Box Company
Wabash, IN, USA

Terry Burger (non-voting)

ASSE International
Cleveland, OH, USA

Sean Cleary

IAPMO BPI
Scranton, PA, USA

Joseph Feldman

Chudnow Manufacturing
Linden, NJ, USA

Chris Haldiman

Watts Water Technologies
Springfield, MO, USA

Ken Nolan

Watts Water Technologies
North Andover, MA, USA

Tom Valente

CSA Group
Independence, OH, USA

Contents

1.0	General	1
1.1	Application	1
1.2	Scope.....	1
1.3	Reference Standards.....	2
2.0	Test Specimens	2
2.1	Samples Submitted for Test.....	2
3.0	Performance Requirements and Compliance Testing	2
3.1	Connection Torque	2
	Table 1.....	2
3.2	Deterioration at Maximum Rated Temperature and Pressure	3
	Figure 1	3
3.3	Hydrostatic Test	4
	Figure 2	4
3.4	Hydrostatic Leakage Tests of Check Valves	4
3.5	Allowable Pressure Loss at Rated Flow Test.....	5
	Table 2.....	6
3.6	Drip Tightness of Check Valves	7
3.7	Check Valve Operation.....	7
3.8	Dual Check Valve Integrity at Minimum Intermittent Rated Flow	8
	Table 3.....	8
4.0	Detailed Requirements	9
4.1	Materials	9
4.2	Instructions for Marking and Installation	10
5.0	Definitions	11

ASSE/ANSI 1032-2023

Performance Requirements for Dual Check Backflow Preventers

1.0 General

1.1 Application

This standard applies to devices classified as dual check backflow preventers (herein referred to as “device”). The purpose of this device is to keep polluted water from flowing back into the potable water system when pressure is temporarily higher in the polluted part of the system than in the potable water piping. The devices covered by this standard are intended to protect the potable water supply from low hazard pollution at residential service lines and individual outlets. These devices are intended for continuous or intermittent pressure conditions with cold water service. Usage with hot water is limited to the temperature specified by the manufacturer.

1.2 Scope

1.2.1 Description

This device consists of 2 independently acting check valves, internally force loaded to a normally closed position, designed, and constructed to operate under intermittent or continuous pressure conditions.

1.2.2 Size Range

Nominal device sizes shall be 1/4” to 2” (8 to 50 DN).

1.2.3 Working Pressure

The device shall be designed for a maximum working pressure of not less than 160 psi (1103 kPa).

1.2.4 Temperature Range

Cold water service ranges from 40.0 °F to 110.0 °F (4.4 °C to 43.3 °C), or the manufacturer’s maximum rated temperature, whichever is greater.

Hot water service ranges from 40.0 °F to 180.0 °F (4.4 °C to 82.2 °C), or the manufacturer’s maximum rated temperature, whichever is greater.

1.2.5 Flow Capacity

The device shall meet the minimum water flow capacities at or below the maximum pressure loss specified in Section 3.5.

1.2.6 Repairability

The internal parts of the device shall be accessible for inspection, repairs, or replacements. All replaceable parts of the assemblies of the same size and model shall be interchangeable with the original parts.