

95™

**IEEE Recommended Practice for
Insulation Testing of AC Electric
Machinery (2300 V and Above)
With High Direct Voltage**

IEEE Power Engineering Society

Sponsored by the
Electric Machinery Committee



Published by
The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

12 April 2002

Print: SH94982
PDF: SS94982

IEEE Recommended Practice for Insulation Testing of AC Electric Machinery (2300 V and Above) With High Direct Voltage

Sponsor

**Electric Machinery Committee
of the
IEEE Power Engineering Society**

Reaffirmed 30 August 2012

Approved 21 March 2002

IEEE-SA Standards Board

Reaffirmed 24 April 2008

Approved 1 August 2002

American National Standards Institute

Abstract: This recommended practice provides information on the use of high direct voltage for proof tests and for periodic diagnostic tests on the groundwall insulation of stator (armature) windings in ac electric machines.

Keywords: electric machine windings, electrical insulation, high direct voltage

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2002 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 12 April 2002. Printed in the United States of America.

Print: ISBN 0-7381-3245-4 SH94982
PDF: ISBN 0-7381-3246-2 SS94982

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied **“AS IS.”**

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

[This introduction is not part of IEEE Std 95-2002, IEEE Recommended Practice for Insulation Testing of AC Electric Machinery (2300 V and Above) With High Direct Voltage.]

Traditionally, the insulation of rotating machines has been tested for dielectric strength with alternating voltage. In 1952, attention was directed to testing with direct voltage. Since then, high direct voltage has been widely used. Many reports of procedure and results are found in the IEEE Transactions with expressions of widely differing opinion.

In 1957, the Insulation Subcommittee of the IEEE Rotating Machinery Committee appointed a working group to review the existing literature and to prepare a guide for the conduct and interpretation of high direct-voltage insulation tests. It was found that many methods of making the tests have been used and that there was no uniform opinion of their relative merits.

In 1971, the Insulation Subcommittee of the IEEE Rotating Machinery Committee appointed a working group to revise the existing guide to a recommended practice.

In 1996, the Materials Subcommittee of the IEEE Electric Machinery Committee appointed a working group to revise the existing recommended practice. The document has been updated in a number of respects and typical test results using the ramped voltage test method have been included.

At present there is wide usage of high direct voltage for insulation testing, but there are still areas of disagreement regarding the utility of such tests. In this recommended practice every effort has been made to state facts and to indicate what is not certain. This document gives the present opinion and evaluation of high direct-voltage insulation testing of a large number of investigators with experience in a wide area of test activities.

Many of those who have used the methods described in this recommended practice have found them to be satisfactory and a valuable addition to other test procedures. It is hoped that the use of this recommended practice will achieve more uniform results and a fuller understanding and appreciation for the benefits of the high direct-voltage dielectric test.

A general discussion of test procedures, a comparison between alternating and direct-voltage testing, and requirements for high voltage power supplies may be found in Annex A of this recommended practice. For background information on overvoltage testing, see Clause 8 of IEEE Std 56-1977 and see IEEE P62.2/D23.^a

Participants

This document was originally developed by a working group of the Insulation Subcommittee of the IEEE Rotating Machinery Committee. The members of this working group were:

C. D. Sidway, *Chair*
B. R. Loxley, *Secretary*

C. E. Asbury
J. S. Askey
B. M. Cain
A. W. W. Cameron
E. B. Curdts

J. L. Kuehlthau
H. M. Marsden
G. L. Moses
E. R. Scattergood

W. Schneider
H. R. Tomlinson
H. P. Walker
W. A. Weddendorf
E. S. Yates

^aInformation on references can be found in Clause 2.

The 1977 revision was prepared by a working group of the Insulation Subcommittee. The members were:

R. F. Sharrow, Chair

J. M. Brown	E. B. Curdts	W. J. Sheets
A. W. W. Cameron	R. J. Hillen	G. Wolff

This revision was prepared by a working group of the Materials Subcommittee of the Electric Machinery Committee. The members were:

N. E. Nilsson, Chair

R. Bartnikas	B. K. Gupta	L. Rodland
K. Becker	M. Jacobs	L. Rux
J. Grant	W. McDermid	V. Warren
V. Green	B. Nindra	C. A. Wilson

The following members of the balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Paul A. Anderson	John Travis Griffith	James A. Oliver
William E. Anderson	Franklin H. Grooms	Madan Rana
Roy L. Balke	Thomas J. Hammons	R. V. Rebbapragada
William H. Bartley	Adrienne M. Hendrickson	Jesus Martinez
R. Bartnikas	Gary A. Heuston	Rodriguez
K. Becker	Peter H. Landrieu	Charles M. Rowe
Thomas H. Bishop	Antonio J. Marques-Cardoso	James A. Ruggieri
E. A. Boulter	Walter J. Martiny	L. Rux
Steven R. Brockschink	C. V. Maughan	Maurice A. Secrest
Stephen P. Conrad	W. McDermid	John Shea
Roger H. Daugherty	Jeffrey L. McElray Sr.	Daniel Slomovitz
Guru Dutt Dhingra	Donald G. McLaren	Greg C. Stone
James H. Dymond	James R. Michalec	Qi Su
James S. Edmonds	Gary L. Michel	James E. Timperley
Franklin T. Emery	Rihong Mo	Paul Dieter Wagner
Jorge Fernandez-Daher	Daleep C. Mohla	V. Warren
Nirmal K. Ghai	Glenn Mottershead	Karim Younsi
J. Grant	Arthur S. Neubauer	H. Zhu
	N. E. Nilsson	

When the IEEE-SA Standards Board approved this standard on 20 March 2002, it had the following membership:

James T. Carlo, Chair

James H. Gurney, Vice Chair

Judith Gorman, Secretary

Sid Bennett	Toshio Fukuda	Nader Mehravari
H. Stephen Berger	Arnold M. Greenspan	Daleep C. Mohla
Clyde R. Camp	Raymond Hapeman	William J. Moylan
Richard DeBlasio	Donald M. Heirman	Malcolm V. Thaden
Harold E. Epstein	Richard H. Hulett	Geoffrey O. Thompson
Julian Forster*	Lowell G. Johnson	Howard L. Wolfman
Howard M. Frazier	Joseph L. Koepfinger*	Don Wright
	Peter H. Lips	

*Member Emeritus

Also included is the following nonvoting IEEE-SA Standards Board liaison:

Alan Cookson, *NIST Representative*
Satish K. Aggarwal, *NRC Representative*

Andrew D. Ickowicz
IEEE Standards Project Editor

Contents

1.	Overview.....	1
1.1	Scope.....	1
1.2	Purpose.....	1
1.3	Application and limitations.....	1
2.	References.....	3
3.	Definitions.....	4
4.	Test preparations.....	6
4.1	Safety precautions required for high direct-voltage tests	6
4.2	Influencing factors	6
4.3	Gas-cooled machines	8
4.4	Liquid-cooled machines.....	8
4.5	Isolation of the winding from cables and auxiliary equipment.....	8
4.6	Sectionalizing the winding.....	9
5.	Test equipment and connections.....	9
5.1	High direct-voltage test equipment.....	9
5.2	Discharge and grounding provisions	10
5.3	High-voltage test connection to the winding	11
5.4	Test connection to ground.....	12
6.	Test procedure: proof tests.....	12
6.1	Test voltage for acceptance proof testing	13
6.2	Test voltage for maintenance proof testing.....	13
6.3	Voltage application	13
6.4	Discharging and grounding.....	13
6.5	Test results	14
6.6	Insulation failure	14
7.	Test procedure: controlled overvoltage test.....	14
7.1	Test method.....	14
7.2	Test setup	14
7.3	Measured current	15
7.4	Test voltage for controlled overvoltage testing	15
7.5	Initial voltage level	15
7.6	Voltage increments	16
7.7	Discharging and grounding.....	18
7.8	Test results	18
7.9	Use of controlled overvoltage tests.....	26
8.	Fault location	26
9.	Suggested test record	27
Annex A	(informative) Test Procedures.....	29
Annex B	(informative) Bibliography	46

WARNING

Due to high voltage used, dielectric tests should be conducted only by experienced personnel, and adequate safety precautions should be taken to avoid injury to personnel and damage to property.

IEEE Recommended Practice for Insulation Testing of AC Electric Machinery (2300 V and Above) With High Direct Voltage

1. Overview

1.1 Scope

This recommended practice provides uniform methods for testing insulation with high direct voltage. It applies to stator (armature) windings of ac electric machines rated 2300 V or higher. It covers acceptance testing of new equipment in the factory or in the field after installation, and routine maintenance testing of machines that have been in service.

1.2 Purpose

The purpose of this recommended practice is to:

- a) Provide uniform procedures for performing high direct-voltage acceptance tests and routine maintenance tests on the main ground insulation of windings of ac electric machines.
- b) Provide guidance in analyzing the variations in measured current versus applied voltage so that the condition of the insulation can be more effectively assessed.
- c) Compare direct-voltage testing with alternating voltage testing.

1.3 Application and limitations

Testing of machine insulation may be conducted in the factory, in the field during installation, as a condition of acceptance, to verify the efficacy of repairs or maintenance, after a system disturbance or extended outage, and/or on a routine basis during the lifetime of the machine.

High direct-voltage acceptance tests are generally performed to provide some assurance that the winding insulation has a minimum level of electrical strength. Because the inherent electrical strength of sound insulation is well above the usual proof test value, failure during an acceptance test at an appropriate voltage indicates the insulation is unsuitable for service.