



IEEE Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis— Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V

IEEE Power & Energy Society

Sponsored by the
Switchgear Committee

C37.06TM

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

6 November 2009

IEEE Std C37.06TM-2009

IEEE Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis— Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V

Sponsor

**Switchgear Committee
of the
IEEE Power & Energy Society**

Approved 11 September 2009

IEEE-SA Standards Board

Abstract: The preferred ratings of indoor and outdoor high-voltage circuit breakers rated above 1000 V for use in commercial, industrial, and utility installations are described.

Keywords: capacitance switching, dielectric withstand voltage, endurance, gas-insulated substations, high-voltage circuit breakers, interrupting capability, TRV

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2009 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 5 November 2009. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6078-8 STD95977
Print: ISBN 978-0-7381-6079-5 STDPD95977

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std C37.06-2009, IEEE Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis—Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V.

This standard is a revision of ANSI C37.06-2000. It reflects changes needed to coordinate with the final wording contained in the defining IEEE Std C37.04-1999 and corrigendum, IEEE Std C37.04aTM-2003, IEEE Std C37.04bTM-2008, IEEE Std C37.09TM-1999 and corrigendum, IEEE Std C37.09aTM-2005, IEEE PC37.09bTM (Draft 3, September 2009), IEEE Std C37.010TM-1999 and IEEE Std C37.010-2005, and other international standards such as IEC 62271-100:2008 [B5].^{a, b}

ANSI C37.06-2000 and the earlier editions were prepared by working groups sponsored by NEMA. In January 2003, NEMA transferred responsibility for ANSI C37.06 to the IEEE Power & Energy Society Switchgear Committee. IEEE Std C37.06 is now the responsibility of the High-Voltage Circuit Breaker Subcommittee of the IEEE Power & Energy Society, Switchgear Committee.

This introduction summarizes significant substantive and editorial changes between this revision and the 2000 version. It also comments historically on the changes made since the 1987 edition and the evolution of the *preferred ratings standards*. This standard, IEEE Std C37.06-2009, identifies preferred ratings of circuit breakers and does not exclude use of circuit-breaker characteristics not identified in this standard.

The major focus of this revision is to adjust the ratings tables to coordinate with the revised scheme for representation of transient recovery voltage (TRV). The new TRV scheme has been defined and elaborated in IEEE Std C37.04b-2008, IEEE PC37.09b (Draft 3, September 2009), and IEEE Std C37.010-2005, and this revision brings ANSI C37.06-2000 into harmony with those documents.

The manner of representing the TRV has been changed as part of a major effort to harmonize with the TRV requirements in IEC 62271-100:2008 [B5]. Accompanying this change in the TRV representation is the introduction of the rate of rise of recovery voltage (RRRV) ratings.

The representation of TRV in this revision is harmonized with that in IEC 62271-100:2008 [B5]. (A joint IEEE and IEC task force working group was established to solve the problem of TRV envelopes). The new TRV capability of circuit breakers according to IEEE Std C37.04b-2008 is described by two- or four-parameter envelopes rather than the former “1-cosine” and “exponential-cosine” envelopes used in previous editions of this standard. The two-parameter method is used on voltages below 100 kV, and the four-parameter method is used at 100 kV and above. Comprehensive explanations of the two-parameter and the four-parameter methods are provided in this standard.

The technical data of the tables remains very much the same, except that some ratings have been updated to reflect the requirements of the users. In particular, the tables now reflect a first pole to clear factor of 1.3 and 1.5 for effectively grounded and non-effectively grounded systems respectively.

In order to keep the tables of reasonable size, it has been necessary to add tables with the data for the new representation of TRV values. These tables make the ratings easier to understand and simplify use during power testing. The tables provide the preferred values for the inherent (i.e., prospective) TRV. The tables provide the TRV values for 100% terminal faults (T100), as well as for 60%, 30%, and 10% terminal faults (T60, T30, T10), plus the short-line fault and the out-of-phase switching conditions.

Many technical comments have been given in the text along with curves, or details have been listed explicitly in the tables to assist with a summary understanding of the phenomena involved. The explanatory information clauses for the tables are indicated in clauses that follow the tables. It is noted that according to

^a Information on references can be found in Clause 2.

^b The numbers in brackets correspond to those of the bibliography in Annex C.

the IEEE formatting, the Notes on tables are normative (mandatory part of the standard) and that Notes to the text are informative.

Harmonization of voltages was begun with the adoption of 550 kV and 800 kV, replacing 525 kV and 765 kV respectively, in IEC. The transmission voltage classes of 121 kV, 169 kV, and 242 kV were changed to 123 kV, 170 kV and 245 kV (maximum voltages) respectively listed in ANSI C37.06-1997 to complete the harmonization of voltages with IEC.

New symbols for the recovery voltage given in IEEE Std C37.04b-2008 are used in this document, and the correlation between the new and the old symbols is discussed in the “Information” clause referenced in the footnote of the affected tables. The new symbols and TRV representation are in harmony with the revised IEEE Std C37.011™-2005.

To facilitate use of the tables, the individual lines and columns have been identified with line numbers and column numbers.

The TRV values have been revised to reflect the new representation of the TRV, but other key values have not been changed from the 2000 edition.

Throughout this document, the term *peak* traditionally associated with the maximum value of transient or periodic waveform is used. This continues the practice introduced in the 1997 edition, which substituted *peak* for the previously used *crest* term.

In an effort to harmonize with IEC 62271-series standards, new terms *Class S1* and *Class S2* are used to denote traditional terms as *indoor* or *outdoor*. The term *Class S1* circuit breakers is for cable systems (historical predominant use was for indoor circuit breakers) and the term *Class S2* circuit breakers is for overhead line systems (historical predominant use was for outdoor circuit breakers). Definitions are included in IEEE Std C37.04b-2008.

General notes

- 1) For the previous 1-cosine standard waveform envelope, the time-to-peak (T_2) value is equal to 1.138 times the (t_3) parameter value listed in this standard. This is a purely mathematical translation to fit the new TRV representation. The actual TRV that the circuit breaker must withstand is essentially identical under the old system as in the new system. The restated TRV values are consistent with an amplitude factor of 2.0, namely for non-damped systems. The old envelopes were characterized by the time-to-peak value (T_2) and its peak (E_2) was the focal point of the old TRV. In the new scheme, the parameters are (t_3) and (u_c).
- 2) The titles of the tables include the term *prospective TRV* to emphasize that the TRV ratings are for the prospective (inherent to the system) TRVs that would result if unmodified by the interruption process either by the arc voltage, circuit-breaker capacitance, capacitors, and/or of any resistor insertion designed into the circuit breaker.

Specific notes on individual tables

Table 1—The data in Table 1 is essentially the same as in Table 1 of ANSI C37.06-2000 edition for indoor circuit breakers. It has been redesignated for Class S1 circuit breakers, those connected by cables rather than directly to overhead lines. The TRV data has been relocated to Table 2 and Table 3. The historic voltage range factor K has been dropped, as it was eliminated from the rating structure in the 1999 revision of IEEE Std C37.04-1999.

Circuit breakers designed and tested in accordance with the 1979 (or earlier) editions of IEEE C37.04-1999 and IEEE Std C37.09-1999, with a voltage range factor K greater than 1.0, should be applied in accordance with the older standards. The preferred ratings for such circuit breakers are shown in ANSI C37.06-1987.

Table 2 and Table 3—These tables contain the expanded TRV data values for the new two-parameter method representation of TRV for circuit breakers rated below 100 kV. The old “rated time-to-peak” (T_2) values for TRV have been replaced by the new t_3 values in accord with IEEE Std C37.04b-2008. The values are harmonized with the values in IEC 62271-100:2008 [B5] and are based on an amplitude factor of 1.40 for the T100 terminal fault. Table 2 includes values for T100 terminal fault and out-of-phase test conditions, while Table 3 includes values for T100, T60, T30, and T10 terminal faults.

Table 4—This table presents the preferred capacitance current switching ratings for Class S1 circuit breakers applied to capacitance switching classes C0, C1, and C2, in accordance with IEEE Std C37.09a-2005 and C1 and C2 coordinated with IEEE Std C37.04a-2003 and the revised application guide IEEE Std C37.012-2005.

Table 5—This table is similar to new Table 1, but includes the preferred ratings for Class S2 circuit breakers, connected directly to overhead lines. In the 2000 edition, these circuit breakers were designated as outdoor circuit breakers. The values are unchanged from the 2000 edition, except that TRV values have been transferred to new Table 6 and Table 7, and restated in the new two-parameter method representation.

Table 6 and Table 7—These tables contain two-parameter method TRV data reformatted in the same manner as Table 2 and Table 3, except that the short-line fault TRV values for outdoor circuit breakers are added to Table 6. The TRV values are based on an amplitude factor of 1.54 for the T100 terminal fault, as in the 2000 edition.

Table 8—This table presents the preferred capacitance current switching ratings for Class S2 circuit breakers (voltage classes below 100 kV) applied to capacitance switching for classes C0, C1 and C2, in accordance with IEEE Std C37.09a-2005, and coordinated with IEEE Std C37.04a-2003 and the revised application guide IEEE Std C37.012-2005 for C1 and C2 applications, with voltages rated below 100 kV. The Capacitor Subcommittee of the IEEE PES Transmission and Distribution Committee suggested updated values.

Table 9—This table provides preferred ratings for outdoor circuit breakers rated 100 kV and above. It has been modified in a manner similar to Table 5, and TRV values have been transferred to new Table 10, Table 11, Table 12, and Table 13.

Table 10, Table 11, Table 12, and Table 13—These tables contain revised TRV requirements for circuit breakers rated 100 kV and above. Table 10 and Table 11 include values for T100 terminal fault, short-line fault, and out-of-phase conditions using the four-parameter representation of TRV. The values in these two tables differ by the first pole to clear factor (k_{pp}), 1.3 for Table 10 and 1.5 for Table 11. Table 12 and Table 13 contain the corresponding values for T100, T60, T30, and T10 terminal faults, based on the four-parameter method TRV representation for T100 and T60, and the two-parameter method representation for T30 and T10 terminal fault conditions.

Table 14—This table presents the preferred capacitance current switching ratings for classes C0, C1, and C2 in accordance with IEEE Std C37.09a-2005, and coordinated with IEEE Std C37.04a-2003 and the revised IEEE Std C37.012-2005 for C1 and C2, for voltages rated 100 kV and above. The Capacitor Subcommittee of the IEEE PES Transmission and Distribution Committee suggested updated values.

Table 15—This table presents preferred dielectric withstand ratings. It contains no significant changes from Table 4 in the 2000 edition. Lines 5, 7, 10, 12 were added to include the characteristics of some vacuum circuit breakers in service. The interrupter full-wave withstand was removed in the 1997 version, but reinstated (as a Note) in the 2000 revision. Also in the 2000 edition, the creepage distances were revised to coordinate with IEEE Std C37.010-1999.

Table 16—This table presents preferred dielectric withstand ratings for circuit breakers in gas-insulated substations, previously in Table 5 of the 2000 edition. Some ratings were added to represent what is

manufactured today. Medium voltage ratings have been added, and the 3 μ s chopped wave test requirements have been removed to harmonize with IEC.

Table 17—This table presents the schedule of operating endurance capabilities for circuit breakers. Minor modifications have been made.

Table 18—This table presents rated control voltage data, previously in Table 8 of ANSI C37.06-2000. Minor modifications have been made to coordinate with IEEE Std C37.90™-2005 [B8].

Table 19—This table presents minimum reclosing time values, previously in Table 7 of ANSI C37.06-2000. There is no change in content.

Annex A (normative)—This annex describes the symbols used in the tables and is a summary of symbols taken from IEEE Std C37.04b-2008.

Annex B (normative)—This annex describes the symbols used in the tables, and is a summary of symbols taken from IEEE Std C37.04b-2008.

Voltage range factor >1.0—Users should consult ANSI C37.06-1987 when applying indoor circuit breakers with a rated voltage range factor K greater than 1.0.

Line closing switching surge factors—Users should consult ANSI C37.06-1987, Table 7, for line-closing switching surge factors for special purpose 362 kV to 800 kV circuit breakers. Such factors are not circuit-breaker ratings and are based on system characteristics. The table on line closing switching surge values (Table A2 in ANSI C37.06-2000) has been eliminated. Line closing switching surge values were not “ratings” and were the result of a calculation, and not demonstrated during any design test. The reader is referred to ANSI C37.06-1987 and IEEE Std C37.04-1979 for the historical data and discussion.

NOTE 1—Footnotes following tables are normative, i.e., they form part of the table. ^c

NOTE 2—Notes to clauses in the standard are informative, i.e., they are for information and clarification.

NOTE 3—Users are reminded that use of this standard requires selection of one or more alternatives from some of the tables.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

^c Notes in text, tables, and figures of a standard are given for information only and do not contain requirements needed to implement this standard.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the HVCB (High-Voltage Circuit Breaker) Subcommittee PC37.06 had the following membership:

Georges Montillet, *Chair*
W. J. (Bill) Bergman, *Vice Chair*

Roy Alexander	Leslie Falkingham	Yasin Musa
Mike Anderson	Tom Field	Jeffrey Nelson
Mauricio Aristizabal	Marcel Fortin	T. W. Olsen
Stan Billings	Alan Kollar	Miklos Orosz
Wallace Binder	Carl Kurinko	Rod Sauls
Frank Blalock	Helmut Heiermeier	Carl Schneider
Anne Bosma	Luther Holloman	Devki Sharma
John Brunke	Robert Jeanjean	R. Kirkland Smith
Eldridge Byron	Anders Johnson	Brad Staley
Chih Chow	Steve Lambert	Tom Tobin
Patrick Dilillo	Albert Livshitz	Jeff Williams
Randy Dotson	Hua Y. Liu	Charles Wagner
Denis Dufournet	Franco Lo Monaco	Thomas Wolfe
Kenneth Edwards	Bill Long	Richard York
	Tony Mannarino	

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman	Douglas J. Edwards	Albert Livshitz
Steven Alexanderson	Kenneth Edwards	R. Long
Mauricio Aristizabal	Gary Engmann	Lisardo Lourido
Robert Barnett	Paul Forquer	Keith Malmedal
G. Bartok	Marcel Fortin	Frank Mayle
W. J. (Bill) Bergman	Kenneth Gettman	Nigel McQuin
Steven Bezner	James Graham	Jeffrey Merryman
Stan Billings	Keith Gray	Peter Meyer
Wallace Binder	Thomas Grebe	Gary Michel
Michael Bio	Randall Groves	Georges Montillet
Thomas Blair	Helmut Heiermeier	Jerry Murphy
Frank Blalock	Gary Heuston	Jeffrey Nelson
William Bloethe	Scott Hietpas	Michael S. Newman
Anne Bosma	John Horak	Joe Nims
Steven Brockschink	R. Jackson	T. W. Olsen
Steven Brown	James Jones	Miklos Orosz
Ted Burse	Gael Kennedy	Donald Parker
Eldridge Byron	Yuri Khersonsky	Shawn Patterson
Chih Chow	Joseph L. Koepfinger	David Peelo
Stephen Conrad	Boris Kogan	Iulian Profir
Tommy Cooper	David W. Krause	Robert Puckett
Jerry Corkran	Jim Kulchisky	Michael Roberts
Michael Crawford	Saumen Kundu	Timothy Robirds
Alexander Dixon	Carl Kurinko	Charles Rogers
Randall Dotson	Chung-Yiu Lam	Charles Ross
Dana Dufield	Gerald Lee	Steven Sano
Denis Dufournet	George Lester	Bartien Sayogo
Donald Dunn	Hua Liu	Carl Schneider

Devki Sharma
H. Smith
James E. Smith
Jerry Smith
R. Kirkland Smith
David Stone
Paul Sullivan

S. Telander
Dennis Thonsgard
Norbert Trapp
John Vergis
Charles Wagner
Keith Wallace

John Webb
James Wilson
Larry Yonce
Richard York
Janusz Zawadzki
Matthew Zeedyk
Xi Zhu

When the IEEE-SA Standards Board approved this standard on 11 September 2009, it had the following membership:

Robert M. Grow, *Chair*
Thomas Prevost, *Vice Chair*
Steve M. Mills, *Past Chair*
Judith Gorman, *Secretary*

John Barr
Karen Bartleson
Victor Berman
Ted Burse
Richard DeBlasio
Andy Drozd
Mark Epstein

Alexander Gelman
Jim Hughes
Richard H. Hulett
Young Kyun Kim
Joseph L. Koepfinger*
John Kulick

David J. Law
Ted Olsen
Glenn Parsons
Ronald C. Petersen
Narayanan Ramachandran
Jon Walter Rosdahl
Sam Sciacca

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Howard L. Wolfman, *TAB Representative*
Michael Janezic, *NIST Representative*
Satish Aggarwal, *NRC Representative*

Don Messina
IEEE Standards Program Manager, Document Development

Matthew Ceglia
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
1.3 Preferred ratings	2
2. Normative references.....	2
3. General applications to circuit breakers	3
4. Basic definitions applied in this standard	3
5. Preferred ratings for Class S1 circuit breakers for cable systems.....	4
5.1 Information for Table 1, Table 2, and Table 3.....	7
5.2 Information for Table 4 on preferred capacitance current switching ratings for Class S1 cable systems circuit breakers rated below 100 kV	10
6. Preferred rating for Class S2 circuit breakers for line systems rated below 100 kV	11
6.1 Information for Table 5	12
6.2 Information for Table 6 and Table 7.....	15
6.3 Information for Table 8 on preferred capacitance current switching ratings for Class S2 line systems circuit breakers rated below 100 kV	18
7. Preferred ratings for circuit breakers rated 100 kV and above	19
7.1 Information for Table 9	20
7.2 Information for Table 10, Table 11, and Table 12.....	25
7.3 Information for Table 13	28
7.4 Information for Table 14 on preferred capacitance current switching ratings for circuit breakers rated 100 kV and above, including circuit breakers applied in gas-insulated substations	31
8. Preferred dielectrics withstand ratings for circuit breakers	32
8.1 Information for Table 15 and Table 16.....	35
9. Circuit-breaker operation and operating endurance capabilities.....	35
9.1 Information for Table 17	37
10. Control voltage ranges for circuit breakers.....	38
10.1 Information for Table 18	38
11. Rated reclosing times for circuit breakers	40
11.1 Information for Table 19	40
Annex A (normative) TRV symbols used in the tables with the two-parameter method	41
Annex B (normative) Symbols used in the tables with the four-parameter method	43
Annex C (informative) Bibliography.....	46

IEEE Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis— Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection in all circumstances. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This standard applies to all indoor and outdoor types of ac high-voltage circuit breakers rated above 1000 V and rated on a symmetrical current basis.

1.2 Purpose

Inconsistency in application of preferred ratings of high-voltage circuit breakers may result in wrong application of interrupting current and voltage levels.

The recommendations outlined in the following clauses are intended to provide consistent functionality for high-voltage circuit breakers rated above 1000 V.