



ANSI C12.1-2022

*American National Standard for Electric Meters—
Code for Electricity Metering*

Secretariat:

National Electrical Manufacturers Association

Approved: June 9, 2022

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

ANSI standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by The American National Standards Institute, Inc. (ANSI) that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. An American National Standard implies a consensus of those substantially concerned with its scope and provisions. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly, and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The existence of an American National Standard does not in any respect preclude anyone, whether s/he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards. It is intended as a guide to aid the manufacturer, the consumer, and the general public.

The American National Standards Institute, Inc., does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute, Inc. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on this title page.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc., require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209**

© 2022 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

Printed in the United States of America

Foreword (This foreword is not part of American National Standard C12.1-2022)

This American National Standard establishes acceptable performance criteria for electricity meters. Accuracy class designations, current class designations, voltage and frequency ratings, test current values, service connection arrangements, pertinent dimensions, form designations, and environmental tests are covered.

This version of C12.1 has been modified in several areas in an effort to respond to a changing industry and to improve the clarity of some of the tests. In the North American market, electromechanical meters are no longer manufactured and tests related to them have been deprecated. Additional work in the field of electromagnetic compatibility and auxiliary communications device influence has also been included in this version. The content of another standard in this series, ANSI C12.20, has been merged into C12.1 so that there is now a singular document that covers the entire Code for Electricity Metering. Blondel and non-Blondel meters are both covered by this new version of C12.1. C12.20 will be withdrawn with the publication of this version of C12.1.

Most other specifications have been retained from the previous edition. The following is a brief summary of the main changes:

- Polyphase loading has been mandated for all type testing of polyphase meters
- Voltage tests for meters with wide input voltage ranges have been simplified
- Test No. 4: Effect of variation of power factor has been greatly simplified
- Test No. 7: Equality of current circuits has been simplified
- Test No. 10: Effect of register friction has been deprecated
- Test No. 12: Effect of tilt has been deprecated
- Introduction of the Critical Change Value concept for certain External Influence tests
- Test No. 17: Effect of high-voltage line surges has been modernized
- Test No. 18: Effect of external magnetic field has been modernized
- Test No. 26: Effect of radio frequency interference has been modernized
- Test No. 28: Effect of electrostatic discharge (ESD) has been modernized
- Tests 39 through 44: Harmonic Influence have been carried over from C12.20
- Appendices A and B have been modernized
- A section on non-Blondel metering has been added to Appendix A

The Code for Electricity Metering is a body of work that originated over 110 years ago with the first edition released in 1910. Since then, a great many people have dedicated themselves to updating and modernizing this work. This latest edition is dedicated to all the past and present committee members who have demonstrated a passion for Electricity Metering standards development, and upon whose shoulders this latest version stands.

The Secretariat of the Accredited Standards Committee on Electricity Metering, C12, is held by the National Electrical Manufacturers Association (NEMA) and the National Institute of Standards and Technology (NIST). At the time this standard was processed and approved, the C12 Committee had the following members:

Tom Nelson, Chair

Paul Orr, Secretary

Organization Represented:

Aclara
Baltimore Gas and Electric Company
Brooks Utility Products
Duke Energy
Edwards Precision Power
Elevate Energy
EnerNex
Ercot
Eurofins MET Labs
Florida Power & Light Company
Future DOS R&D Inc.
Greeneville Light & Power
Honeywell Smart Energy
Hydro Quebec
Itron, Inc.
Landis+Gyr
Milbank Manufacturing Company
Networked Energy Services Corporation
NIST
Oncor Electric Delivery Company LLC
Pacific Gas and Electric Company
Power Measurements, LLC
Public Service Electric & Gas
Radian Research, Inc.
Sask Power
Schneider Electric
Schweitzer Engineering Laboratories, Inc.
Sensus, A Xylem Brand
Siemens Industry, Inc.
Southern Company
Technology for Energy Corporation
TESCO - The Eastern Specialty Company
The Durham Company
UL Solutions
Watthour Engineering Company, Inc.
Xcel Energy

Name of Representative:

Curt Crittenden
Sean Gorman
Robert Kiessling
Kerry Barnette
Shannon Edwards
Lawrence Kotewa
Aaron Snyder
Don Tucker
Michael DeVilbiss
Eduardo Sotolongo
Avygdor Moise
Ron Zook
Scott Holdsclaw
Jean-Luc Sabourin
Greg Dickson
Matthew Kraus
Shawn Glasgow
Larry Colton
Tom Nelson
Ray Cumpton
Alex Yan
William Hardy
David Ellis
Frank Boudreau
Bin Lu
Piotr Przydatek
Don MacArthur
Andrew Dudding
Fan Zhang
Anthony Bell
Steve Hudson
Tom Lawton
Mark Shoemaker
Scott Hunter
Lea Wren
Dan Nordell

The following members of the C12.1 Committee were actively involved in the revision of this standard:

Curt Crittenden, Chair

Frank Boudreau, Vice Chair

Kerry Barnette	Duke Energy
Frank Boudreau	Radian Research, Inc.
Brent Cain	Itron, Inc.
Curt Crittenden	Aclara Meters LLC
Michael DeVilbiss	Eurofins E&E
Andrew Dudding	Sensus, A Xylem Brand
David Ellis	Public Service Electric & Gas
Tim Everidge	Radian Research, Inc.
Sean Gorman	Baltimore Gas & Electric Company
Dan Gunderson	Minnesota Power
William Hardy	Power Measurements, LLC
Scott Holdsclaw	Honeywell Smart Energy
Steve Hudson	Technology for Energy Corporation
Scott Hunter	UL Solutions
Lawrence Kotewa	Elevate Energy
Robert Lee	Aclara Meters LLC
Tom Nelson	NIST
Dan Nordell	Xcel Energy
Piotr Przydatek	Schneider Electric
Aaron Snyder	EnerNex
Don Tucker	Ercot
John Voisine	Landis+Gyr
Lea Wren	Watthour Engineering Company, Inc.

In addition, the Editorial Committee for the current revision of C12.1 includes the following:

Andrew Dudding	Frank Boudreau
Greg Dickson	Scott Holdsclaw
Brian Cole	Piotr Przydatek
Ron Zook	Shannon Edwards
Zach Hughes	June Sabbah
Joel Canine	Avygdor Moise
David Ellis	Dan Nordell
Bill Hardy	

CONTENTS

Section 1 Scope and References	1
1.1 Scope	1
1.2 References	1
Section 2 Definitions.....	3
Section 3 Standards and Standardizing Equipment	12
3.1 General.....	12
3.2 Traceability paths to the International System of Units, SI.....	12
3.2.1 Direct transfer	12
3.2.1.1 Independent laboratory.....	12
3.2.1.2 Meter laboratory transport standard comparison to an NMI	12
3.2.1.3 Indirect transfer	12
3.3 Meter laboratory	12
3.3.1 Laboratory conditions	13
3.3.2 Reference temperature and humidity	13
3.3.3 Laboratory power sources	13
3.4 Meter shop	13
3.5 Laboratory standards	13
3.5.1 Basic reference standards	13
3.5.2 Transport standards	13
3.6 Periodic verification of reference standards.....	13
3.7 Portable/field/working standard watt-hour meters.....	13
3.8 Performance records	14
3.9 Performance requirements for standard watt-hour meters.....	14
3.9.1 General test conditions	14
3.9.1.1 Test voltage.....	14
3.9.1.2 Test current	14
3.9.1.3 Test phase angle	14
3.9.1.4 Test frequency	14
3.9.1.5 Waveform distortion.....	14
3.9.1.6 Ambient temperature	14
3.9.1.7 External magnetic field	14
3.9.2 Tests for portable and reference standards	14
3.9.2.1 Insulation.....	14
3.9.2.2 Accuracy specification for the effect of variation of voltage and current	15
Section 4 Acceptable Performance of New Types of Electricity Meters and Associated Equipment	16
4.1 General.....	16
4.1.1 Acceptable meters.....	16
4.1.2 Adequacy of testing laboratory	16
4.1.3 Retesting of new meter type	16
4.1.4 Test documentation.....	16
4.1.5 Test device	16

4.1.6	Tests performed as a group.....	16
4.1.7	Handling of failed device.....	16
4.1.8	Restart testing.....	17
4.1.9	Reporting of test meters.....	17
4.2	Types of meters.....	17
4.2.1	Basic type.....	17
4.2.2	Variations within the basic type.....	17
4.2.3	Type designation.....	17
4.2.4	Form designation.....	17
4.2.5	Acceptance of basic types in whole or part.....	17
4.2.6	Minor variations.....	17
4.2.7	Special types.....	17
4.3	Specifications for design and construction.....	17
4.3.1	Sealing.....	17
4.3.2	Enclosures.....	18
4.3.3	Terminals and markings.....	18
4.3.4	Construction and workmanship.....	18
4.3.5	Provision for adjustment.....	18
4.4	Selection of meters for approval tests.....	18
4.4.1	Samples to be representative of the basic type.....	18
4.4.2	Number to be tested.....	18
4.5	Conditions of test.....	19
4.5.1	Tests to be applied.....	19
4.5.2	Configuration.....	19
4.5.3	Meters for special services.....	19
4.5.4	Meters of non-standard classes.....	19
4.5.5	Meters with wide-voltage range.....	19
4.5.6	Meters equipped with an auxiliary communication device (ACD).....	19
4.5.6.1	Reference conditions.....	19
4.5.6.2	Test mode.....	19
4.5.6.3	Test time.....	19
4.5.6.4	Antennas.....	20
4.5.6.5	Multiple ACDs.....	20
4.5.6.6	ACD states.....	20
4.5.6.7	Tests with dormant ACD condition.....	20
4.5.7	Mounting.....	20
4.5.8	Voltage and frequency.....	20
4.5.9	Current classes and test amperes.....	20
4.5.10	Form designations.....	21
4.5.11	Displays.....	23
4.5.11.1	Viewing requirements.....	23
4.5.11.2	Size of digits.....	23
4.5.11.3	Direction of energy flow.....	23
4.5.12	Provisions for testing of calibration.....	23

	4.5.12.1 Requirement for test outputs	23
	4.5.12.2 Physical implementation of test pulse output	23
	4.5.13 Nameplate	24
4.6	Rules governing the acceptance of types	24
4.6.1	Tolerances	24
4.6.2	Determination of failure and rejection	24
	4.6.2.1 Failure	24
	4.6.2.2 Meter type certification rejection criteria	24
4.7	Performance requirements	26
4.7.1	Test conditions	26
	4.7.1.1 Loading for accuracy tests	26
	4.7.1.2 List of type tests	28
4.7.2	Accuracy tests, internal influences	31
	4.7.2.1 Test No. 1: No load.....	31
	4.7.2.2 Test No. 2: Starting load.....	32
	4.7.2.3 Test No. 3: Load performance	33
	4.7.2.4 Test No. 4: Effect of variation of power factor.....	34
	4.7.2.5 Test No. 5: Effect of variation of voltage	37
	4.7.2.6 Test No. 6: Effect of variation of frequency.....	39
	4.7.2.7 Test No. 7: Equality of current circuits	40
	4.7.2.8 Test No. 8: Meter losses.....	40
	4.7.2.9 Test No. 9: Temperature rise	41
	4.7.2.10 Test No. 10: Effect of register friction.....	45
	4.7.2.11 Test No. 11: Effect of internal heating.....	46
	4.7.2.12 Test No. 12: Effect of tilt	47
	4.7.2.13 Test No. 13: Stability of performance.....	47
	4.7.2.14 Test No. 14: Effect of phase sequence reversal	48
4.7.3	Performance tests, external influences	49
	4.7.3.0 Performance verification.....	49
	4.7.3.1 Test No. 15: Insulation.....	50
	4.7.3.2 Test No. 16: Voltage interruptions test.....	51
	4.7.3.3 Test No. 17: Effect of high-voltage line surges.....	51
	4.7.3.4 Test No. 18: Effect of external magnetic field.....	53
	4.7.3.5 Test No. 19: Effect of variation of ambient temperature.....	54
	4.7.3.6 Test No. 20: Effect of temporary overloads	58
	4.7.3.7 Test No. 21: Effect of current surges in ground conductors.....	59
	4.7.3.8 Test No. 22: Effect of superimposed signals	59
	4.7.3.9 Test No. 23: Effect of voltage variation—secondary time base	59
	4.7.3.10 Test No. 24: Effect of variation of ambient temperature— secondary time base	59
	4.7.3.11 Test No. 25: Effect of electrical fast transient/burst test.....	60
	4.7.3.11a Test No. 25a: Effect of electrical oscillatory SWC test.....	62
	4.7.3.12 Test No. 26: Effect of radio frequency interference	63
	4.7.3.13 Test No. 27: Radio frequency conducted and radiated emission test	65

4.7.3.14	Test No. 28: Effect of electrostatic discharge (ESD).....	69
4.7.3.15	Test No. 29: Effect of storage temperature	70
4.7.3.16	Test No. 30: Effect of operating temperature	70
4.7.3.17	Test No. 31: Effect of relative humidity	71
4.7.3.18	Test No. 32: Mechanical shock.....	71
4.7.3.19	Test No. 33: Transportation drop.....	71
4.7.3.20	Test No. 34: Mechanical vibration	72
4.7.3.21	Test No. 35: Transportation vibration	72
4.7.3.22	Test No. 36: Weather simulation test	72
4.7.3.23	Test No. 37: Salt-spray test	72
4.7.3.24	Test No. 38: Rain tightness.....	73
4.7.4	Harmonics influence—effect of non-sinusoidal waveforms	73
4.7.4.1	Test No. 39: 90 degree phase fired waveform	74
4.7.4.2	Test No. 40: Quadriform waveform.....	76
4.7.4.3	Test No. 41: Peaked waveform.....	78
4.7.4.4	Test No. 42: Pulse waveform	80
4.7.4.5	Test No. 43: Multiple zero crossings on current	82
4.7.4.6	Test No. 44: Multiple zero crossings on voltage.....	84
Section 5 Standards for New and In-Service Performance.....		86
5.0	General principles	86
5.0.1	Purpose	86
5.0.1.1	New metering devices	86
5.0.1.2	In-service metering devices.....	86
5.0.2	Tests	86
5.0.2.1	As-found tests	86
5.0.2.2	As-left tests	86
5.0.2.3	Metering devices removed from service	86
5.0.2.4	Metering devices returned to service	86
5.0.3	Performance tests	87
5.0.3.1	Objectives	87
5.0.3.2	New metering device acceptance testing	87
5.0.3.3	In-service metering devices.....	87
5.0.3.4	Test plans.....	88
5.0.3.5	Test records	89
5.1	Watt-hour meters.....	90
5.1.1	Accuracy requirements	90
5.1.1.1	Test loads.....	90
5.1.1.2	Acceptable performance	90
5.1.1.3	Adjustment limits.....	90
5.1.1.4	Acceptable performance for electronic registers	90
5.1.2	Tests	90
5.1.2.1	New meters and as-found tests	90
5.1.2.2	As-left tests	90
5.1.2.3	Meters returned to service.....	90

5.1.3	Test plans	90
5.1.3.1	Periodic interval plan	90
5.1.3.2	Performance monitoring of new types of meters	91
5.1.4	Determination of average percentage registration	91
5.1.4.1	Method 1	91
5.1.4.2	Method 2	91
5.1.4.3	Method 3	91
5.1.4.4	Method 4	91
5.2	Instrument transformers, magnetic (external to meter)	91
5.2.1	Pre-installation tests	91
5.2.2	Instrument transformers removed from service	92
5.2.3	Performance tests	92
5.2.3.1	Burden test.....	92
5.2.3.2	Secondary voltage test.....	92
5.2.4	Inspection	92
5.3	Coupling capacitor voltage transformers (external to meter)	92
5.3.1	Performance tests	92
5.4	Integrated communication devices.....	92
5.4.1	Performance tests	92
5.5	Service switches (integrated and external to meter)	92
5.5.1	Performance tests	92
5.6	Demand and interval registers (integrated).....	93
5.6.1	Accuracy requirements	93
5.6.1.1	Acceptable performance for new demand or interval registers	93
5.6.1.2	In-service acceptable performance.....	93
5.6.1.3	Test points.....	93
5.6.1.4	Adjustment limits.....	93
5.6.1.5	Performance limits	93
5.7	Other energy measurement devices not already listed (integrated and external to meter)	93
5.7.1	Pulse recorder accuracy requirements.....	93
5.7.1.1	Acceptable performance for pulse recorders.....	93
5.8	Other non-energy measurement devices in a metering device circuit (integrated and external to meter).....	94
Section 6 Auxiliary Pulse Devices for Electricity Metering		95
6.1	General.....	95
6.1.1	Information to be shown on pulse initiator	95
6.1.2	Information to be shown on pulse amplifier or relay	95
6.1.3	Information to be shown on pulse totalizers	95
6.2	Tests to be applied.....	95
6.3	Performance requirements	95
6.3.1	Test conditions	95
6.3.2	Initial conditions	96
6.3.3	Mechanical load.....	96
6.3.4	Insulation.....	96

6.3.5	Performance test	96
6.3.6	Sunlight interference test—pulse devices containing optical sensors.....	96
Appendix A Measurement of Power, Energy, and Related Quantities		100
A.1	Measurement of power	100
A.1.1	Introduction	100
A.1.2	Blondel's theorem.....	100
A.1.3	Direct-current services	100
A.1.3.1	Two-wire direct-current services	100
A.1.3.2	Three-wire direct-current services.....	100
A.1.3.3	Ammeter and voltmeter method.....	100
A.1.4	Single-phase alternating-current services	101
A.1.4.1	Single-phase two-wire services.....	101
A.1.4.2	Single-phase three-wire services	101
A.1.5	Two-phase services	101
A.1.5.1	Two-phase three-wire services	101
A.1.5.2	Two-phase four-wire services	101
A.1.5.3	Two-phase five-wire services	101
A.1.5.4	Balanced two-phase services	101
A.1.6	Three-phase services.....	101
A.1.6.1	Three-wattmeter method	101
A.1.6.2	Two-wattmeter method.....	101
A.1.6.3	Balanced three-phase services.....	102
A.2	Measurement of energy	102
A.2.1	Basic considerations	102
A.2.1.1	Voltage-sensor connection.....	102
A.2.1.2	Application of Blondel's theorem.....	102
A.2.1.3	Watt-hour meter element.....	102
A.2.2	Direct-current or single-phase services	102
A.2.2.1	Two-wire direct-current and single-phase services	102
A.2.2.2	Three-wire direct-current and single-phase services	102
A.2.2.3	Single-phase three-wire services with balanced voltages	103
A.2.2.4	Large-capacity or high-voltage direct-current meters.....	103
A.2.2.5	Large-capacity or high-voltage alternating-current meters	103
A.2.3	Open wye services	103
A.2.4	Two-phase services	103
A.2.4.1	Two-phase three-wire services	103
A.2.4.2	Two-phase four- or five-wire services	104
A.2.4.3	Two-phase five-wire services with balanced voltages	104
A.2.5	Three-phase services, all types	104
A.2.5.1	Methods comparable to power measurements	104
A.2.6	Three-phase three-wire services	104
A.2.6.1	Two-element method.....	104
A.2.6.2	Three-element method	104
A.2.6.3	Balanced voltage and load	104

A.2.7	Three-phase four-wire wye services.....	104
	A.2.7.1 Three-element four-wire wye meter.....	104
	A.2.7.2 Two-and-a-half-element four-wire wye meter.....	105
A.2.8	Three-phase four-wire delta services.....	105
	A.2.8.1 Possible methods of metering.....	105
	A.2.8.2 Three-element four-wire delta meter.....	105
	A.2.8.3 Two-element four-wire delta meter.....	105
A.2.9	Three-phase seven-wire double wye-connected services.....	105
	A.2.9.1 Three single-phase three-wire elements.....	105
A.2.10	Basic meter design considerations.....	105
A.2.11	Factors affecting meter accuracy.....	106
	A.2.11.1 Light loads.....	106
	A.2.11.2 Variations in voltage.....	106
	A.2.11.3 Variations in power factor.....	106
	A.2.11.4 Variations in frequency.....	106
	A.2.11.5 Variations in temperature.....	106
	A.2.11.6 External magnetic fields.....	106
	A.2.11.7 Load range.....	107
	A.2.11.8 Surges.....	107
	A.2.11.9 Adverse environmental conditions.....	107
A.3	Measurement of power factor.....	107
	A.3.1 Single-phase two-wire services.....	107
	A.3.2 Single-phase and polyphase services.....	107
	A.3.3 Balanced three-phase three-wire services.....	108
	A.3.4 System power factor.....	108
	A.3.5 Interval power factor.....	108
A.4	Measurement of reactive energy (varhours, quadergy).....	108
	A.4.1 Q-hour method.....	108
	A.4.2 Electronic meters.....	109
A.5	Non-Blondel metering applications.....	109
	A.5.1 Introduction.....	109
	A.5.2 The single-phase 2S application.....	110
	A.5.3 A vector approach to power computation.....	111
	A.5.3.1 Analysis of 12S and 2S metering of a three-wire single-phase application.....	112
	A.5.3.2 Analysis of 4-wire wye metering using two-element meters (Forms 5S, 26S, 45S, 66S).....	117
	A.5.3.3 Analysis of 4-wire wye metering using 2.5 element meters (Forms 6S, 7S, 14S, 29S, 36S, 46S).....	118
	A.5.3.4 Analysis of 4-wire delta metering using two-element meters (Forms 5S, 45S).....	119
	A.5.3.5 Analysis of 4-wire delta metering using 2.5 element meters (Forms 8S, 15S, 24S).....	120
A.5.4	Conclusions.....	122

Appendix B Standards and Standardizing Equipment	124
B.1 General.....	124
B.2 Final authority.....	124
B.2.1 Electrical units.....	124
B.2.1.1 Current	124
B.2.1.2 Time	124
B.2.1.3 Force	125
B.2.1.4 Energy	125
B.2.1.5 Power	125
B.2.1.6 Electric potential.....	125
B.2.1.7 Resistance	125
B.2.1.8 Charge	125
B.2.1.9 Capacitance	125
B.2.1.10 Magnetic flux	125
B.2.1.11 Inductance	125
B.3 This section has been removed	125
B.4 Establishing a local reference standard of energy.....	125
B.4.1 Meter laboratory	127
B.4.2 Meter shop.....	127
B.4.3 Independent standards laboratory.....	127
B.5 Laboratory conditions.....	127
B.5.1 Reference temperature and humidity	127
B.5.2 Laboratory power sources	128
B.6 Laboratory reference standards	128
B.6.1 Stability of reference standards	128
B.6.2 Basic reference standards	128
B.6.2.1 Intercomparison	129
B.6.3 Transport standards	129
B.6.4 Voltage references	129
B.6.4.1 Standard cells	129
B.6.4.2 Unsaturated standard cells.....	129
B.6.4.3 Solid state voltage standards	129
B.6.5 Standard resistors	129
B.6.6 DC ratio devices	129
B.6.6.1 Reference standard volt box	129
B.6.6.2 Reference voltage dividers.....	130
B.6.6.3 Universal ratio set and Kelvin-Varley divider	130
B.6.6.4 Resistance bridges	130
B.6.6.5 Direct-current comparator	130
B.6.7 AC ratio devices	130
B.6.7.1 Transformer test set.....	130
B.6.8 AC-DC transfer standards.....	130
B.6.8.1 Stability	130
B.6.9 Reference standard of energy	131

B.6.10	Time interval	131
B.6.11	Periodic verification of reference standards	131
B.7	Laboratory secondary standards	131
B.7.1	Voltage measuring equipment	131
B.7.2	Indicating instruments	131
B.7.2.1	Measurement uncertainty	131
B.7.2.2	Instrument bearings or suspensions	131
B.7.2.3	Range extension	131
B.7.3	Watt-hour meters	132
B.7.4	Calibration checks	132
B.7.4.1	Voltage measuring accessories	132
B.7.4.2	Digital voltmeter (multimeters) calibrations	132
B.7.4.3	Calibration of indicating instruments	132
B.7.4.4	Watt-hour meters	132
B.8	Shop instruments	132
B.8.1	Indicating instruments	132
B.8.2	Portable standard watt-hour meters	133
B.9	Performance records	133
B.9.1	Importance of records	133
B.10	Abnormal conditions	133
B.11	This section has been removed	133
B.12	Acceptable performance of standard watt-hour meters	133
B.12.1	General	133
B.12.1.1	Optional provision for pulse output	134
B.12.1.2	Overcurrent protection	134
B.12.1.3	Nameplate	134
B.12.2	This section has been removed	134
B.12.3	Mechanical requirements for reference standard meters	134
B.12.3.1	General	134
B.12.3.2	Adjusting devices	134
B.12.3.3	Device orientation	134
B.12.3.4	Case	134
B.12.3.5	Sealing	134
B.12.3.6	Window	135
B.12.3.7	Terminals	135
B.12.3.8	Digital readouts	135
B.12.3.9	Provision for pulse output	135
Appendix C Registration and Meter Constants		136
C.1	General	136
C.2	Symbols	136
C.3	Object of the test	136
C.4	Test procedure	136
C.5	Allowed effect	136
C.6	Mandatory testpoints	136

Appendix D Periodic Testing Schedule	137
Appendix E Variable Interval Plan	138
Appendix F 90 Degree Phase Fired Waveform Definitions	139
F.1 Fourier construction of 90 degree phase fired current waveform with same peak as I_{ref}	139
F.2 Sine construction of 90 degree phase fired current waveform with same peak as I_{ref}	139
Appendix G Type B Optical Test Output Port (OTOP)	142
G.0 Type B—separate port for OTOP	142
G.1 Physical specifications	142
G.2 Output optical characteristics	142
Appendix H Historical Background	144
H.1 Preface to the First Edition (1910)	144
H.2 Preface to the Second Edition (1922)	145
H.3 Preface to the Third Edition (1928)	145
H.4 Preface to the Fourth Edition (1941)	146
H.5 Preface to the Fifth Edition (1965)	147
H.6 Preface to the Sixth Edition (1975)	148
H.7 Foreword to the Seventh Edition (1982)	150
H.8 Foreword to the Eighth Edition (1988)	151
H.9 Foreword to the Ninth Edition (1995)	154
H.10 Foreword to the Tenth Edition (2001)	155
H.11 Foreword to the Eleventh Edition (2008)	157
H.12 Foreword to the Twelfth Edition (2014)	159

TABLES

Table 1 Maximum Percent Errors at Reference Conditions	15
Table 2 Maximum Percent Errors with Variation of Voltage and Current	15
Table 3 Current Classes and Test Amperes	20
Table 4 Typical Blondel Meter Form Designations	21
Table 5 Typical Non-Blondel Meter Forms.....	22
Table 6 Table of Failures Based on the Number of Meters Tested	25
Table 7 Polyphase Service Loading for Use on Accuracy Tests	27
Table 8 ABC Phase Sequence, Current and Voltage Phase Angles Stated Relative to V_A	28
Table 9 CBA Phase Sequence, Current and Voltage Phase Angles Stated Relative to V_A	28
Table 10 List of Type Tests.....	30
Table 11 Starting Load Test.....	32
Table 12 Load Performance Test.....	33
Table 13 ACD Extreme State Load Performance Test.....	34
Table 14 Effect of Variation of Power Factor Performance Test.....	36
Table 15 Effect of Variation of Voltage	37
Table 16 Effect of Variation of Voltage on Solid State Auxiliary Devices.....	39
Table 17 Effects of Variation of Frequency	39
Table 18 Equality of Current Circuits for Multi-Current Circuit Meters	40
Table 19 Temperature-Rise Test Specifications.....	41
Table 20 Effect of Internal Heating for Current Classes 2, 10, and 20.....	46
Table 21 Effect of Internal Heating for Current Classes 100, 200, and 320	47
Table 22 Limits for Stability of Performance	48
Table 23 Limits for Phase Sequence Reversal.....	48
Table 24 Selected Coupling Modes for Power Line Surge Testing.....	52
Table 25 Effect of External Magnetic Field.....	54
Table 26 Effect of Variation of Ambient Temperature.....	56
Table 27 Effect of Variation of Ambient Temperature for Temperatures $> +50^{\circ}\text{C}$ and $< -20^{\circ}\text{C}$	57
Table 28 Effect of Variation of Temperature on Solid State Auxiliary Devices	58
Table 29 Effect of Temporary Overloads on Accuracy.....	58
Table 30 Effect of Current Surge in Ground Conductor	59
Table 31 Test Modes, Voltage, and Application for Each External Connection Group, Oscillatory Test	62
Table 32 Maximum Difference in Energy Accumulation, Radiated Interference	63
Table 33 Maximum Difference in Energy Accumulation, Conducted Interference	64
Table 34 Current Test Values for I_{ref}	74
Table 35 Effect of Harmonic Influence: 90 Degree Phase Fired Current Waveform Performance Requirements	75
Table 36 Quadriform Waveform	76
Table 37 Effect of Harmonic Influence: Quadriform Waveform Performance Requirements	77
Table 38 Peaked Waveform	78
Table 39 Effect of Harmonic Influence: Peaked Waveform Performance Requirements	79
Table 40 Pulse Waveform.....	80
Table 41 Effect of Harmonic Influence: Pulse Waveform Performance Requirements.....	81
Table 42 Multiple Zero Crossing Current Waveform	82

Table 43 Effect of Harmonic Influence: Multiple Zero Crossing Current Waveform Performance Requirements	83
Table 44 Multiple Zero Crossing Voltage Waveform	84
Table 45 Effect of Harmonic Influence: Multiple Zero Crossing Voltage Waveform.....	85
Table 46 Performance Test, Pulse Devices.....	96
Table 47 Common Non-Blondel Applications	109
Table 48 Errors Under Various 2s Application Conditions	114
Table 49 Errors Under Various 4-Wire Wye Non-Blondel Applications	119
Table 50 Errors Under Various 4-Wire Delta Non-Blondel Applications.....	122
Table 51 Periodic Testing Schedule.....	137
Table 52 Variable Interval Plan.....	138
Table 53 90 Degree Phase Fired Waveform	141
Table 54 Type B Transmitter Performance	142

FIGURES

Figure 1 Diagram of Quadrants 35

Figure 2 Location of Temperature Detectors 42

Figure 3 Dimensions for Jumper Bars of Simulated Meter Temperature-Rise Test for Single-Phase and Polyphase Meters (Maximum Rating 100 A)..... 43

Figure 4 Dimensions for Jumper Bars of Simulated Meter Temperature-Rise Test for Single-Phase and Polyphase Meters (Maximum Rating 101 – 200 A Rating)..... 44

Figure 5 Dimensions for Jumper Bars of Simulated Meter Temperature-Rise Test for Single-Phase and Polyphase Meters (Maximum Rating 201 – 320 A Rating)..... 45

Figure 6 Magnetic Field Orientations 1, 2, and 3 54

Figure 7 Test No. 25 Electrical Fast Transient/Burst Direct Connection..... 61

Figure 8 Test No. 25 Electrical Fast Transient/Burst Capacitive Clamp Connection 61

Figure 9 Typical Test Layout for Test 26a: Effect of Radio Frequency Radiated Interference, Reference 4.7.3.12.1 64

Figure 10 Typical Wiring Diagram for Test 26b—Conducted Interference 65

Figure 11 Typical Test Layout for Test 27—Radiated and Conducted Emissions, Reference 4.7.3.13 66

Figure 12 Typical Wiring Detail for Self-Contained Meters for Test 27—Radiated and Conducted Emissions, Reference 4.7.3.13 67

Figure 13 Typical Wiring Detail for Transformer Rated Meters for Test 27—Radiated and Conducted Emissions, Reference 4.7.3.13 68

Figure 14 Typical GTEM Test Layout for Radiated Interference Test 26a, Reference 4.7.3.12..... 69

Figure 15 90 Degree Phase Fired Waveform 74

Figure 16 Quadriform Waveform 76

Figure 17 Peaked Waveform 78

Figure 18 Pulse Waveform 81

Figure 19 Multiple Zero Crossing Current Waveform 82

Figure 20 Multiple Zero Crossing Voltage Waveform 84

Figure 21 Sunlight Interference Test 98

Figure 22 Variable Angles Sunlight Interference Test 99

Figure 23 2S Meter Connections..... 110

Figure 24 2S Meter Application 111

Figure 25 Single-Phase, 3-Wire Vector Diagrams..... 112

Figure 26 2S Errors at PF=1.0..... 116

Figure 27 5S Metering Application 117

Figure 28 6S Metering Application 118

Figure 29 5S Metering Application 120

Figure 30 8S Metering Application 121

Figure 31 Traceability Path Diagram 126

Figure 32 90 Degree Phase Fired Waveform 140

Figure 33 Type B Transmitter Performance..... 143

< This page left blank intentionally. >

Section 1 Scope and References

1.1 Scope

This standard establishes acceptable performance criteria for new types of AC watthour meters, demand meters, demand registers, pulse devices, and auxiliary devices. It also describes acceptable in-service performance levels for meters and devices used in revenue metering. It also includes information on related subjects, such as recommended measurement standards, installation requirements, test methods, and test schedules. This Code for Electricity Metering is designed as a reference for those concerned with the art of electricity metering, such as utilities, manufacturers, and regulatory bodies.

Where differences exist between the requirements of this standard and the most current version of ANSI C12.10, the requirements of this standard shall prevail.

1.2 References

The following publications shall be used in conjunction with this standard. When they are superseded by an approved revision, the latest approved revision shall apply:

ANSI C12.7-2014 *Requirements for Watthour Meter Sockets*

ANSI C12.10-2011 *Physical Aspects of Watthour Meters—Safety Standard*

ANSI C12.18-2006 (R2016) *Protocol Specification for ANSI Type 2 Optical Port*

ANSI/ASQ Z1.4-2003 (R2018) *Sampling Procedures and Tables for Inspection by Attributes*

ANSI/ASQ Z1.9-2003 (R2018) *Sampling Procedures and Tables for Inspection by Variables for Percent Nonconforming*

ANSI/IEEE C63.4-2014 *Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz*

ASTM B117-2019 *Standard Practice for Operating Salt Spray (Fog) Apparatus*

ASTM G155-2013 *Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non-Metallic Materials*

Code of Federal Regulations (Telecommunication) CFR 47, Part 15—*Radio Frequency Devices, Subparts A—General and B—Unintentional Radiators*

Chapter 19 “The Customers’ Premises, Service and Installations,” *Handbook for Electricity Metering, 11th Edition, Washington, D.C.: Edison Electric Institute, 2014*

IEC 61000-4-3:2020 *Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-6:2013 *Electromagnetic compatibility (EMC) - Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields*

IEEE 1-2000 *IEEE Recommended Practice - General Principles for Temperature Limits in the Rating of Electrical Equipment and for the Evaluation of Electrical Insulation*

IEEE C37.90.1-2012 *IEEE Standard Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus*