BS EN IEC 61326-2-4:2021



**BSI Standards Publication** 

bsi.

# Electrical equipment for measurement, control and laboratory use — EMC requirements

Part 2-4: Particular requirements — Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9

#### National foreword

This British Standard is the UK implementation of EN IEC 61326-2-4:2021. It is identical to IEC 61326-2-4:2020. It supersedes BS EN 61326-2-4:2013, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/65, Measurement and control.

A list of organizations represented on this committee can be obtained on request to its committee manager.

#### **Contractual and legal considerations**

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2021 Published by BSI Standards Limited 2021

ISBN 978 0 539 03114 0

ICS 17.220.20; 25.040.40; 33.100.01; 33.100.20

## Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2021.

#### Amendments/corrigenda issued since publication

Date Text affected

## EUROPEAN STANDARD

### NORME EUROPÉENNE

## EUROPÄISCHE NORM

June 2021

EN IEC 61326-2-4

ICS 25.040.40; 17.220.20; 33.100.20

Supersedes EN 61326-2-4:2013 and all of its amendments and corrigenda (if any)

**English Version** 

Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 2-4: Particular requirements -Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9

#### (IEC 61326-2-4:2020)

Matériel électrique de mesure, de commande et de laboratoire - Exigences relatives à la CEM - Partie 2-4: Exigences particulières - Configurations d'essai, conditions de fonctionnement et critères de performance pour les contrôleurs d'isolement conformes à l'IEC 61557-8 et pour les dispositifs de localisation de défaut d'isolement conformes à l'IEC 61557-9 (IEC 61326-2-4:2020) Elektrische Mess-, Steuer-, Regel- und Laborgeräte - EMV-Anforderungen - Teil 2-4: Besondere Anforderungen -Prüfanordnung, Betriebsbedingungen und Leistungsmerkmale für Isolationsüberwachungsgeräte nach IEC 61557-8 und Geräte zur Isolationsfehlerortung nach IEC 61557-9 (IEC 61326-2-4:2020)

This European Standard was approved by CENELEC on 2020-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2021 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

#### **European foreword**

The text of document 65A/981/FDIS, future edition 3 of IEC 61326-2-4, prepared by SC 65A "System aspects" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61326-2-4:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2021-12-04 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2024-06-04 document have to be withdrawn

This document supersedes EN 61326-2-4:2013 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

#### **Endorsement notice**

The text of the International Standard IEC 61326-2-4:2020 was approved by CENELEC as a European Standard without any modification.

– 2 – IEC 61326-2-4:2020 © IEC 2020

#### CONTENTS

FOREWORD			
1	Scope		
2	2 Normative references		
3	3 Terms and definitions5		
4	4 General7		
5 EMC test plan			
	5.1	General7	
	5.2	Configuration of EUT during testing7	
	5.3	Operation conditions of EUT during testing	
	5.4	Specification of FUNCTIONAL PERFORMANCE	
	5.5	Test description	
6 Immunity requirements		inity requirements	
	6.1	Conditions during the tests	
	6.2	Immunity test requirements9	
	6.3	Random aspects	
	6.4	Performance criteria11	
7 Emission requirements		sion requirements	
	7.1	Conditions during measurements	
	7.2	Emission limits	
8	3 Test results and test report		
9	9 Instructions for use		
Ar EG	nex A ( UIPMEN	normative) Immunity test requirements for PORTABLE TEST AND MEASUREMENT r powered by battery or from the circuit being measured	
Bibliography15			
Та	ıble 101	- Immunity tests	
Table 102 – Performance criteria definition    11			
Table 103 – Test conditions for quiescent and operate modes 12			

IEC 61326-2-4:2020 © IEC 2020

INTERNATIONAL ELECTROTECHNICAL COMMISSION

#### ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE – EMC REQUIREMENTS –

#### Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61326-2-4 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical change with respect to the previous edition:

- update of the document with respect to IEC 61326-1:2020.

- 4 -

IEC 61326-2-4:2020 © IEC 2020

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65A/981/FDIS	65A/992/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this document the following print types are used:

 Terms used throughout this document which have been defined in Clause 3 of this document and of IEC 61326-1:2020: SMALL CAPITALS.

This part of the IEC 61326 series is to be used in conjunction with IEC 61326-1:2020 and follows the same numbering of clauses, subclauses, tables and figures.

When a particular subclause of IEC 61326-1 is not mentioned in this part, that subclause applies as far as is reasonable. When this standard states "addition", "modification" or "replacement", the relevant text in IEC 61326-1 is to be adapted accordingly.

NOTE The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in IEC 61326-1;
- unless notes are in a new subclause or involve notes in IEC 61326-1, they are numbered starting from 101 including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

A list of all parts of the IEC 61326 series, under the general title *Electrical equipment for measurement, control and laboratory use, control and laboratory use – EMC requirements,* can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

#### ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE – EMC REQUIREMENTS –

#### Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9

#### 1 Scope

In addition to IEC 61326-1, this part of IEC 61326 specifies more detailed test configurations, operational conditions and performance criteria than IEC 61326-1 for equipment for

- insulation monitoring according to IEC 61557-8;
- insulation fault location according to IEC 61557-9.

This applies to insulation monitoring devices and for equipment for insulation fault location systems permanently or semi-permanently connected to the distribution system.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Clause 2 of IEC 61326-1:2020 applies, except as follows:

Addition:

IEC 61326-1:2020, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements

IEC 61557-8:2014, Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems

IEC 61557-9:2014, Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems

#### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61326-1:2020 apply, except as follows.