BS EN 61158-3-3:2014



BSI Standards Publication

Industrial communication networks — Fieldbus specifications

Part 3-3: Data-link layer service definition — Type 3 elements



BS EN 61158-3-3:2014 BRITISH STANDARD

National foreword

This British Standard is the UK implementation of EN 61158-3-3:2014. It is identical to IEC 61158-3-3:2014. It supersedes BS EN 61158-3-3:2008 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee AMT/7, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.

Published by BSI Standards Limited 2014

ISBN 978 0 580 79363 9

ICS 25.040.40; 35.100.20; 35.240.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 October 2014.

Amendments/corrigenda issued since publication

Date Text affected

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 61158-3-3

October 2014

ICS 25.040.40; 35.100.20; 35.110

Supersedes EN 61158-3-3:2008

English Version

Industrial communication networks - Fieldbus specifications - Part 3-3: Data-link layer service definition - Type 3 elements (IEC 61158-3-3:2014)

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 3-3: Définition des services de la couche liaison de données - Éléments de type 3 (CEI 61158-3-3:2014) Industrielle Kommunikationsnetze - Feldbusse - Teil 3-3: Dienstfestlegungen des Data Link Layer (Sicherungsschicht) - Typ 3-Elemente (IEC 61158-3-3:2014)

This European Standard was approved by CENELEC on 2014-09-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/759/FDIS, future edition 2 of IEC 61158-3-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-3-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at (dop) 2015-06-17 national level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with (dow) 2017-09-17 the document have to be withdrawn

This document supersedes EN 61158-3-3:2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-3-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-2	NOTE	Harmonized as EN 61158-2.
IEC 61158-4-3	NOTE	Harmonized as EN 61158-4-3.
IEC 61158-5-3	NOTE	Harmonized as EN 61158-5-3.
IEC 61158-6-3	NOTE	Harmonized as EN 61158-6-3.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	EN/HD	Year
IEC 61158-1	-	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-

CONTENTS

INT	ROD	JCTION	7
1	Scop	e	8
	1.1	General	8
	1.2	Specifications	8
	1.3	Conformance	9
2	Norn	native references	9
3	Term	s, definitions, symbols, abbreviations and conventions	9
	3.1	Reference model terms and definitions	9
	3.2	Service convention terms and definitions	11
	3.3	Common data-link service terms and definitions	12
	3.4	Additional Type 3 data-link specific definitions	13
	3.5	Common symbols and abbreviations	15
	3.6	Additional Type 3 symbols and abbreviations	16
	3.7	Common conventions	18
	3.8	Additional Type 3 conventions	19
4	Conr	nectionless-mode data-link service	20
	4.1	General	20
	4.2	Model of the connectionless-mode data-link service	20
	4.3	Sequence of primitives	22
	4.4	Detailed description of DL services	25
5	DL-n	nanagement Service	44
	5.1	General	44
	5.2	Facilities of the DLMS	44
	5.3	Services of the DL-management	45
	5.4	Overview of interactions	
	5.5	Detailed specification of services and interactions	48
Bib	liogra	phy	68
	4		40
_		Relationships of DLSAPs, DLSAP-addresses and group DL-addresses	
•		– SDA service	
Fig	ure 3	– SDN service	23
Fig	ure 4	- SRD service	23
Fig	ure 5	– MSRD service	24
Fig	ure 6	- CS service	24
		 Reset, Set value, Get value, Ident (local), DLSAP status, DLSAP activate, ctivate responder, DLSAP activate subscriber and DLSAP deactivate services 	47
Fia	ure 8	– Event service	47
		- Ident (remote) service	
9			
Tak	ole 1 -	- Summary of DL services and primitives	22
Tab	ole 2 -	- SDA data ack primitives and parameters	26
Tab	ole 3 -	- Values of DL_status for the SDA data ack service	28
Tab	ole 4 -	- SDN data primitives and parameters	29

Table 6 CDD data raply primitives and parameters	
Table 6 – SRD data reply primitives and parameters	. 32
Table 7 – Values of Update_status for the SRD data reply service	. 33
Table 8 – Additional values of DL_status for the SRD data reply service	. 34
Table 9 – SRD reply-update primitives and parameters	. 34
Table 10 – Values of DL_status for the SRD reply-update service	. 36
Table 11 – MSRD MCT data reply primitives and parameters	. 37
Table 12 – MSRD DXM data reply primitive and parameters	. 39
Table 13 – CS time event primitives and parameters	. 41
Table 14 – Values of DL_status for the CS time event service	. 42
Table 15 – CS clock value primitives and parameters	. 42
Table 16 – Values of CS_status for the CS clock value service	. 44
Table 17 – Values of DL_status for the CS clock value service	. 44
Table 18 – Summary of DL-management services and primitives	. 47
Table 19 – Reset primitives and parameters	. 48
Table 20 – Values of DLM_status for the reset service	. 48
Table 21 – Set value primitives and parameters	.49
Table 22 – Mandatory DLE-variables	. 50
Table 23 – Optional DLE-variables	. 50
Table 24 – Permissible values of mandatory DLE-variables	. 51
Table 25 – Permissible values of optional DLE-variables	. 51
Table 26 – Meaning of the values for the parameter isochronous_mode	. 52
Table 27 – Default reaction times and operating parameters for a master station for asynchronous transmission	. 52
Table 28 – Default reaction times and operating parameters for a slave station with asynchronous transmission	. 52
Table 29 – Default reaction times and operating parameters for master stations for coupling of synchronous and asynchronous transmission segments	. 53
Table 30 – Default reaction times and operating parameter for slave stations for coupling of synchronous and asynchronous transmission segments	. 53
Table 31 – Values of DLM_status for the set value service	. 53
Table 32 – Get value primitives and parameters	. 54
Table 33 – Additional mandatory DLE-variables in master stations	. 54
Table 34 – Permissible values of the additional DLE-variables in master stations	. 55
Table 35 – Values of DLM_status for the get value service	. 55
Table 36 – Event primitive and parameters	. 55
Table 37 – Mandatory DLL events and fault types	. 56
Table 38 – Permissible values of T _{SH}	. 56
Table 39 – Ident primitives and parameters	
Table 40 – Ident_list for the ident service	
Table 41 – Values of DLM_status for the ident service (local)	
Table 42 – Values of DLM_status for the ident service (remote)	
Table 43 – DLSAP status primitives and parameters	
·	50

Table 45 – DLSAP activate primitives and parameters	60
Table 46 – DLSAP activate service_list	60
Table 47 – DLSAP activate DLSDU_length_list (SDA, SDN, SRD, MSRD and CS)	61
Table 48 – DLSDU lengths of SDA and SDN as used in the DLSAP activate service	62
Table 49 – DLSDU lengths of SRD and MSRD as used in the (master station) DLSAP activate service	62
Table 50 – DLSDU lengths of CS as used in the DLSAP activate service	62
Table 51 – Values of DLM_status for the DLSAP activate service	62
Table 52 – DLSAP activate responder primitives and parameters	63
Table 53 – DLSDU_length_list for the DLSAP activate responder service	63
Table 54 – DLSDU length of SRD and MSRD as used in the DLSAP activate responder service	64
Table 55 – Values of DLM_status for the DLSAP activate responder service	65
Table 56 – DLSAP activate subscriber primitives and parameters	65
Table 57 – DLSDU_length_list for the DLSAP activate subscriber service	66
Table 58 – DLSDU lengths of MSRD as used in the DLSAP activate subscriber service (master and slave stations)	66
Table 59 - Values of DLM_status for the DLSAP activate subscriber service	66
Table 60 – DLSAP deactivate primitives and parameters	67
Table 61 – Values of DLM_status for the DLSAP deactivate service	67

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the "three-layer" fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term "service" refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-3: Data-link layer service definition – Type 3 elements

1 Scope

1.1 General

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term "time-critical" is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 3 fieldbus data-link layer in terms of

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take; and
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 3 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model, and
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.