

BS EN 61158-4-13:2014



BSI Standards Publication

Industrial communication networks — Fieldbus specifications

Part 4-13: Data-link layer protocol specification — Type 13 elements

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 61158-4-13:2014. It is identical to IEC 61158-4-13:2014. It supersedes BS EN 61158-4-13:2008 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee AMT/7, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.

Published by BSI Standards Limited 2014

ISBN 978 0 580 79445 2

ICS 24.040.40; 35.100.20; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2014.

Amendments/corrigenda issued since publication

Date	Text affected
-------------	----------------------

English Version

**Industrial communication networks - Fieldbus specifications -
Part 4-13: Data-link layer protocol specification - Type 13
elements
(IEC 61158-4-13:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 4-13: Spécification du protocole de la
couche liaison de données - Éléments de type 13
(CEI 61158-4-13:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-13:
Protokollspezifikation des Data Link Layer
(Sicherheitsschicht) - Typ 13-Elemente
(IEC 61158-4-13:2014)

This European Standard was approved by CENELEC on 2014-09-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/762/FDIS, future edition 2 of IEC 61158-4-13, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-4-13:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-19

This document supersedes EN 61158-4-13:2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-4-13:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for bibliography, the following notes have to be added for the standards indicated:

IEC 61158-1:2014	NOTE	Harmonised as EN 61158-1:2014
IEC 61158-3-13:2014	NOTE	Harmonised as EN 61158-3-13:2014
IEC 61158-5-13:2014	NOTE	Harmonised as EN 61158-5-13:2014
IEC 61158-6-13:2014	NOTE	Harmonised as EN 61158-6-13:2014
IEC 61784-1	NOTE	Harmonised as EN 61784-1
IEC 61784-2	NOTE	Harmonised as EN 61784-2

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61588	-	Precision clock synchronization protocol for networked measurement and control systems	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic reference model: Naming and addressing	-	-
ISO/IEC 8802-3	2000	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-

CONTENTS

INTRODUCTION.....	7
1 Scope.....	8
1.1 General.....	8
1.2 Specifications.....	8
1.3 Procedures.....	8
1.4 Applicability.....	9
1.5 Conformance.....	9
2 Normative references	9
3 Terms, definitions, symbols, abbreviations and conventions	9
3.1 Reference model terms and definitions.....	9
3.2 Service convention terms and definitions.....	11
3.3 Data-link service terms and definitions	12
3.4 Symbols and abbreviations.....	16
3.5 Common conventions	17
3.6 Additional conventions	18
4 Overview of the DL-protocol	18
4.1 Overview	18
4.2 General description	18
4.3 Service assumed from the PhL.....	21
4.4 DLL architecture.....	22
4.5 Local parameters and variables.....	23
5 General structure and encoding of PhPDUs and DLPDU and related elements of procedure.....	26
5.1 Overview	26
5.2 MA_PDU structure and encoding.....	26
5.3 Common MAC frame structure, encoding and elements of procedure	26
5.4 Invalid DLPDU.....	28
6 DLPDU-specific structure, encoding and elements of procedure	29
6.1 General	29
6.2 Overview	29
6.3 Start of synchronization (SoC).....	29
6.4 PollRequest (PReq).....	31
6.5 Poll response (PRes)	34
6.6 Start of asynchronous (SoA).....	37
6.7 Asynchronous send (ASnd)	41
7 DLE elements of procedure	45
7.1 Overall structure.....	45
7.2 Cycle state machine (CSM)	45
7.3 Isochronous transmission TX/RX control (ITC)	64
7.4 Asynchronous transmission TX/RX control (ATC)	69
7.5 Asynchronous slot scheduler (ASS).....	74
7.6 Exception signaling (ES)	75
7.7 NMT signaling (NS).....	78
7.8 DLL management protocol.....	79
Bibliography.....	83

Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses	14
Figure 2 – Slot communication network management.....	19
Figure 3 – Overall flow of data frames during one cycle	19
Figure 4 – Interaction of PhS primitives to DLE	21
Figure 5 – Data-link layer internal architecture	23
Figure 6 – Type 13 fieldbus DLPDU	26
Figure 7 – State transition diagram of the MNs CSM.....	51
Figure 8 – State transition diagram of MNs CSM at CSM_MS_NON_CYCLIC	53
Figure 9 – State transition diagram of MNs CSM at CSM_MS_CYCLIC.....	55
Figure 10 – State transition diagram of the CNs CSM	59
Figure 11 – State transition diagram of CNs CSM at CSM_CS_NON_CYCLIC	60
Figure 12 – State transition diagram of CNs CSM at CSM_CS_CYCLIC.....	61
Figure 13 – Multiple slot assignment example	65
Figure 14 – Time triggered PRes example	67
Figure 15 – State transition diagram of ITC.....	68
Figure 16 – State transition diagram of ATC	71
Figure 17 – State transition diagram of ASS	74
Figure 18 – State transition diagram of ES.....	77
Figure 19 – State transition diagram of NS.....	79
Figure 20 – State transition diagram of DLM	81
Table 1 – Data-link layer components	22
Table 2 – MAC multicast addresses	27
Table 3 – Message types	27
Table 4 – Node ID assignment.....	28
Table 5 – Structure of SoC DLPDU	30
Table 6 – Structure of SoC-Flag.....	30
Table 7 – Structure of PReq DLPDU	32
Table 8 – Structure of PReq-Flag.....	33
Table 9 – Structure of PRes DLPDU	34
Table 10 – Structure of PRes-Flag	35
Table 11 – Structure of SoA DLPDU	38
Table 12 – Structure of SoA-Flag.....	38
Table 13 – Definition of the RequestedServiceID in the SoA DLPDU.....	39
Table 14 – Structure of ASnd DLPDU	42
Table 15 – Definition of the ServiceID in the ASnd DLPDU	42
Table 16 – Structure of NMTRrequest user data.....	43
Table 17 – Primitives exchanged between CSM and ITC	46
Table 18 – Parameters used with primitives exchanged between CSM and ITC	46
Table 19 – Primitives exchanged between CSM and ATC	47
Table 20 – Parameters used with primitives exchanged between CSM and ATC.....	47
Table 21 – Primitives exchanged between CSM and ASS	48

Table 22 – Parameters used with primitives exchanged between CSM and ASS	48
Table 23 – Primitives exchanged between CSM and ES	49
Table 24 – Parameters used with primitives exchanged between CSM and ES	49
Table 25 – Primitives exchanged between CSM and NS	49
Table 26 – Parameters used with primitives exchanged between CSM and NS	50
Table 27 – Primitives exchanged between CSM and DLM.....	50
Table 28 – Parameters used with primitives exchanged between CSM and DLM.....	50
Table 29 – Transitions of the MNs CSM	52
Table 30 – Transitions of MNs CSM at CSM_MS_NON_CYCLIC	53
Table 31 – Transitions of MNs CSM at CSM_MS_CYCLIC	56
Table 32 – Transitions of the CNs CSM	59
Table 33 – Transitions of CNs CSM at CSM_CS_NON_CYCLIC	60
Table 34 – Transitions of CNs CSM at CSM_CS_CYCLIC.....	61
Table 35 – CSM function table	63
Table 36 – Example of isochronous slot assignment	66
Table 37 – Primitives exchanged between ITC and DLS-user	67
Table 38 – Parameters used with primitives exchanged between ITC and DLS-user	68
Table 39 – Transitions of ITC.....	68
Table 40 – ITC function table	69
Table 41 – Primitives exchanged between ATC and DLS-user	69
Table 42 – Parameters used with primitives exchanged between ATC and DLS-user	70
Table 43 – Primitives exchanged between ATC and ES	71
Table 44 – Parameters used with primitives exchanged between ATC and ES	71
Table 45 – Transitions of ATC	72
Table 46 – ATC function table.....	74
Table 47 – Transitions of ASS	75
Table 48 – ASS function table.....	75
Table 49 – Primitives exchanged between ES and DLS-user	76
Table 50 – Parameters used with primitives exchanged between ES and DLS-user	76
Table 51 – Transitions of ES.....	77
Table 52 – Primitives exchanged between NS and DLS-user	78
Table 53 – Parameters used with primitives exchanged between NS and DLS-user	78
Table 54 – Transitions of NS.....	79
Table 55 – Primitives exchanged between DLM and DLS-user	79
Table 56 – Parameters used with primitives exchanged between DLM and DLS-user.....	80
Table 57 – Transitions of DLM	81
Table 58 – DLM function table	82

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-13: Data-link layer protocol specification – Type 13 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

- a) in a synchronously-starting cyclic manner, according to a pre-established schedule, and
- b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This standard specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) procedures for giving communications opportunities to all participating DL-entities, sequentially and in a cyclic manner for deterministic and synchronized transfer at cyclic intervals up to one millisecond;
- c) procedures for giving communication opportunities available for time-critical data transmission together with non-time-critical data transmission without prejudice to the time-critical data transmission;
- d) procedures for giving cyclic and acyclic communication opportunities for time-critical data transmission with prioritized access;
- e) procedures for giving communication opportunities based on ISO/IEC 8802-3 medium access control, with provisions for nodes to be added or removed during normal operation;
- f) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.