BS 8414-2:2015

Incorporating Corrigendum No. 1



BSI Standards Publication

Fire performance of external cladding systems –

Part 2: Test method for non-loadbearing external cladding systems fixed to and supported by a structural steel frame



...making excellence a habit."

Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2015

Published by BSI Standards Limited 2015

ISBN 978 0 580 91691 5

ICS 13.220.50

The following BSI references relate to the work on this document: Committee reference FSH/21 Draft for comment 14/30287010 DC

Publication history

First published October 2005 Second (present) edition, April 2015

Amendments issued since publication

Date

Text affected

September 2015

C1 – See Foreword

Contents

Foreword ii

- 1 Scope 1
- 2 Normative references 1
- **3** Terms and definitions *1*
- 4 Principle 2
- 5 Test apparatus 2
- 6 Test specimen 7
- 7 Conditioning 7
- 8 Procedure 7
- 9 Post-test examination 8
- **10** Test report *9*

Annexes

Annex A (normative) Timber crib source 10 Annex B (informative) An example of a structural steel test frame 12

Bibliography 14

List of figures

Figure 1 – Schematic of test apparatus 4

Figure 2 – Location of thermocouples for a cladding test 6

Figure A.1 – Side elevation and plan of the combustion chamber and position of crib (fire load) 11

Figure B.1 – Example of a steel test frame 13

List of tables

Table B.1 – Section details 12

Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 14, an inside back cover and a back cover.

Foreword

Publishing information

This part of BS 8414 is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 30 April 2015. It was prepared by Technical Committee FSH/21, *Reaction to Fire Tests*. A list of organizations represented on this committee can be obtained on request to its secretary.

Supersession

This part of BS 8414 supersedes BS 8414-2:2005, which is withdrawn.

Relationship with other publications

BS 8414 is published in two parts:

- Part 1: Test method for non-loadbearing external cladding systems applied to the masonry face of a building; and
- Part 2: Test method for non-loadbearing external cladding systems fixed to and supported by a structural steel frame.

Information about this document

This British standard was developed from BRE Fire Note 9 [1], following a recommendation by the then House of Commons Environment, Transport and Regional Affairs Committee [2] on the potential risk of fire spread in buildings via external cladding systems.

This is a full revision of the standard, and introduces the following principal changes:

- clarification and rewording of a number of requirements to align both parts of the standard (BS 8414-1 and BS 8414-2);
- removal of the option for using alternative fuel sources.

Text introduced or altered by Corrigendum No. 1 is indicated in the text by tags $C_1 \land C_1$. Minor editorial changes are not tagged.

Hazard warnings

WARNING. This British standard calls for the use of substances and/or procedures that might be injurious to health if adequate precautions are not taken. It refers only to technical suitability and does not absolve the user from legal obligations relating to health and safety at any stage.

Use of this document

It has been assumed in the preparation of this part of BS 8414 that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Presentational conventions

The provisions of this standard are presented in roman (i.e. upright) type. Its methods are expressed as a set of instructions, a description, or in sentences in which the principal auxiliary verb is "shall".

Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.

Contractual and legal considerations

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

BRITISH STANDARD

1 Scope

This British standard provides a test method for determining the fire performance characteristics of non-loadbearing external cladding systems, such as curtain walling, glazed elements, infill panels and insulated composite panels, fixed to and supported by a structural steel frame when exposed to an external fire under controlled conditions. The fire exposure is representative of an external fire source or a fully-developed (post-flashover) fire in a room, venting through an opening such as a window aperture that exposes the cladding to the effects of external flames, or from an external fire source.

This British Standard does not apply to non-loadbearing external rainscreen overcladding systems or external wall insulation systems applied to the face of a building, the fire testing of which are covered in BS 8414-1.

This British Standard does not cover exposure to radiant heat from a fire in an adjacent building.

NOTE Performance Criteria and Classification methodology of the external fire performance can be found in references such as Report BR 135: Fire performance of external thermal insulation for walls of multi-storey buildings [3].

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS EN 60584-1:2013, Thermocouples – Part 1:EMF specifications and tolerances

BS EN ISO 13943, Fire safety – Vocabulary

3 Terms and definitions

For the purposes of this British Standard the terms and definitions given in BS EN ISO 13943 and the following apply.

3.1 collapse

any part of the cladding system which falls away and becomes detached

3.2 damaged area

total of those surface areas which have been affected permanently by fire under specified conditions

[SOURCE: BS EN ISO 13943]

NOTE 1 Area is expressed in square metres.

NOTE 2 Users of this term should specify the types of damage to be considered. This includes loss of material, deformation, softening, melting, charring, combustion, pyrolysis or chemical attack.

3.3 external cladding system

complete cladding assembly

NOTE 1 This includes, for example, sheeting rails, fixings, cavities, insulation and membranes, coatings, flashings or joints.

NOTE 2 The limits of the cladding system are taken to be from the external weathering surface to the internal finished face of the structural frame.