



**CSA  
Group**

**C22.2 No. 127-15**

# **Equipment and lead wires**



# Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# ***Standards Update Service***

***C22.2 No. 127-15  
October 2015***

**Title:** *Equipment and lead wires*

To register for e-mail notification about any updates to this publication

- go to [shop.csa.ca](http://shop.csa.ca)
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **2423989**.

If you require assistance, please e-mail [techsupport@csagroup.org](mailto:techsupport@csagroup.org) or call 416-747-2233.

Visit CSA Group's policy on privacy at [www.csagroup.org/legal](http://www.csagroup.org/legal) to find out how we protect your personal information.

*C22.2 No. 127-15*  
***Equipment and lead wires***



*™A trade-mark of the Canadian Standards Association, operating as "CSA Group"*

*Published in October 2015 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at [shop.csa.ca](http://shop.csa.ca)  
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ISBN 978-1-4883-0104-9*

*© 2015 CSA Group  
All rights reserved. No part of this publication may be reproduced in any form whatsoever  
without the prior permission of the publisher.*

# Contents

Technical Committee on Wiring Products	4
Subcommittee on Flexible Cords/Equipment and Appliance Wires and Cables	6
Preface	8
<b>1 Scope</b>	<b>9</b>
<b>2 Reference publications</b>	<b>9</b>
<b>3 Definitions</b>	<b>10</b>
<b>4 General requirements</b>	<b>11</b>
<b>5 Construction</b>	<b>11</b>
5.1 Conductors	11
5.1.1 Material	11
5.1.2 Coated copper wires	11
5.1.3 Uncoated copper wires	11
5.1.4 Stranding	11
5.1.5 Diameter and area	12
5.1.6 Resistance	12
5.1.7 Joints	12
5.2 Separator	12
5.3 Insulation	13
5.3.1 General	13
5.3.2 Thickness	13
5.3.3 Braid coating	13
5.3.4 Colour	13
5.4 Covering over insulation — All types	13
5.5 Shields (optional)	14
5.6 Covering over shields	14
5.7 Jackets and coverings	14
5.8 Multiple-conductor constructions	15
5.8.1 Types	15
5.8.2 Construction	15
<b>6 Tests</b>	<b>17</b>
6.1 Equipment wires (see Tables 8 and 9)	17
6.1.1 Physical properties of insulation	17
6.1.2 Flame	17
6.1.3 Cold bend	17
6.1.4 Cold bend and dielectric	18
6.1.5 Low-temperature impact — Types TXFW and TLW	18
6.1.6 Heat-resistant properties	18
6.1.7 Dielectric strength following temperature conditioning	19
6.1.8 Deformation	19

6.1.9	Dielectric strength after heat deformation — Type GTF	20
6.1.10	Spark — All types	20
6.1.11	Dielectric strength at room temperature	20
6.1.12	Insulation resistance at room temperature	21
6.1.13	Dielectric strength at elevated temperature	21
6.1.14	Insulation resistance at elevated temperature	22
6.1.15	Insulation resistance at 50 °C — Type TXFW	22
6.1.16	Insulating varnish — Types TEW, REW, and TEWN	22
6.1.17	Durability of printing	22
6.1.18	Resistance to cutting — Type TXFW	23
6.1.19	Weather resistance — Type TXFW	24
6.1.20	Relative permittivity — Type TXFW	24
6.2	Lead wires (see Table 21)	24
6.2.1	Physical properties of insulations	24
6.2.2	Nylon covering	24
6.2.3	Heat-resistant properties	25
6.2.4	Deformation — Types CL904, CL1051, CL1054, CL1055, CL1056, CL1251, CL1252, CL1253, CL1254, and CL1255	26
6.2.5	Cold bend — All types	26
6.2.6	Flame	27
6.2.7	Burning particles — Types CL1054, CL1055, CL1056, CL1251, CL1252, CL1253, CL1254, CL1255, CL1502, and CL1503	27
6.2.8	Insulating varnish — All types	28
6.2.9	Dielectric strength at rated temperature — Types CL1055, CL1056, CL1251, CL1252, CL1253, CL1254, and CL1255	28
6.2.10	Durability of printing — Types of lead wires with surface ink printing	28
6.2.11	Ozone resistance — Types CL905, CL1055, CL1254, and CL1255	28
6.2.12	Flexibility — Type CL904 wire with an extruded nylon covering	29
6.2.13	Additional requirements for gasoline-vapour-resistant Type CL1251 lead wire	29
6.2.14	Conductor/insulation compatibility of uncoated copper conductors	30
6.2.15	Spark — All types	31
6.3	Types GTO and ICS cables (see Table 31)	31
6.3.1	Physical properties of insulation	31
6.3.2	Physical properties of jackets	32
6.3.3	Dielectric strength at room temperature — All types	32
6.3.4	Extended voltage application — All types	32
6.3.5	Horizontal flame (FT2)	33
6.3.6	Specific surface resistivity — Types having polyethylene insulation and a polyvinyl chloride jacket, and Type ICS	33
6.3.7	U-bend discharge — All types	34
6.3.8	Abrasion — GTO cables without coverings	34
6.3.9	Dielectric strength after aging — Type ICS	34
6.3.10	Dielectric strength test after oil immersion — Type ICS	35
6.3.11	Swelling — Type ICS	35
6.3.12	Weather (sunlight) resistance — GTO types	35
6.3.13	Spark — All types	35
6.4	Electronic wires — Single-conductor thermoplastic types and twin lead wires (see Table 35)	36
6.4.1	General	36

6.4.2	Physical properties of insulation	36
6.4.3	Physical properties of jackets	36
6.4.4	Physical properties of overall insulating covering	36
6.4.5	Properties of finished wires	37
6.5	Electronic wires — Multiple-conductor thermoplastic types (see	42
6.5.1	General	42
6.5.2	Physical properties of insulation	42
6.5.3	Physical properties of overall insulating coverings	42
6.5.4	Properties of finished wire	42
6.6	Electronic wires — Single-conductor thermoset types (see Table 43)	45
6.6.1	General	45
6.6.2	Physical properties of insulation	45
6.6.3	Physical properties of jackets	45
6.6.4	Physical properties of overall insulating covering	45
6.6.5	Properties of finished wire	46
6.7	Electronic wires — Multiple-conductor thermoset types (see Table 46)	49
6.7.1	General	49
6.7.2	Physical properties of insulation	49
6.7.3	Physical properties of overall insulating coverings	49
6.7.4	Properties of finished wire	49
<b>7</b>	<b>Marking</b>	<b>51</b>
7.1	Product	51
7.2	Package	52

---

# Technical Committee on Wiring Products

<b>K.L. Rodel</b>	Hubbell Canada LP, Pickering, Ontario <i>Category: Producer Interest</i>	<i>Chair</i>
<b>P. Desilets</b>	Leviton Manufacturing of Canada Limited, Pointe-Claire, Québec <i>Category: Producer Interest</i>	<i>Vice-Chair</i>
<b>W.J. Bryans</b>	Electro-Federation Canada, Toronto, Ontario	<i>Associate</i>
<b>W.J. Burr</b>	Burr and Associates, Campbell River, British Columbia <i>Category: General Interest</i>	
<b>C. Davis</b>	Electro Cables Incorporated, Trenton, Ontario <i>Category: Producer Interest</i>	
<b>S.W. Douglas</b>	International Association of Electrical Inspectors, Toronto, Ontario <i>Category: General Interest</i>	
<b>D. Drysdale</b>	Nexans Canada Inc, Milton, Ontario <i>Category: Producer Interest</i>	
<b>S.P. Hawkins</b>	Shawflex A Division of ShawCor Ltd., Toronto, Ontario	<i>Associate</i>
<b>R.J. Kelly</b>	Government of Nunavut-Dept of Community & Government Services, Iqaluit, Nunavut <i>Category: Regulatory Authority</i>	
<b>G. Montminy</b>	Régie du bâtiment du Québec, Québec, Québec <i>Category: Regulatory Authority</i>	
<b>B.F. O'Connell</b>	Pentair Thermal Management Canada Ltd., Trenton, Ontario	<i>Associate</i>



---

<b>T. Olechna</b>	Electrical Safety Authority, Mississauga, Ontario <i>Category: Regulatory Authority</i>	
<b>C. Samuels</b>	ConocoPhillips Canada, Calgary, Alberta	<i>Associate</i>
<b>M.K. Shea</b>	City of Victoria, Victoria, British Columbia <i>Category: Regulatory Authority</i>	
<b>T. Simmons</b>	British Columbia Institute of Technology, Burnaby, British Columbia <i>Category: General Interest</i>	
<b>E. Thompson</b>	Atkore International (Allied Tube & Conduit Corporation), Harvey, Illinois, USA <i>Category: Producer Interest</i>	
<b>A.Z. Tsisserev</b>	Applied Engineering Solutions Ltd., Vancouver, British Columbia <i>Category: General Interest</i>	
<b>J. Turner</b>	Swansea Consulting, Toronto, Ontario	<i>Associate</i>
<b>L. Letea</b>	CSA Group, Toronto, Ontario	<i>Project Manager</i>

# ***Subcommittee on Flexible Cords/ Equipment and Appliance Wires and Cables***

<b>J. Singh</b>	Domtech Inc., Trenton, Ontario	<i>Chair</i>
<b>D. Drysdale</b>	Nexans Canada Inc., Milton, Ontario	<i>Vice-Chair</i>
<b>J. Bunch</b>	Radix Wire, Cleveland, Ohio, USA	
<b>W.F. Constantine</b>	Draka Cableteq USA, North Dighton, Massachusetts, USA	
<b>J. Crossman</b>	Domtech Inc., Trenton, Ontario	
<b>C. Davis</b>	Electro Cables Incorporated, Trenton, Ontario	
<b>P. Desilets</b>	Leviton Manufacturing of Canada Limited, Pointe-Claire, Québec	
<b>P.V. Donovan</b>	Deca Cables Inc., Trenton, Ontario	
<b>G.L. Dorna</b>	Belden Wire & Cable Company Engineering Center, Richmond, Indiana, USA	
<b>S.B. Friedman</b>	General Cable Industries, Inc., Lincoln, Rhode Island, USA	
<b>B. Iyer</b>	Lake Cable, LLC, Bensenville, Illinois, USA	
<b>J. Johnson</b>	Electro Cables Incorporated, Trenton, Ontario	

<b>T. Rudd</b>	Shawflex A Division of ShawCor Ltd., Toronto, Ontario	
<b>S.L. Stene</b>	Underwriters Laboratories Inc., Santa Clara, California, USA	<i>Associate</i>
<b>D. Verhage</b>	Domtech Inc., Trenton, Ontario	
<b>L. Letea</b>	CSA Group, Toronto, Ontario	<i>Project Manager</i>

# Preface

This is the eighth edition of CSA C22.2 No. 127, *Equipment and lead wires*. It is one of a series of Standards issued by CSA Group under *Part II* of the *Canadian Electrical Code*. It supersedes the previous editions, published in 2009, 1999, 1995, 1988, 1981, 1966, and 1964.

For general information on the Standards of the *Canadian Electrical Code, Part II*, see the preface to CAN/CSA-C22.2 No. 0, *General Requirements — Canadian Electrical Code, Part II*.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Integrated Committee on Flexible Cords/Equipment and Appliance Wires, under the jurisdiction of the Technical Committee on Wiring Products and the Strategic Steering Committee on Requirements for Electrical Safety.

**Interpretations:** The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA’s procedures for interpretation shall be followed to determine the intended safety principle”.

**Notes:**

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Request for interpretation” in the subject line:*
  - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
  - b) *provide an explanation of circumstances surrounding the actual field condition; and*
  - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at [standardsactivities.csa.ca](http://standardsactivities.csa.ca).*
- 5) *This Standard is subject to review five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following*
  - a) *information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Proposal for change” in the subject line:*
  - b) *Standard designation (number);*
  - c) *relevant clause, table, and/or figure number;*
  - d) *wording of the proposed change;*
  - e) *rationale for the change.*

# C22.2 No. 127-15

## ***Equipment and lead wires***

### **1 Scope**

#### **1.1**

This Standard applies to insulated conductors intended for internal wiring of electrical equipment, for leads of transformers, motors, etc., and for luminous-tube signs and ignition systems, to be installed in accordance with the *Canadian Electrical Code, Part I*.

#### **1.2**

Constructions to which this Standard applies are shown in Tables 1 and 2. The Tables are not a complete summary of the construction details, but all of the items shown therein are requirements or limitations.

#### **1.3**

The values given in SI units are the units of record for the purposes of this Standard. The values given in parentheses are for information and comparison only.

#### **1.4**

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the Standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

## **2 Reference publications**

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

#### **CSA Group**

C22.1-15

*Canadian Electrical Code, Part I*

CAN/CSA-C22.2 No. 0-10 (R2015)

*General Requirements — Canadian Electrical Code, Part II*