



BSI Standards Publication

**Electric cables –  
Thermosetting insulated,  
armoured cables of rated  
voltages of 600/1 000 V  
and 1 900/3 300 V for fixed  
installations, having low  
emission of smoke and  
corrosive gases when  
affected by fire –  
Specification**

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2016

Published by BSI Standards Limited 2016

ISBN 978 0 580 86673 9

ICS 29.060.20

The following BSI references relate to the work on this standard:

Committee reference GEL/20/17

Draft for comment 15/30301443 DC

**Publication history**

First published December 1986

Second edition November 1990

Third edition August 1997

Fourth edition September 1997

Fifth (present) edition April 2016

**Amendments issued since publication**

<b>Date</b>	<b>Text affected</b>
-------------	----------------------

---

## Contents

Foreword *iii*

1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Rated voltage	3
5	Conductors	4
6	Insulation	4
7	Identification of cores	5
8	Laying-up	6
9	Bedding	6
10	Armour	7
11	Oversheath	8
12	Cable marking and additional information	9
13	End sealing	11
14	Schedule of tests	12
15	Test conditions	13
16	Routine tests	13
17	Sample tests	14
18	Type tests	15

### Annexes

Annex A (informative)	Guide to use and installation of cables	23
Annex B (normative)	Armour wire tests	30
Annex C (normative)	Compatibility test	32
Annex D (normative)	Abrasion resistance test	32
Annex E (normative)	Insulation resistance constant test on oversheath	33
Annex F (normative)	Resistance of conductor and armour	34
Annex G (informative)	Gross cross-sectional area of armour	36
Annex H (normative)	Test for shrinkage of oversheath on cable	37
Annex I (informative)	Guidance on type tests	38
Annex J (informative)	United Kingdom reference codes	41

Bibliography 42

### List of figures

Figure 1	An example of the marking on the oversheath of the cable	10
----------	--	----

### List of tables

Table 1	Maximum permitted voltages against rated voltage of cable	3
Table 2	Diameter of steel armour wire and mass of zinc coating	7
Table 3	Schedule of tests	12
Table 4	Single-core 600/1 000 V cables with copper conductors	17
Table 5	Two-core 600/1 000 V cables with copper conductors	18
Table 6	Three-core 600/1 000 V cables with copper conductors	19
Table 7	Four-core 600/1 000 V cables with copper conductors	20
Table 8	Five-core 600/1 000 V cables with copper conductors	21
Table 9	Multicore auxiliary 600/1 000 V cables with copper conductors	21
Table 10	Single-core 1 900/3 300 V cables with copper conductors	22
Table 11	Three-core 1 900/3 300 V cables with copper conductors	22
Table A.1	Selection of cables for a.c. systems	24
Table A.2	Test voltages after installation	29
Table B.1	Temperature correction multiplication factors	31
Table C.1	Compatibility requirements	32

Table D.1 – Vertical load requirements	33
Table F.1 – Maximum resistance of conductor and armour for single-core cable	34
Table F.2 – Maximum resistance of conductor and armour for two-, three-, four- and five-core cable	35
Table F.3 – Maximum resistance of conductor and armour for 600/1 000 V multicore auxiliary cables	35
Table G.1 – Gross cross-sectional area of armour wires for the single-core 600/1 000 V cable	36
Table G.2 – Gross cross-sectional area of armour wires for the two-, three-, four- and five-core 600/1 000 V cable	36
Table G.3 – Gross cross-sectional area of armour wires for 600/1 000 V multicore auxiliary cable	37
Table I.1 – Test schedule for the smoke emission test	40
Table J.1 – Historical cable codes included in BS 6724	41

### Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 42, an inside back cover and a back cover.

## Foreword

### Publishing information

This British Standard is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 30 April 2016. It was prepared by Subcommittee GEL/20/17, *Low voltage cables*, under the authority of Technical Committee GEL/20, *Electric cables*. A list of organizations represented on these committees can be obtained on request to their secretary.

### Supersession

This British Standard supersedes BS 6724:1997+A3:2008, which will be withdrawn on 30 April 2017.

### Information about this document

This is a full revision of the standard, and introduces the following principal changes.

- a) The range of cable types is restricted to cables with copper conductors.
- b) The marking requirements have been updated and clarified.
- c) Test methods have been updated in accordance with the latest BS EN standards.
- d) 48-core auxiliary cables have been removed as they are no longer market relevant.

The new edition takes account of:

- BS EN 50363 (replacing certain parts of BS 7655) on materials;
- BS EN 50395 (replacing Annex K of BS 6724:1997) on electrical tests;
- BS EN 50396 (replacing Annex D of BS 6724:1997) on thickness measurement;
- BS EN 60332-1-2 (replacing BS EN 50265-2-1);
- BS EN 60332-3-24 (replacing BS EN 50266-2-4); and
- BS EN 62230 (replacing BS EN 50356) on spark testing.

### Product certification/inspection/testing

Users of this British Standard are advised to consider the desirability of third-party certification/inspection/testing of product conformity with this British Standard. Users seeking assistance in identifying appropriate conformity assessment bodies or schemes may ask BSI to forward their enquiries to the relevant association.

### Hazard warnings

**WARNING.** This British Standard calls for the use of substances and/or procedures that can be injurious to health if adequate precautions are not taken. It refers only to technical suitability and does not absolve the user from legal obligations relating to health and safety at any stage.

### Use of this document

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

**Presentational conventions**

The provisions of this standard are presented in roman (i.e. upright) type. Its requirements are expressed in sentences in which the principal auxiliary verb is "shall".

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

**Contractual and legal considerations**

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**

## 1 Scope

This British Standard specifies requirements for the construction and performance of thermosetting insulated, armoured cables of rated voltages of 600/1 000 V and 1 900/3 300 V, having low emission of smoke and corrosive gases when affected by fire.

*NOTE 1 Other thermosetting insulated, armoured cables for voltages of 600/1 000 V and 1 900/3 300 V can be found in BS 5467, but these do not have low levels of emission of smoke and corrosive products under exposure to fire.*

This British Standard is applicable to cables for use in fixed installations in industrial areas, buildings or similar applications.

This British Standard specifies requirements for the following types of cables:

- a) 600/1 000 V cables, wire armoured and oversheathed having single-core, two-, three-, four- and five-core stranded copper conductor;
- b) 600/1 000 V multicore auxiliary cables, wire armoured, and oversheathed, stranded copper conductor; and
- c) 1 900/3 300 V cables, wire armoured and oversheathed, having single-core or three-core stranded copper conductor.

This British Standard is applicable to cables that are designed for a maximum sustained conductor temperature of 90 °C and for a maximum short-circuit conductor temperature of 250 °C (for a maximum of 5 s).

*NOTE 2 Limitation on the temperature of the cables may be imposed in situations where they might be touched or where they could touch other materials.*

*NOTE 3 Annex A gives a guide to the use and installation of cables, Annex B gives armour wire tests, Annex C gives a compatibility test, Annex D gives an abrasion resistance test, Annex E gives an insulation resistance constant test on oversheath, Annex F gives the resistance of conductor and armour, Annex G gives the gross cross-sectional area of armour, Annex H gives a test for shrinkage of oversheath on cable, Annex I gives guidance on type tests and Annex J gives the standard United Kingdom reference codes.*

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 7655-1.2, *Specification for insulating and sheathing materials for cables – Part 1: Cross-linked elastomeric insulating compounds – Section 1.2: General 90 °C application*

BS 7655-1.3, *Specification for insulating and sheathing materials for cables – Part 1: Elastomeric insulating compounds – Section 1.3: XLPE*

BS 7655-6.1, *Specification for insulating and sheathing materials for cables – Part 6: Thermoplastic sheathing compounds having low emission of corrosive gases, and suitable for use in cables having low emission of smoke when affected by fire – Section 6.1: General application thermoplastic types*

BS EN 10244-2:2009, *Steel wire and wire products – Non-ferrous metallic coatings on steel wire – Part 2: Zinc or zinc alloy coatings*

BS EN 50363-5, *Insulating, sheathing and covering materials for low voltage energy cables – Part 5: Halogen-free, cross-linked insulating compounds*

BS EN 50395, *Electrical test methods for low voltage energy cables*