

BSI Standards Publication

Fire resistance tests for non-loadbearing elements

Part 2: Ceilings



BS EN 1364-2:2018 BRITISH STANDARD

National foreword

This British Standard is the UK implementation of EN 1364-2:2018. It supersedes BS EN 1364-2:1999, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee FSH/22/-/7, Non loadbearing separating elements.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2018 Published by BSI Standards Limited 2018

ISBN 978 0 580 83887 3

ICS 13.220.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 28 February 2018.

Amendments/corrigenda issued since publication

Date Text affected

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 1364-2

January 2018

ICS 13.220.50; 91.060.30

Supersedes EN 1364-2:1999

English Version

Fire resistance for tests for non-loadbearing elements - Part 2: Ceilings

Essais de résistance au feu des éléments non porteurs -Partie 2: Plafonds Feuerwiderstandsprüfungen für nichttragende Bauteile - Teil 2: Unterdecken

This European Standard was approved by CEN on 8 October 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents Page European foreword......4 Introduction ______5 1 Normative references.......6 3 4 5 6 Size......7 6.1 Self-supporting ceilings exposed to fire from below or from above7 6.1.1 Number8 6.2 6.3 Design 8 6.3.1 6.3.2 6.3.3 Support conditions8 Construction.......9 6.4 6.5 Verification.......9 Installation of test specimen......9 General.......9 7.1 7.2 Supporting construction 9 General.......9 7.2.1 7.2.2 Exposure to fire from below......9 Exposure to fire from above......9 7.2.3 8 9.1 Furnace thermocouples (plate thermometers) 10 9.1.1 9.1.2 9.2 10 Test procedure.......11 10.1 10.2 Pressure control ______11 10.3 10.4 10.5 11 11.1 11.2

11.3	Insulation	12
12	Test report	12
13	Field of direct application of test results	
13.1	General	
13.2	Self-supporting ceilings exposed to fire from below or from above	12
13.2.1	Size	12
13.2.2	Fittings	13
13.2.3	Cavities above self-supporting ceilings	13
13.2.4	Cables, pipes, etc. above the ceiling	13
13.3	Suspended ceilings with fire from below	13
13.3.1	Size	13
13.3.2	Fittings	14
13.3.3	Cavity	14
13.3.4	Length of supporting hangers	14
13.3.5	Cables, pipes, etc. above the ceiling	14
13.4	Suspended ceilings with fire from above	14
13.4.1	Size	14
13.4.2	Cavity	14
13.4.3	Length of supporting hangers	14
13.4.4	Supporting construction with fire from above	14
	Cables, pipes, etc. above the ceiling	
13.5	Ceilings incorporating self-supporting and suspended parts with fire from below	15
13.5.1	Size	
13.5.2	Fittings	15
13.5.3	Cavity	15
13.5.4	Length of supporting hangers	15
	Cables, pipes etc. above the ceiling	
13.6	Ceilings incorporating self-supporting and suspended parts with fire from above	
13.6.1	Size	
13.6.2	Cavity	15
	Length of supporting hangers	
	Supporting construction with fire from above	
	Cables, pipes, etc. above the ceiling	
	oranhy	24
KINIIO	JEANNY	7.4

European foreword

This document (EN 1364-2:2018) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2018, and conflicting national standards shall be withdrawn at the latest by July 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1364-2:1999.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

The main changes with respect to the previous edition are listed below:

- a) locations of thermocouples are modified in line with the definitions in EN 1363-1;
- b) a more precise definition of the test specimen;
- c) more precise rules in the field of direct application.

EN 1364 'Fire resistance tests for non-loadbearing elements' consists of the following:

- Part 1: Walls
- Part 2: Ceilings
- Part 3: Curtain walling full configuration
- Part 4: Curtain walling part configuration
- Part 5: Air transfer grilles

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard has been prepared to provide a method of test for assessing the fire resistance of non-loadbearing ceilings. It is applicable to self-supporting ceilings as well as suspended ceilings, with either fire from below of from above.

This European Standard is not applicable to loadbearing systems. The fire resistance of loadbearing floors in conjunction with a suspended ceiling should be assessed by using EN 1365-2.

Caution — The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

Safety note — Monitoring for integrity by the cotton pad or other means and insulation by use of the roving thermocouple from above a test specimen (in the case of fire from below) or within a void beneath a fire test specimen (in the case of fire from above) can be hazardous unless the risks associated with these practices are considered and appropriate precautions taken to protect operators from radiation, smoke, hot gases and from contact with furnace flame.

Operators should not reach over the test specimen (in the case of fire from below) or enter the void beneath a test specimen (in the case of fire from above) to carry out inspection tests of any type during the test.

1 Scope

This part of EN 1364 specifies a method for determining the fire resistance of ceilings, which in themselves possess fire resistance independent of any building element above them. This European Standard is used in conjunction with EN 1363-1.

The method is applicable to ceilings, which are either suspended by hangers or fixed directly to a supporting frame or construction, and to self-supporting ceilings.

Within this test method, the ceiling is exposed to fire, with the exposure being applied either:

- a) from below the ceiling, or
- b) from above the ceiling to simulate fire within the cavity above the ceiling.

The contribution to fire resistance which a suspended ceiling might provide as a protective membrane to loadbearing elements is determined using the procedure given in EN 13381-1. The fire resistance of loadbearing floors in conjunction with a suspended ceiling can also be assessed by using tests according to EN 1365-2.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:2012, Fire resistance tests - Part 1: General Requirements

EN 1363-2, Fire resistance tests - Part 2: Alternative and additional procedures

EN ISO 13943, Fire safety - Vocabulary (ISO 13943)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1 and EN ISO 13943 and the following apply.

3.1

ceiling

non-loadbearing element of a building construction designed to provide horizontal fire separation

3.2

self-supporting ceiling

ceiling with a span between building constructions, without any additional hangers

3.3

suspended ceiling

ceiling which is suspended from a supporting construction

3.4

cavity

space between the upper surface of the ceiling and the underside of any floor, roof or its supporting construction