

ASSE/ANSI 1032-2023



Performance Requirements for
**Dual Check Valve Type Backflow
Preventers for Carbonated Beverage
Dispensers, Post Mix Type, and Non-
Carbonated Beverage Dispensers**

ASSE Board Approved: July 2023
ANSI Approved: August 2023
ICS Code: 13 060 20 | 55 230



General Information

Neither this standard, nor any portion thereof, may be reproduced without the written consent of ASSE International.

No product may be said to be ASSE listed unless the manufacturer has received approval from ASSE International and the product is listed in ASSE's online directory. Instructions for receiving the authorization to display the ASSE Seal are available from the ASSE International Office.

Organizations wishing to adopt or list any ASSE standard should print the ASSE standard number on the cover page first and in equal or larger type to that of the adopting or listing organization.

ASSE International
Mokena, Illinois
Copyright © 2023, 2021, 2011, 2004, 1980
All rights reserved.

Foreword

This foreword shall not be considered a part of the standard; however, it is offered to provide background information.

ASSE International is dedicated to the preservation of public health and safety through “Prevention Rather Than Cure.” ASSE standards are developed in the interest of consumer safety.

Prevention of contamination or pollution of potable water in plumbing systems, which is one of the major objectives of the Society’s Standards Program, is addressed by the development and promulgation of Standards embracing performance criteria for manufactured plumbing components designed to safeguard public health and safety.

The recognition of probable sources or causes of contamination or pollution of a potable water system, whereby it becomes unfit or undesirable for human consumption, is vital to the maintenance of the system’s continued potability.

While backflow into potable water lines is always a potential source of contamination, in connection with Post Mix Type Carbonated Beverage Dispensers, backflow of CO₂ gas into copper piping of the potable water system, causing copper carbonate poisoning, is especially serious and must always be protected against.

This standard is focused on those devices known as Dual (Double) Check Valves, which are one type of device recognized for backflow protection for use in connection with Post Mix Type Carbonated Beverage Dispensers. In addition to the inclusion of this device in the system, periodic inspection and servicing of the device is essential.

This standard is part of ASSE’s backflow prevention device standards, each of which cover a different type of backflow protection device; each tailored to the protective requirements essential to the specific system conditions in which it is installed and the degree of hazard involved.

Recognition is made of the time volunteered by members of the working group and of the support of the manufacturers who also participated in the meetings for this standard.

This standard does not imply ASSE’s endorsement of a product which conforms to these requirements. Compliance with this standard does not imply acceptance by any code body.

It is recommended that these devices be installed consistent with local codes by qualified and trained professionals. It is recommended that these devices be installed and maintained per the manufacturer’s instructions.

This standard was promulgated in accordance with procedures developed by the American National Standards Institute (ANSI).

2023 Product Standards Committee

Tsan-Liang Su, PhD – Chairman
Stevens Institute of Technology
Hoboken, NJ, USA

Karl Abrahamson
Saint Paul Department of Safety and Inspections
Cottage Grove, MN, USA

John Bertrand
Watts Water Technologies
Cleveland, OH, USA

Julia Briggs
NSF International
Ann Arbor, MI, USA

William Briggs Jr.
TSF Engineering
New York, NY, USA

Terry Burger (non-voting)
ASSE International
Cleveland, OH, USA

William Chapin
Professional Code Consulting, LLC
Cullman, AL, USA

Steve Ducharme
Piping Industry Technical College/UA 254
Winnipeg, MB, Canada

Mark E. Fish
Zurn Elkay Water Solutions
Cary, NC, USA

Fernando Fernandez
Toto USA Inc.
Ontario, CA, USA

Ron George
Plumb-Tech Design & Consulting Services LLC
Newport, MI, USA

Mark Gibeault
Kohler Company
Kohler, WI, USA

Daniel Gleiberman
Sloan Valve Company
Los Angeles, CA, USA

Brandon Gunnell
Precision Plumbing Products
Portland, OR, USA

Chris Haldiman
Watts Water Technologies
Springfield, MO, USA

Kevin Hardwick
Precision Plumbing Products
Portland, OR, USA

John F. Higdon, P.E.
Merit Brass Company
Matthews, NC, USA

Mike Johnson
Delta Faucet
Indianapolis, IN, USA

Jim Kendzel
American Supply Association
Itasca, IL, USA

Anthony Menafro
State of NJ Department of Community Affairs
Trenton, NJ, USA

Bob Neff
Delta Faucet
Pendleton, IN, USA

David Orton
NSF International
Ann Arbor, MI, USA

Thomas Pitcherello
Self
Bordentown, NJ, USA

Daniel Rademacher
Viega, LLC
Butte, MT, USA

Shabbir Rawalpindiwala
Self
Kohler, WI, USA

Billy Smith
ASPE
Montgomery, AL, USA

Chris White (non-voting)
ASSE International
Mokena, IL, USA

Chris Wright
Ontario Pipe Trades
Dundalk, ON, Canada

ASSE 1032 Working Group

Bert Bain

The Ford Meter Box Company
Wabash, IN, USA

Terry Burger (non-voting)

ASSE International
Cleveland, OH, USA

Pete Bertagna

Watts Watter Technologies
North Andover, MA, USA

Kevin Bretzman

The Ford Meter Box Company
Wabash, IN, USA

Sean Cleary

IAPMO BPI
Stranton, PA, USA

Joseph Feldman

Chudnow Manufacturing
Linden, NJ, USA

Chris Haldiman

Watts Water Technologies
Springfield, MO, USA

Ken Nolan

Watts Water Technologies
North Andover, MA, USA

Tom Valente

CSA Group
Independence, OH, USA

Contents

1.0	General	1
1.1	Application	1
1.2	Scope.....	1
1.3	Limitations on Design.....	2
1.4	Reference Standards.....	2
2.0	Test Specimens	3
2.1	Samples Submitted for Test.....	3
3.0	Performance Requirements and Compliance Testing	3
3.1	Hydrostatic Test	3
	Figure 1	3
3.2	Deterioration at Maximum Rated Temperature and Pressure Test.....	4
3.3	Endurance Cycling Test	4
	Figure 2	5
3.4	Hydrostatic Leakage Test of Check Valves.....	5
	Figure 3	6
3.5	Drip Tightness of Check Valves Test	6
3.6	Allowable Pressure Loss at Rated Flow Test.....	7
4.0	Detailed Requirements	8
4.1	Materials	8
4.2	Instructions for Marking and Installation	8
5.0	Definitions	8

ASSE/ANSI 1032-2023

Performance Requirements for Dual Check Valve Type Backflow Preventers for Carbonated Beverage Dispensers, Post Mix Type, and Non-Carbonated Beverage Dispensers

1.0 General

1.1 Application

Dual check valve type backflow preventers (for carbonated beverage dispensers, post mix type, and non-carbonated beverage dispensers), herein referred to as “device,” prevent carbon dioxide gas and carbonated water from backflowing into the potable water system which supplies the carbonating unit. These devices operate under continuous or intermittent pressure conditions.

1.2 Scope

1.2.1 Description

These devices consist of 2 independently acting check valves internally force loaded to a normally closed position and designed to operate under intermittent or continuous pressure conditions.

These devices shall be permitted to be equipped with a supplementary check valve installed downstream of the independently acting check valves.

1.2.2 Size Range

These devices shall be designed to accommodate 1/4 or 3/8 inch nominal pipe sizes (NPS) (8 or 10 mm DN).

1.2.3 Minimum Working Pressure

Devices shall be designed for a working pressure of not less than 200.0 psi (1379.0 kPa).

1.2.4 Temperature Range

Devices shall be designed to operate at temperatures of 33.0 °F to 110.0 °F (0.6 °C to 43.3 °C).