

ASME PTC 19.5-2022
[Revision of ASME PTC 19.5-2004 (R2013)]

Flow Measurement

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME PTC 19.5-2022
[Revision of ASME PTC 19.5-2004 (R2013)]

Flow Measurement

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: September 15, 2023

The next edition of this Code is scheduled for publication in 2027.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

“ASME” and the above ASME symbol are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved.

CONTENTS

Notice		xi
Foreword		xii
Committee Roster		xiv
Correspondence With the PTC Committee		xv
Section 1	Object, Scope, and Uncertainty	1
1-1	Object	1
1-2	Scope	1
1-3	Uncertainty	1
1-4	References to ASME Standards	1
Section 2	Definitions, Values, and Descriptions of Terms	3
2-1	General	3
2-2	Primary Definitions and Systems of Units	3
2-3	Symbols and Dimensions	3
2-4	Thermal Expansion	3
2-5	References	5
Section 3	Differential Pressure Class Meters	6
3-1	Nomenclature	6
3-2	General Equation for Mass Flow Through a Differential Pressure Class Meter	6
3-3	Basic Physical Concepts Used in the Derivation of the General Equation for Mass Flow .	6
3-4	Theoretical Flow — Liquid as the Flowing Fluid	8
3-5	Theoretical Flow — Gas or Vapor as the Flowing Fluid	10
3-6	Factors Not Accounted for in Theoretical Mass Flow by Idealized Flow Assumptions . . .	11
3-7	Discharge Coefficient, C , in the Incompressible Fluid Equation	11
3-8	Discharge Coefficient, C , and the Expansion Factor, ϵ , for Gases	12
3-9	Calculation of Expansion Factor, ϵ	12
3-10	Determining Discharge Coefficient for Differential Pressure Class Meters	12
3-11	Thermal Expansion/Contraction of Inlet Section and Primary Element	13
3-12	Selection and Recommended Use of Differential Pressure Class Meters	13
3-13	Restrictions of Use	15
3-14	Procedure for Sizing a Differential Pressure Class Meter	15
3-15	Flow Calculation Procedure	17
3-16	Sample Calculation	17
3-17	References	21
Section 4	Orifice Meters	23
4-1	Nomenclature	23
4-2	Introduction	23
4-3	Types of Thin-Plate, Square-Edged Orifices	23
4-4	Code Compliance Requirements	23

4-5	Multiple Sets of Differential Pressure Taps	23
4-6	Machining Tolerances, Dimensions, and Markings for Orifice Plate	24
4-7	Machining Tolerances and Dimensions for Differential Pressure Taps	27
4-8	Location of Temperature and Static Pressure Measurements	30
4-9	Empirical Formulations for Discharge Coefficient, C	30
4-10	Limitations and Uncertainty of Eq. (4-9-1) for Discharge Coefficient, C	31
4-11	Uncertainty of Expansion Factor, ε	32
4-12	Unrecoverable Pressure Loss	33
4-13	Calculations of Differential Pressure Class Flow Measurement Systematic Uncertainty . .	33
4-14	Procedure for Fitting a Calibration Curve and Extrapolation Technique	37
4-15	References	39
Section 5	Nozzles and Venturis	40
5-1	Nomenclature	40
5-2	Introduction	40
5-3	Required Proportions of ASME Nozzles	40
5-4	Nozzle Pressure Tap Requirements	46
5-5	Nozzle Installation Requirements	47
5-6	Discharge Coefficient for ASME Nozzles	48
5-7	The ASME Venturi Tube	49
5-8	Venturi Design and Design Variations	51
5-9	Venturi Pressure Taps	52
5-10	Discharge Coefficient of the ASME Venturi	53
5-11	Installation Requirements for the ASME Venturi	53
5-12	Laboratory Calibrations	53
5-13	Uncertainty of Expansion Factor, ε	53
5-14	Unrecoverable Pressure Loss	54
5-15	References	54
Section 6	Differential Pressure Class Meter Installation and Flow Conditioning Requirements	55
6-1	Nomenclature	55
6-2	Introduction	55
6-3	Metering Section Requirements	55
6-4	Meter Installation in the Metering Section	56
6-5	Additional Pipe Length Requirements	57
6-6	Flow Conditioners and Installation	62
6-7	Installation of Temperature Sensors	62
6-8	References	64
Section 7	Sonic Flow Nozzles and Venturis — Critical Flow, Choked Flow Conditions	65
7-1	Nomenclature	65
7-2	Introduction	65
7-3	Definitions and Description of Terms	70
7-4	Guiding Principles	72
7-5	Instruments and Methods of Measurement	72
7-6	Installation	76
7-7	Pressure and Temperature Measurements	77
7-8	Computation of Results	81

7-9	Flow Uncertainty	86
7-10	Discharge Coefficients	87
7-11	Other Methods and Examples	91
7-12	Special Applications	97
7-13	References	98
Section 8	Flow Measurement by Velocity Traverse	101
8-1	Nomenclature	101
8-2	Introduction	101
8-3	Traverse Measurement Locations	103
8-4	Recommended or Required Locations of Measurement Sections	110
8-5	Use and Calibration Requirements for Sensors	111
8-6	Flow Measurement by Pitot Rake	117
8-7	General Requirements	120
8-8	Flow Computation Corrections	120
8-9	Uncertainty Analysis	121
8-10	References	122
Section 9	Ultrasonic Flowmeters	123
9-1	Scope	123
9-2	Purpose	123
9-3	Definitions and Symbols	123
9-4	Applications	124
9-5	Flowmeter Description	125
9-6	Performance-Affecting Characteristics	129
9-7	Calibration	139
9-8	Error Sources and Their Reduction	141
Section 10	Tracer Method for Measuring Water Flow	145
10-1	Nomenclature	145
10-2	Introduction	145
10-3	Constant Rate Injection Method	145
10-4	Tracer Selection	146
10-5	Mixing Length and Mixing Distance	146
10-6	Procedure	148
10-7	Fluorometric Method of Analysis	149
10-8	Flow Test Setup	150
10-9	Uncertainty	154
10-10	Reference	155
Section 11	Vortex Shedding Meters	156
11-1	Nomenclature	156
11-2	Principle of Measurement	156
11-3	Flowmeter Descriptions	157
11-4	Application Considerations	158
11-5	Installation	160
11-6	Operation	161
11-7	Calibration and Uncertainty	161
11-8	References	164

Section 12	Mechanical Meters	165
12-1	Nomenclature	165
12-2	Introduction	165
12-3	Turbine Meters	166
12-4	Turbine Meter Signal Transducers and Indicators	166
12-5	Calibration	166
12-6	Recommendations for Use	168
12-7	Piping Installation and Disturbances	170
12-8	Example of Flow Measurement by Turbine Meter With Natural Gas	170
12-9	Random Uncertainty Due to Time Variance of Data	171
12-10	Field Checks	172
12-11	Positive Displacement Meters	172
12-12	References	175
Section 13	Coriolis Mass Flowmeters	177
13-1	Definitions and Nomenclature	177
13-2	Introduction	177
13-3	Meter Construction	179
13-4	Calibration and Uncertainty	181
13-5	Application Considerations	188
13-6	Field Uncertainty Examples	190
 Mandatory Appendix		
I	Laboratory Calibration Evaluation and Extrapolation	197
 Nonmandatory Appendices		
A	Pulsating Flow Measurement	204
B	Critical Flow Functions for Air by R. C. Johnson	217
C	Deviation of Johnson C* Values	218
D	Real Gas Correction Factors	219
E	Conversion Factors	223
F	Thermal Expansion Tables	233
G	Historical Definitions of Units of Measurement	242
 Figures		
3-4-1	Water Leg Correction for Flow Measurement	9
3-12.3-1	Unrecoverable Pressure Loss Versus Beta Ratio	16
4-6-1	Standard Orifice Plate	24
4-6.1-1	Deflection of an Orifice Plate by Differential Pressure	25
4-7-1	Location of Pressure Taps for Orifices With Flange Taps	28
4-7-2	Location of Pressure Taps for Orifices With Corner Taps	29
4-10.1-1	Minimum Reynolds Number for Flange Taps	32
5-3-1	High β Nozzle	41
5-3-2	Low β Nozzle	42
5-3-3	Throat Tap Nozzle for $\beta > 0.44$	42
5-3-4	Throat Tap Nozzle for $\beta \leq 0.44$	43

5-3-5	Throat Tap Nozzle End Detail	43
5-3-6	Example Throat Tap Nozzle Flow Section	44
5-3.4-1	ASME Nozzle Required Surface Finish to Produce a Hydraulically Smooth Surface	45
5-3.4-2	Boring in Flow Section Upstream of Nozzle	46
5-5.6-1	Nozzle With Diffusing Cone	48
5-6.2.1-1	Reference Curve for Throat Tap Nozzles	49
5-7-1	Profile of the ASME Venturi	50
6-5.3.1-1	Allowable Diameter Steps for 0.2% Additional Uncertainty	61
6-6.1-1	Flow Conditioner Designs	63
7-2-1	Ideal Mach Number Distribution Along Venturi Length at Typical Subcritical and Sonic Flow Conditions	67
7-2.2-1	Definition of Sonic Flow as the Maximum of the Flow [See Eq. (7-2-1)]	69
7-3.2-1	Schematic Representation of Flow Defects at Venturi Throat	71
7-3.2-2	Schematic Diagram of Sonic Surfaces at the Throat of an Axially Symmetric Sonic Flow Venturi Nozzle	72
7-4-1	Requirements for Maintaining Sonic Flow in Venturi Nozzles	73
7-4-2	Mass Flow Versus Back-Pressure Ratio for a Flow Nozzle Without a Diffuser and a Venturi Nozzle With a Diffuser	73
7-5.3.1-1	Standardized Toroidal Throat Sonic Flow Venturi Nozzle	75
7-5.3.3-1	Standardized Cylindrical Throat Sonic Flow Venturi	76
7-5.3.4-1	ASME Long-Radius Flow Nozzles	77
7-6.2-1	Standardized Inlet Flow Conditioner and Locations for Pressure and Temperature Measurements	78
7-6.3-1	Comparison of the “Continuous Curvature” Inlet With the “Sharp-Lip, Free-Standing” Inlet	78
7-7.1.1-1	Static and Total (Stagnation) Pressure Measurements on a Pipe	79
7-7.1.2-1	Standardized Pressure Tap Geometry Installation	80
7-8.3-1	Generalized Compressibility Chart	83
7-8.6.1-1	Calculation Processes for the Isentropic Path From Inlet to Sonic Throat for a Real Gas Using the Method of Johnson	85
7-10.2-1	Composite Results for Toroidal-Throat Venturi Nozzles	89
7-10.2-2	Mean Line Discharge Coefficient Curves for Toroidal-Throat Venturi Nozzles	90
7-11.1.1-1	Error in Method 3 for Air Based on Sonic Flow Functions When Using Air Property Data	92
7-11.1.4-1	Error in Sonic Flow Function, C^*_i , for Air Using Method 6 Based on Ideal Gas Theory With Ratio of Specific Heats Corresponding to the Inlet Stagnation State	95
8-3.1-1	Pipe Velocity Measurement Loci	104
8-3.2-1	Duct Velocity Measurement Loci for Gaussian Distribution	109
8-3.2-2	Recommended Number of Measurement Loci for the Equal-Area Method	110
8-5.1-1	Pitot Tubes Not Requiring Calibration	112
8-5.1-2	Pitot Tubes Needing Calibration But Acceptable	113
8-5.1.2-1	Wedge-Type Five-Hole Probe Installation Schematic	114
8-5.1.2-2	Five-Hole Probe Designs	115
8-5.1.2-3	The Fechheimer Probe Installation	116
8-6-1	Insertion Type Pitot Rake	118
8-6-2	Pitot Rake	119
8-6-3	Impact Pressure Tube Rake	120
9-5.1.3-1	Common Acoustic Path Configurations	126

9-5.3.2-1	Wetted Recessed Transducer Configuration	127
9-5.5-1	Acoustic Flow Measuring System Block Diagram	130
9-6.1.1.3-1	Reflective Path Transducer Configuration	131
9-6.1.2.5-1	Recessed Transducer Configuration	133
9-6.1.2.6-1	Protruding Transducer Configuration	133
9-6.1.2.7-1	Flush Transducer Configuration	134
9-6.1.2.9-1	Waveguide Transducer Configuration	135
9-6.2.2-1	Cross-Beam Transducer Configuration	136
9-8.4-1	Laminar (Blue) and Turbulent (Red) Flow Velocity Profiles and 1-, 2-, 3-, and 5-Beam Acoustic Patch Diagrams	143
10-5-1	Schematic Control Volume	147
10-5.1-1	Experimental Results	147
10-7.3-1	Example Calibration Curves	151
10-8.1-1	Tracer Injection Schematic	152
10-8.2-1	Sampling System	153
10-8.3-1	Fluorometer Signal Versus Time	153
11-2-1	Vortex Formation	157
11-5.5-1	Locations of Pressure and Temperature Measurements	161
11-7.1-1	Illustration of a K-Factor Curve	162
12-11-1	Positive Displacement Volumeters	173
12-11.3-1	Method of Interpolation of Positive Displacement Meter Performance From Calibration Data to Other Fluid Viscosity and Operating Conditions	175
13-3.1-1	Typical Mechanical Arrangement	179
13-3.1-2	Oscillating Flow Tubes	180
13-3.2-1	Electronic Transmitter	181
13-4.2.3-1	Typical Calibration Curve With Uncertainty Bands (2σ Limits Shown)	185
13-4.3.2.1-1	Temperature Effect on Zero (2σ Limits Shown)	186
13-4.3.2.2-1	Pressure Effect on Span (2σ Limits Shown)	187
13-5.1.2-1	Pressure Drop Versus Mass Flow	189
I-6.3-1	Regression of Calibration Data With 95% Confidence Limits	202
A-3.1-1	Measured Errors Versus Oscillating Differential Pressure Amplitude Relative to the Steady State Mean	205
A-3.2-1	Fluid-Metering System Block Diagram	207
A-3.6-1	Experimental and Theoretical Pulsation Error	210
A-4.1-1	Semi-Log Plot of Theoretical Meter Pulsation Error Versus Rotor Response Parameter for Sine Wave Flow Fluctuation, $D_2 = 0.1$, and Pulsation Index, $I = 0.1$ and 0.2	211
A-4.5-1	Experimental Meter Pulsation Error Versus Pulsation Index	213
B-1-1	Graph of Critical Flow Functions for Air	217
C-1-1	Graph of Deviation of Critical Flow Functions for Air (Shown in Figure B-1-1)	218
D-1-1	Graph of Correction Factors for Air to Real Gas From Ideal Gas, up to 30 atm	220
D-1-2	Graph of Correction Factors for Air to Real Gas From Ideal Gas, up to 100 atm	221
D-1-3	Graph of Correction Factors for Air to Real Gas From Ideal Gas, up to 300 atm	222
Tables		
2-3-1	Symbols Typically Used in Flow Measurement	4
3-1-1	Symbols Specifically Applied in Sections 3 through 6 (in Addition to Symbols in Table 2-3-1)	7

3-2-1	Values of Constants in the General Equation for Various Units	8
3-4-1	Units and Conversion Factor for Water Leg Correction for Flow Measurement	10
3-12.2-1	Uncertainty of Discharge Coefficient, C , (Uncalibrated) and Expansion Factor, ϵ	14
3-16-1	Natural Gas Analysis	17
4-6.1-1	Recommended Plate Thickness, E , for Stainless Steel Orifice Plate	25
4-13.1-1	Sensitivity Coefficients in the General Equation for Differential Pressure Meters	34
4-13.2.1-1	Example 1 — Systematic Uncertainty Analysis for Given Steam Flow Orifice Metering Run	35
4-13.2.2-1	Example 2 — Systematic Uncertainty Analysis for Given Steam Flow Orifice Metering Run	35
4-13.2.3-1	Example 3 — Systematic Uncertainty Analysis for Given Gas Flow and Meter Tube	36
4-13.4.1-1	Systematic Uncertainty, 0.075% Accuracy Class Differential Pressure Transmitter	38
4-13.4.2-1	Systematic Uncertainty, 0.075% Accuracy Class Static Pressure Transmitter	38
4-13.5-1	Systematic Uncertainty Analysis for Given Gas Flowmetering Run With Laboratory Calibration	38
6-5.1-1	Straight Lengths for Orifice Meters	58
6-5.1-2	Straight Lengths for Nozzles	59
6-5.1-3	Straight Lengths for Classical Venturi	60
6-6.1.1-1	Hole Coordinates for Perforated Plate	64
6-6.2-1	Loss Coefficients for Flow Conditioners	64
7-1-1	Symbols Specifically Applied in Section 7 (in Addition to Symbols in Table 2-3-1)	66
7-10.2-1	Summary of Points Plotted in Figure 7-10.2-1 and Coefficients for Eq. (7-10-2)	88
7-10.3-1	Discharge Coefficients for Cylindrical-Throat Venturi Nozzles	91
7-11.1.1-1	Percent Error in Method 3 Based on Sonic Flow Functions and Air Property Data	92
7-11.1.2.1-1	Sonic Flow Function, C^* , and Critical Property Ratios [Ideal Gases and Isentropic Relationships, Eqs. (7-2-7) through (7-2-9)] Versus Type of Ideal Gas	94
8-1-1	Symbols Specifically Applied in Section 8 (in Addition to Symbols in Table 2-3-1)	102
8-3.1-1	Locations and Weighting Factors for Gaussian Method in Pipes	105
8-3.1-2	Locations and Weighting Factors for Chebychev Method in Pipes	105
8-3.1-3	Locations and Weighting Factors for the Log-Linear Method in Pipes	106
8-3.1-4	Locations and Weighting Factors for the Equal-Area Method in Pipes	106
8-3.2-1	Locations and Weighting Factors for the Gaussian Method in Rectangular Ducts	107
8-3.2-2	Locations and Weighting Factors for Chebychev Method in Rectangular Ducts	108
8-3.2-3	Locations and Weighting Factors for the Equal-Area Velocity Method in Rectangular Ducts	109
8-9-1	Sample Uncertainty Estimate	122
9-3.2-1	Symbols Specifically Applied in Section 9 (in Addition to Symbols in Table 2-3-1)	124
10-1-1	Symbols Specifically Applied in Section 10 (in Addition to Symbols in Table 2-3-1)	146
10-7.2-1	Temperature Exponents for Tracer Dyes	149
10-9.2-1	Typical Uncertainties Using a Fluorescent Tracer	154
11-1-1	Symbols Specifically Applied in Section 11 (in Addition to Symbols in Table 2-3-1)	156
11-7.3-1	Recommended Distance From Disturbance for Less Than 0.5% Increase in Uncertainty .	163
11-7.4-1	Vortex Measurement Uncertainty Example	163
11-7.4-2	Vortex Measurement Uncertainty Example With Installation Uncertainty	164
11-7.4-3	Vortex Measurement Uncertainty Example With Vortex Meter, Pressure Sensor, and Temperature Sensor Uncertainties	164
12-1-1	Symbols Specifically Applied in Section 12 (in Addition to Symbols in Table 2-3-1)	165
13-1.2-1	Symbols Specifically Applied in Section 13 (in Addition to Symbols in Table 2-3-1)	178
13-4.2.1.3.1-1	Impact of Meter Tube Gas Velocity on Performance	182

13-4.2.1.3.2-1	Measurement Recommendations for Different Gas Test Pressures	183
13-4.2.2.4-1	Best Practices for Liquid and Gas Testing Data Collection Time	183
13-6.1-1	Example 1 — Analysis of Unheated Natural Gas Applications at Maximum Flow Rate . . .	191
13-6.1-2	Example 1 — Analysis of Unheated Natural Gas Application at Minimum Flow Rate . . .	192
13-6.2-1	Example 2 — Analysis of Heated Natural Gas Applications at Maximum Flow Rate	193
13-6.2-2	Example 2 — Analysis of Heated Natural Gas Applications at Minimum Flow Rate	194
13-6.3-1	Example 3 — Analysis of Liquid Condensate Application With Flowmeter Zeroed	195
13-6.4-1	Example 4 — Analysis of Liquid Condensate Application With Flowmeter Not Zeroed . .	196
I-1-1	Symbols Used in Mandatory Appendix I (in Addition to Symbols in Table 2-3-1)	197
I-6-1	Calibration Data, Test Data, and Predicted Value for an ASME Throat Tap Nozzle	201
A-3.1-1	Error Threshold Versus Relative Amplitude of ΔP	206
E-1-1	Conversions to SI (Metric) Units	224
E-1-2	Conversion Factors for Pressure (Force/Area)	226
E-1-3	Conversion Factors for Specific Volume (Volume/Mass)	227
E-1-4	Conversion Factors for Specific Enthalpy and Specific Energy (Energy/Mass)	228
E-1-5	Conversion Factors for Specific Entropy, Specific Heat, and Gas Constant [Energy/(Mass \times Temperature)]	230
E-1-6	Conversion Factors for Viscosity (Force \times Time/Area \sim Mass/Length \times Time)	231
E-1-7	Conversion Factors for Kinematic Viscosity (Area/Time)	232
F-1-1	Thermal Expansion Data (SI)	234
F-1-2	Thermal Expansion Data (U.S. Customary)	239

NOTICE

All ASME Performance Test Codes (PTCs) shall adhere to the requirements of ASME PTC 1, General Instructions. It is expected that the Code user is fully cognizant of the requirements of ASME PTC 1 and has read them before applying ASME PTCs.

ASME PTCs provide unbiased test methods for both the equipment supplier and the users of the equipment or systems. The Codes are developed by balanced committees representing all concerned interests and specify procedures, instrumentation, equipment-operating requirements, calculation methods, and uncertainty analysis. Parties to the test can reference an ASME PTC confident that it represents the highest level of accuracy consistent with the best engineering knowledge and standard practice available, taking into account test costs and the value of information obtained from testing. Precision and reliability of test results shall also underlie all considerations in the development of an ASME PTC, consistent with economic considerations as judged appropriate by each technical committee under the jurisdiction of the ASME Board on Standardization and Testing.

When tests are run in accordance with a Code, the test results, without adjustment for uncertainty, yield the best available indication of the actual performance of the tested equipment. Parties to the test shall ensure that the test is objective and transparent. All parties to the test shall be aware of the goals of the test, technical limitations, challenges, and compromises that shall be considered when designing, executing, and reporting a test under the ASME PTC guidelines.

ASME PTCs do not specify means to compare test results to contractual guarantees. Therefore, the parties to a commercial test should agree before starting the test, and preferably before signing the contract, on the method to be used for comparing the test results to the contractual guarantees. It is beyond the scope of any ASME PTC to determine or interpret how such comparisons shall be made.

FOREWORD

The history of this Instruments and Apparatus Supplement began when the American Society of Mechanical Engineers (ASME) organized the Research Committee on Fluid Meters in 1916. This Committee's stated objective was to prepare "a textbook on the theory and use of fluid meters sufficient as a standard reference." The first edition of Part 1 of their report, published in 1924, met that objective. It received immediate approval and was widely referenced by users of fluid meters and educators. The Committee originally planned to issue the report on Fluid Meters in three parts: Part 1, Their Theory and Application, followed by Parts 2, A Description of Meters, and 3, Selection and Installation. However, Part 1 was so well received that second and third editions were needed before the other two parts could be prepared. The second edition of Part 1 was considerably different from the first, although it followed roughly the same format and arrangement; the third edition was very similar to the second. These were published in 1927 and 1930, respectively.

Part 2 of the report was published in 1931 and contained a complete description of the physical characteristics of the meters then being manufactured. Unfortunately, the material in Part 2 rapidly became obsolete and the Committee decided to advise those interested in the descriptions to secure them from the manufacturers, whose literature would necessarily be up to date.

Part 3, published in 1933, gave instructions for correct installation of meters and discussed the effect of incorrect installation. However, Part 3 was also abandoned, in this case because the Committee decided the material in it should be an integral part of the complete report.

The fourth edition of Part 1 was issued in 1937 as a completely new draft. Earlier editions had been criticized because the material as presented was difficult to put to practical use. A change in format and the addition of new material apparently corrected this problem, since this edition went through many printings.

The fifth edition, issued in 1959, followed this successful general format and included material gained in the long interval since the previous edition. The Committee also issued a manual, Flowmeter Computation Handbook, in 1961. The procedures in this publication could be adapted to computer programming.

The format of the sixth edition, published in 1971, differed slightly from that of the fourth and fifth editions. Each section was complete by itself, so altering one section would not affect the preceding or following sections.

The sixth edition, somewhat like the third edition and its Part 3, was divided into two parts. The material on installation and application became both a part of the complete report and a separate publication, ASME Performance Test Code (PTC) 19.5, Flow Measurement. This was in accordance with an agreement made between the Research Committee on Fluid Meters and the Performance Test Code Committee in 1964. Practically all of the material in ASME PTC 19.5 was taken from Fluid Meters, and most of the writers were also members of the Research Committee on Fluid Meters. The two committees decided to combine the material into one publication in such a way that the sections dealing with specifications and instructions could be published separately, which would reduce the work of the committees and the number of separate publications. However, this publication also prompted considerable criticism that the material as presented was difficult to put to practical use.

Consequently, the Board on Performance Test Codes, which is now the PTC Standards Committee under the Board on Standardization and Testing, formed a committee to address these concerns. This committee produced ASME PTC 19.5-2004, Flow Measurement, which included a much broader range of methods of flow measurement than any of its predecessors. Even so, it did not include every method, only those that were judged at the time to meet the requirements and needs of test codes by providing results of the highest level of accuracy consistent with the best engineering knowledge and practice currently available.

ASME PTC 19.5-2022 provides guidance on the proper use of flowmeters including guidance on estimating their measurements' systematic uncertainties. The choice of flow-measurement devices and calibration requirements in any given case depends on the requirements of the PTC referencing this Supplement.

ASME PTC 19.5-2022 includes recommendations from the ASME Board on Standardization Testing Task Groups on ASME equations for fluid flow through a classic ASME venturi, wall tap nozzle, and orifice meter, which reconcile some differences between ASME PTC 19.5 and ASME MFC-3. These recommendations resulted in updates to the discharge coefficients for venturi meters, wall tap nozzles, and orifice meters; updates to the straight-length requirements; and some updates to the systematic uncertainties.

ASME PTC 19.5-2022 has added further guidance and a method for determining the uncertainty of extrapolating the calibration data of some flowmeters. The PTC referencing this Supplement should define the acceptable added uncertainty for extrapolation of the meter's data used in specific applications.

Sections have been added to cover the frequently used Coriolis and ultrasonic flowmeters. A new section on vortex meters, which are used in some performance testing, has also been added. PTC documents typically do not reference the use of electromagnetic flowmeters; the ASME PTC 19.5 Committee recommends the use of ASME MFC-16-2014 for guidance.

This Code is available for public review on a continuing basis. This provides an opportunity for additional input from industry, academia, regulatory agencies, and the public-at-large.

ASME PTC 19.5-2022 was approved by the PTC Standards Committee on April 21, 2021, and was approved as an American National Standard by the American National Standard Institute Board of Standards Review on January 5, 2022.

ASME PTC COMMITTEE

Performance Test Codes

(The following is the roster of the committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

S. A. Scavuzzo, *Chair*
T. K. Kirkpatrick, *Vice Chair*
D. Alonzo, *Secretary*

STANDARDS COMMITTEE PERSONNEL

P. G. Albert , Consultant	S. P. Nuspl , Consultant
D. Alonzo , The American Society of Mechanical Engineers	R. Pearce , Kansas City Power and Light
J. M. Burns , Burns Engineering Services, Inc.	S. A. Scavuzzo , The Babcock & Wilcox Co.
A. E. Butler , GE Power and Water	J. A. Silvaggio, Jr. , Siemens Demag Delaval Turbomachinery, Inc.
W. C. Campbell , Generating Plant Performance Consultants	T. L. Toburen , T2E3
J. Gonzalez , Generación SAU	W. C. Wood , Consultant
R. E. Henry , Consultant	T. C. Heil , <i>Alternate</i> , The Babcock & Wilcox Co.
D. R. Keyser , Survice Engineering	R. P. Allen , <i>Honorary Member</i> , Consultant
T. K. Kirkpatrick , McHale & Associates, Inc.	P. M. McHale , <i>Honorary Member</i> , McHale & Associates, Inc.
M. P. McHale , McHale & Associates, Inc.	R. R. Priestley , <i>Honorary Member</i> , Consultant
J. W. Milton , Chevron, USA	R. E. Sommerlad , <i>Honorary Member</i> , Consultant

PTC 19.5 COMMITTEE — FLOW MEASUREMENT

P. G. Albert , <i>Chair</i> , Consultant	D. R. Kuhny , Micro Motion, Inc.
K. Kenneally , <i>Vice Chair</i> , MPR Associates, Inc.	W. R. Murray , Krohne
M. Pagano , <i>Secretary</i> , The American Society of Mechanical Engineers	B. R. Novitsky , U.S. Air Force — AFMETCAL
A. G. Caswell, Jr. , Clean Air Engineering	J. B. Nystrom , Alden Research Lab
J. Dwyer , Primary Flow Signal, Inc.	F. Saldarriaga , Global Forensic Investigations
C. J. Erwin , GE Power	P. Stacy , Alden Research Lab
J. Foster , Emerson Process Management	R. Wakeland , Wakeland Engineering, PLLC
A. Hawley , Southwest Research Institute	K. W. John , <i>Alternate</i> , U.S. Air Force — AFMETCAL
A. Jackson-Sandfort , Vogt Power International	C. Wakeland , <i>Alternate</i> , Wakeland Engineering, PLLC
M. Keilty , Endress + Hauser Flowtec AG	A. Banerjee , <i>Contributing Member</i> , Lehigh University
D. R. Keyser , Survice Engineering	R. Jethra , <i>Contributing Member</i> , WIKA USA
S. Korellis , EPRI	T. K. Kirkpatrick , <i>Contributing Member</i> , McHale & Associates, Inc.

CORRESPONDENCE WITH THE PTC COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Code should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/PTCcommittee>.

Revisions and Errata. The committee processes revisions to this Code on a periodic basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Code. Approved revisions will be published in the next edition of the Code.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Code is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Code

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Code and the paragraph, figure, or table number(s)

(4) the edition(s) of the Code to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Code. An interpretation can be issued only in response to a request submitted through the online Interpretation Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Code requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The PTC Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/PTCcommittee>.

Section 1

Object, Scope, and Uncertainty

1-1 OBJECT

The purpose of this ASME Performance Test Code (PTC) Supplement is to give instructions and guidance for the accurate determination of flows commonly needed in support of individual PTCs. The choice of flow measurement device and calibration requirement depends on the requirements of the PTC referencing this Supplement. The purpose of the measurement, uncertainty required, and specific application must all be taken into consideration. It is not the intent of this Supplement to supersede the guidance or requirements of any PTC. The intent is to provide a common document that can be referenced by all PTCs.

1-2 SCOPE

This Supplement describes the techniques and methods of flow measurements required or recommended by ASME PTCs. A variety of commonly used flow measurement devices are included to provide details for the different applications referenced by various PTCs. This is a supplementary document that does not supersede the mandatory requirements of any PTC, unless such an agreement has been expressed in writing prior to testing or a PTC requires that specified sections or paragraphs within this Supplement be used.

1-3 UNCERTAINTY

This Supplement provides guidance on potential magnitudes and sources of uncertainty to assist in the derivation of the expected overall systematic uncertainty of a specific flow measurement. This overall systematic uncertainty includes estimated component uncertainties for

- (a) flow coefficients for an uncalibrated meter
- (b) calibration
- (c) extrapolation of a calibrated meter beyond its calibrated range
- (d) installation requirements and potential risks for deviations
- (e) additional requirements to improve the flow measurement

The uncertainty of any flow measurement depends on the type and design of the instrument; the characteristics of the flow along with flow conditioning upstream and downstream; the pressure, temperature, density, frequency output, and stability of the flow; and the installation of sensing lines for differential-pressure measurements.

The specific uncertainty for each flow measurement can be determined by information in this Supplement; the specific ASME PTC; ASME PTC 19.1; and, in some cases, manufacturer's guidance. The uncertainty values shown in this Supplement are typically systematic values for a component or examples of systematic uncertainties. The reported uncertainty values are at 95% confidence level. The uncertainty values represent plus/minus (\pm) values unless asymmetrical uncertainty exists, in which case the plus (+) and minus (-) values along with sign will be shown.

1-4 REFERENCES TO ASME STANDARDS

Below is a list of ASME publications referenced in this Code. In all cases, the latest edition shall apply. Specific references to ASME and other publications are included within each section.

ASME B31.1. Power Piping.

ASME B31.3. Process Piping.

ASME MFC-3M. Measurement of Fluid Flow in Pipes Using Orifice, Nozzle, and Venturi.

ASME MFC-7. Measurement of Gas Flow by Means of Critical Flow Venturi Nozzles.

ASME MFC-8M. Fluid Flow in Closed Conduits: Connections for Pressure Signal Transmissions Between Primary and Secondary Devices.

ASME MFC-16. Measurement of Liquid Flow in Closed Conduits with Electromagnetic Flowmeters.